Product Data Sheet December 2017 00813-0100-4016, Rev RF

Rosemount[™] DP Level Transmitters and 1199 Diaphragm Seal Systems



Applications

- Level, flow, pressure, interface, density
- Extreme hot and cold temperatures
- Corrosive, clogging, or viscous processes
- Hygienic requirements
- Special process connections



Proven, reliable, and innovative DP level technologies

To meet your application requirements, Rosemount DP Level technologies deliver an unsurpassed product offering that is easy to specify, order, and install. The offering includes a wide variety of process connections, direct mount or capillary connections, and materials of construction to address almost any application. If you don't see what you need listed here, ask us. We can create a custom engineered solution to meet your needs.

Rosemount Level Transmitters

Level transmitters combine world-class Rosemount pressure instrumentation with direct-mount seals, all in a single integrated model number.



Balanced system Tuned-system assembly



plus capillary

Rosemount 3051SAL, 3051L, and 2051L Level Transmitters

- Achieve best-in-class system reliability with all welded systems
- Wireless configurations provide new data access
- Connect to virtually any process with a comprehensive offering of process connections, fill fluids, direct mount or capillary connections, and materials
- Quantify and optimize total system performance with QZ option

Rosemount Tuned-System[™] Assemblies optimize results

- Reduce installed costs by 20 percent by eliminating excess capillary and transmitter mounting hardware
- Improve performance by up to 30 percent
- Increase response time by up to 80 percent
- Reduce risk with up-front quantified performance reports

Contents

Rosemount 3051S ERS System	. 5
Rosemount 3051S Scalable [™] Level Transmitter	22
Rosemount 3051L Level Transmitter	54
Rosemount 2051L Liquid Level Transmitter	62
Rosemount 1199 Direct Mount Seal Systems	69
Rosemount 1199 Remote Mount Seal Systems	75
Flanged seals	82

Threaded seals	103
Hygienic seals	108
Specialty seals	119
Specifications	126
Product certifications	142
Dimensional drawings	169

Rosemount 3051S Electronic Remote Sensor (ERS)[™] System

The Rosemount 3051S ERS System is a digital DP Level architecture that links two Rosemount 3051S Pressure Sensors together electronically. The pressure sensors are synchronized on a single power loop where the differential pressure, level, and volume are calculated and transmitted using a standard two-wire 4–20mA HART[®] signal.

A digital upgrade to a proven technology

- 90 percent improvement in time response
- Elimination of temperature effects and measurement drift
- Multivariable capabilities including DP, P_{LO}, P_{HI}, volume, and level
- Proven Rosemount 3051S Sensor technology

Simplified installations and maintenance routines

- Elimination of wet legs or dry legs
- Easy installations without need for heat tracing and insulation
- Proactive maintenance and troubleshooting with sensor alerts and diagnostics
- Simplified inventories with sensors and standard cable

Rosemount 1199 Seal Systems

A seal system consists of a pressure transmitter, one or two seals, a fill fluid, and either a direct mount or capillary style connection. Seal systems provide a reliable process pressure measurement and prevent the process medium from contacting the transmitter diaphragm. Transmitter/diaphragm seal systems should be considered when:

- The process temperature is outside of the operating ranges of the transmitter.
- The process is corrosive and/or requires specific exotic materials of construction.
- The process contains suspended solids or is viscous and is prone to plugging of connections.
- The application requires the use of flush-mount hygienic connections that facilitates CIP/SIP service.
- There is a requirement for easier cleaning of the process from the connections to avoid contamination between batches.

Application flexibility

- Flanged, threaded, and hygienic process connections
- Meets industry standards such as EN 1092-1, ANSI/ASME B16.5, JIS B2238, ANSI/ASME B1.20.1, EN 10226-1, GOST 33259-15, ISO 228-1
- Variety of fill fluids applications including cold temperature, hot temperature, and hygienic and food grade
- Three different capillary diameters allow for optimization of accuracy and time response.

Reliable system construction

- Welded design with no threaded connections
- 100 percent helium leak tested
- Advanced manufacturing techniques ensure air-free, leak-tight system that is stable over time
- Reliable operation in full vacuum applications

Robust seal design

- Backup convolutions on the diaphragm protect seal integrity.
- Recessed diaphragms reduce potential for handling damage.



Figure 1. Rosemount Seal System Construction Options Welded-repairable construction



- All connection pointed welded except gasket between sensor All connection points welded including welded disk over sensor module and transmitter flange
- Transmitter can be re-used if repair work is required

Welded

All welded (vacuum) construction

- module isolators
- Ideal for vacuum applications (< 6 psia, 400 mbar-a)
- Seal system and transmitter are not repairable

Rosemount 3051S ERS System



The Rosemount 3051S ERS System is a flexible, 2-wire 4–20 mA HART architecture that calculates differential pressure (DP) electronically using two pressure sensors that are linked together with a non-proprietary electrical wire.

Ideal applications for the Rosemount 3051S ERS System include tall vessels and distillation columns that have traditionally required long lengths of capillary or impulse piping. When used in these types of applications, the Rosemount 3051S ERS System can deliver:

- More accurate and repeatable DP measurements
- Faster time response
- Simplified installations
- Reduced maintenance

How to order

- 1. Select two Rosemount 3051S ERS Transmitter models. These may be any combination of Rosemount 3051SAM and 3051SAL models.
- 2. Decide which model will be the ERS primary (4–20 mA loop termination and optional LCD display) and which will be the ERS Secondary. This will be specified by the "Configuration Type" code in each model number.
- 3. Specify two full model numbers per the desired configuration.

Additional information

Specifications: page 126 Certifications: page 142 Dimensional drawings: page 169



Rosemount 3051SAM Transmitter for ERS applications

- Coplanar and in-line sensor module platforms
- Variety of process connections including threaded NPT, flanges, manifolds, and Rosemount 1199 Remote seals
- Available with 15-year stability and 15-year limited warranty

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

Table 1. Rosemount 3051SAM Transmitter for ERS Applications Ordering Information

Rosemount model	Transmitter type	
3051SAM	Scalable advanced measurement transmitter	
Performan	ce class ⁽¹⁾	
1	Ultra: 0.025% span accuracy, 200:1 rangedown, 15-year stability, 15-year limited warranty	*
2	Classic: 0.035% span accuracy, 150:1 rangedown, 15-year stability	*
4	Enhanced ERS System performance, 15-year stability, 15-year limited warranty	*
Configurat	ion type	
Р	ERS - primary	*
S	ERS - secondary	*

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Pressure module type		Pressure sensor type	
G	Coplanar	Gage	*
Т	In-Line	Gage	*
E	In-Line	Absolute	*
А	Coplanar	Absolute	

Pressure range⁽²⁾

	Coplanar gage	In-Line gage	In-Line absolute	Coplanar absolute	
1A	N/A	–14.7 to 30 psig (–1,01 to 2,06 bar)	0 to 30 psia (0 to 2,06 bar)	0 to 30 psia (0 to 2,06 bar)	*
2A	–250 to 250 inH ₂ O (–621,60 to 621,60 mbar)	–14.7 to 150 psig (–1,01 to 10,34 bar)	0 to 150 psia (0 to 10,34 bar)	0 to 150 psia (0 to 10,34 bar)	*
3A	–393 to 1000 inH ₂ O (–0,97 to 2,48 bar)	–14.7 to 800 psig (–1,01 to 55,15 bar)	0 to 800 psia (0 to 55,15 bar)	0 to 800 psia (0 to 55,15 bar)	*
4A	–14.2 to 300 psig (–0,97 to 20,68 bar)	–14.7 to 4000 psig (–1,01 to 275,79 bar)	0 to 4000 psia (0 to 275,79 bar)	0 to 4000 psia (0 to 275,79 bar)	*
5A	–14.2 to 2000 psig (–0,97 to 137,89 bar)	–14.7 to 10000 psig (–1,01 to 689,47 bar)	0 to 10000 psia (0 to 689,47 bar)	N/A	*

Isolating diaphragm

2 ⁽³⁾	316L SST	*
3(3)	Alloy C-276	*
4(3)(4)	Alloy 400	
5 ⁽⁴⁾⁽⁵⁾	Tantalum	
6 ⁽³⁾⁽⁴⁾	Gold-plated alloy 400 (includes graphite-filled PTFE O-ring)	
7(3)(4)	Gold-plated 316L SST	

Process connection

	Coplanar module type	In-Line module type	
A11 ⁽⁶⁾	Assemble to Rosemount 305 Manifold	Assemble to Rosemount 306 Manifold	*
A12 ⁽⁶⁾	Assemble to Rosemount 304 or AMF Manifold with SST traditional flange	Assemble AMF Manifold to 1/2–14 NPT female process connection	*
A15 ⁽⁶⁾	Assemble to Rosemount 304 or AMF manifold to SST traditional flange with alloy C-276 drain vents	N/A	*
A22 ⁽⁶⁾	Assemble AMF manifold to SST coplanar flange	N/A	*
B11 ⁽⁶⁾⁽⁷⁾	Assemble to one Rosemount 1199 Remote Diaphragm Seal with SST transmitter flange	Assemble to one Rosemount 1199 Remote Diaphragm	*
E11	Coplanar flange (CS), ¹ /4–18 NPT, 316 SST drain vents	¹ /2–14 NPT female process connection	*

Process connection				
	Coplanar module type	In-Line module type		
E12	Coplanar flange (SST), ¹ /4–18 NPT, 316 SST drain vents	N/A	*	
E13 ⁽³⁾	Coplanar flange (cast C-276), 1/4–18 NPT, alloy C-276 drain vents	N/A	*	
E14	Coplanar flange (cast alloy 400), ¹ /4–18 NPT, alloy 400/ K–500 drain vents	N/A	*	
E15 ⁽³⁾	Coplanar flange (SST), 1/4–18 NPT, Alloy C-276 drain vents	N/A	*	
E16 ⁽³⁾	Coplanar flange (CS), 1/4–18 NPT, Alloy C-276 drain vents	N/A	*	
E21	Coplanar flange (CS), RC 1/4, 316 SST drain vents	N/A	*	
E22	Coplanar flange (SST), RC 1/4, 316 SST drain vents	N/A	*	
E23 ⁽³⁾	Coplanar flange (Cast C-276), RC ¹ /4, alloy C-276 drain vents	N/A	*	
E24	Coplanar flange (cast alloy 400), RC ¹ /4, alloy 400/K–500 drain vents	N/A	*	
E25 ⁽³⁾	Coplanar flange (SST), RC 1/4, alloy C-276 drain vents	N/A	*	
E26 ⁽³⁾	Coplanar flange (CS), RC 1/4, alloy C-276 drain vents	N/A	*	
F12	Traditional flange (SST), 1/4–18 NPT, 316 SST drain vents	N/A	*	
F13 ⁽³⁾	Traditional flange (cast C-276), 1/4–18 NPT, alloy C-276 drain vents	N/A	*	
F14	Traditional flange (cast alloy 400), 1/4–18 NPT, alloy 400/ K–500 drain vents	N/A	*	
F15 ⁽³⁾	Traditional flange (SST), 1/4–18 NPT, alloy C-276 drain vents	N/A	*	
F22	Traditional flange (SST), RC 1/4, 316 SST drain vents	N/A	*	
F23 ⁽³⁾	Traditional flange (cast C-276), RC 1/4, alloy C-276 drain vents	N/A	*	
F24	Traditional flange (cast alloy 400), RC ¹ /4, alloy 400/K500 drain vents	N/A	*	
F25 ⁽³⁾	Traditional flange (SST), RC 1/4, alloy C-276 drain vents	N/A	*	
F52	DIN-compliant traditional flange (SST), 1/4–18 NPT, 316 drain vents, 7/16-in. bolting	N/A	*	
G11	Vertical mount level flange (SST), 2-in. ANSI Class 150, 316 SST drain vents	G ¹ /2 A DIN 16288 male (range 1–4 only)	*	
G12	Vertical mount level flange (SST), 2-in. ANSI Class 300, 316 SST drain vents	N/A	*	
G21	Vertical mount level flange (SST), 3-in. ANSI Class 150, 316 SST drain vents	N/A	*	
G22	Vertical mount level flange (SST), 3-in. ANSI Class 300, 316 SST drain vents	N/A	*	

Process connection					
	Coplanar module type		In-line module type		
G31	Vertical mount level flange (SST), DIN-DN 50 PN 40, 316 SST drain vents		N/A		*
G41	Vertical mount level flange (SST), DIN-DN 80 PN 40, 316 SST drain vents		N/A		*
P11	N/A		Level flange (SST), 2-in. Al	NSI Class 150	*
P12	N/A		Level flange (SST), 2-in. ANSI Class 300		*
P21	N/A		Level flange (SST), 3-in. ANSI Class 150		*
P22	N/A		Level flange (SST), 3-in. Al	NSI Class 300	*
P31	N/A		Level flange (SST), DIN-DN	N 50 PN 40	*
F11	Traditional flange (CS), 1/4–18 NPT, 316 SST dra	ain vents	Non-threaded instrument	flange (I-Flange)	
F32	Bottom vent traditional flange (SST), 1/4–18 NF drain vents	РТ, 316 SST	N/A		
F42	Bottom vent traditional flange (SST), RC ¹ /4, 31 vents	6 SST drain	N/A		
F62	DIN-compliant traditional flange (316 SST), 1/4 316 drain vents, M10 bolting	–18 NPT,	N/A		
F72	DIN-compliant traditional flange (316 SST), ¹ /4–18 NPT, 316 drain vents, M12 bolting		N/A		
Transmitte	routput				
A	4–20 mA with digital signal based on HART Pro	otocol			*
Housing st	ousing style Mat			Conduit entry size	
Housings for	r ERS primary - configuration type code P	1			
1A	Plantweb [™] housing	Aluminum		¹ /2–14 NPT	*
1B	Plantweb housing	Aluminum		M20 $ imes$ 1.5 (CM 20)	*
1J	Plantweb housing	SST		¹ /2–14 NPT	*
1K	Plantweb housing	SST		M20 ×1.5 (CM 20)	*
2E	Junction box with remote display output	Aluminum		¹ /2–14 NPT	*
2F	Junction box with remote display output	Aluminum		M20 × 1.5 (CM 20)	*
2M	Junction box with remote display output	SST		¹ /2–14 NPT	*
1C	Plantweb housing	Aluminum		G ¹ /2	
1L	Plantweb housing	SST		G ¹ /2	
2G	Junction box with remote display output	Aluminum		G ¹ /2	
Housings for	r ERS secondary - configuration type code S				
2A	Junction box	Aluminum		¹ /2–14 NPT	*
2B	Junction box	Aluminum		M20 $ imes$ 1.5 (CM 20)	*

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

2J	Junction box	SST	¹ /2–14 NPT	*
2C	Junction box	Aluminum	G ¹ /2	

Options (include with selected model number)

Extended	product warranty	
WR3	3-year limited warranty	*
WR5	5-year limited warranty	*
ERS conne	ection cable	
R02	25 ft. (7,62 m) spool of ERS cable (gray color)	
R05	50 ft. (15,2 m) spool of ERS cable (gray color)	*
R10	100 ft. (30,5 m) spool of ERS cable (gray color)	*
R15	150 ft. (45,7 m) spool of ERS cable (gray color)	*
R20 ⁽⁸⁾	200 ft. (60,96 m) spool of ERS cable (gray color)	
R22 ⁽⁹⁾	225 ft. (68,58 m) spool of ERS cable (gray color)	
R30	300 ft. (91,44 m) spool of ERS cable (gray color)	
R40	400 ft. (121,9 m) spool of ERS cable (gray color)	
R50	500 ft. (152,4 m) spool of ERS cable (gray color)	
H02	25 ft. (7,62 m) spool of ERS cable (blue color)	
H05	50 ft. (15,2 m) spool of ERS cable (blue color)	
H10	100 ft. (30,5 m) spool of ERS cable (blue color)	
H15	150 ft. (45,7 m) spool of ERS cable (blue color)	
H20 ⁽⁸⁾	200 ft. (60,96 m) spool of ERS cable (blue color)	
H22 ⁽⁹⁾	225 ft. (68,58 m) spool of ERS cable (blue color)	
J02	25 ft. (7,62 m) spool of ERS armored cable with $1/2$ in. armor cable gland	
J05	50 ft. (15,2 m) spool of ERS armored cable with 1/2 in. armor cable gland	
J07	75 ft. (22,8 m) spool of ERS armored cable with 1/2 in. armor cable gland	
J10	100 ft. (30,5 m) spool of ERS armored cable with 1/2 in. armor cable gland	
J12 ⁽⁹⁾	125 ft. (38,1 m) spool of ERS armored cable with $1/2$ in. armor cable gland	
Mounting	bracket	
B1 ⁽⁴⁾	Traditional flange bracket, CS, 2-in. pipe	*
B2 ⁽⁴⁾	Traditional flange bracket, CS, panel	*
B3 ⁽⁴⁾	Traditional flange flat bracket, CS, 2-in. pipe	*
B4	Bracket, all SST, 2-in. pipe and panel	*
B7 ⁽⁴⁾	Traditional flange bracket, B1 with SST bolts	*
B8 ⁽⁴⁾	Traditional flange bracket, B2 with SST bolts	*
B9 ⁽⁴⁾	Traditional flange bracket, B3 with SST bolts	 *

BA ⁽⁴⁾	Traditional flange bracket, B1, all SST	*		
BC ⁽⁴⁾	Traditional flange bracket, B3, all SST	*		
Special con	Special configuration (software)			
C1 ⁽¹⁰⁾	Customer software configuration (requires Configuration Data Sheet)	*		
C3	Gage pressure calibration on Rosemount 3051SAMA4 only	*		
C4 ⁽¹⁰⁾	NAMUR alarm and saturation levels, high alarm	*		
C5 ⁽¹⁰⁾	NAMUR alarm and saturation levels, low alarm	*		
C6 ⁽¹⁰⁾	Custom alarm and saturation levels, high alarm (requires C1 and Configuration Data Sheet)	*		
C7 ⁽¹⁰⁾	Custom alarm and saturation levels, low alarm (requires C1 and Configuration Data Sheet)	*		
C8 ⁽¹⁰⁾	Low alarm (standard Rosemount alarm and saturation levels)	*		
Special con	ifiguration (hardware)			
D2 ⁽¹¹⁾	¹ /2–14 NPT flange adapters	*		
D4 ⁽¹²⁾	External ground screw assembly	*		
D5 ⁽¹¹⁾	Delete transmitter drain/vent valves (install plugs)	*		
D7 ⁽¹¹⁾	Coplanar flange without drain/vent ports			
D9 ⁽¹¹⁾	RC 1/2 flange adapters			
Product ce	rtifications			
E1	ATEX Flameproof	*		
11	ATEX Intrinsic Safety	*		
N1	ATEX Type n	*		
K1	ATEX Flameproof and Intrinsically Safe, Type n, Dust	*		
ND	ATEX Dust	*		
E4	TIIS Flameproof	*		
E5	FM Explosion-proof, Dust Ignition-proof	*		
15	FM Intrinsically Safe; Nonincendive	*		
K5	FM Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*		
E6 ⁽¹³⁾	CSA Explosion-proof, Dust Ignition-proof, Division 2	*		
16	CSA Intrinsically Safe	*		
K6 ⁽¹³⁾	CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*		
E7	IECEx Flameproof	*		
17	IECEx Intrinsic Safety	*		
N7	IECEx Type n	*		
K7	IECEx Flameproof, Intrinsic Safety, Type n	*		
E2	INMETRO Flameproof	*		
12	INMETRO Intrinsically Safe	*		
K2	INMETRO Flameproof, Intrinsic Safety, Type n	*		

E3	China Flameproof	*	
13	China Intrinsic Safety, Dust Ignition-proof	*	
EP	Korea Flameproof	*	
IP	Korea Intrinsic Safety	*	
КР	Korea Flameproof, Intrinsic Safety	*	
EM	Technical Regulations Customs Union (EAC) Flameproof	*	
IM	Technical Regulations Customs Union (EAC) Intrinsic Safety	*	
KM	Technical Regulations Customs Union (EAC) Flameproof, Intrinsic Safety	*	
KA ⁽¹³⁾	ATEX and CSA Flameproof, Intrinsically Safe, Division 2	★	
KB ⁽¹³⁾	FM and CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*	
КС	FM and ATEX Explosion-proof, Intrinsically Safe, Division 2	*	
KD ⁽¹³⁾	FM, CSA, and ATEX Explosion-proof, Intrinsically Safe	*	
Shipboard	approvals		
SBS	American Bureau of Shipping (ABS) Type Approval	*	
SBV	Bureau Veritas (BV) Type Approval	*	
SDN	Det Norske Veritas (DNV) Type Approval	*	
SLL	Lloyds Register (LR) Type Approval	★	
Calibration	Calibration certification		
Q4	Calibration certificate	*	
QP	Calibration certificate and tamper evident seal	*	
Material tra	aceability certification		
Q8	Material traceability certification per EN 10204 3.1	*	
Quality cer	tification for safety		
QS	Prior-use certificate of FMEDA Data	*	
QT	Safety certified to IEC 61508 with certificate of FMEDA data	\star	
Surface fini	ish certification ⁽¹⁴⁾		
Q16	Surface finish certification for hygienic remote seals	*	
Toolkit per	formance reports ⁽¹⁵⁾		
QZ	Remote seal system performance calculation report	*	
Terminal b	locks ⁽¹⁰⁾		
T1	Transient terminal block	*	
Sensor fill f	iluid ⁽¹⁶⁾		
L1	Inert sensor fill fluid	*	

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

O-ring		
L2	Graphite-filled PTFE O-ring	*
Bolting ma	iterial ⁽¹¹⁾	
L4	Austenitic 316 SST bolts	*
L5 ⁽³⁾	ASTM A 193, grade B7M bolts	*
L6	Alloy K–500 bolts	*
L7 ⁽³⁾	ASTM A 453, Class D, grade 660 bolts	*
L8	ASTM A 193, Class 2, grade B8M bolts	*
Display typ	e (ERS primary only) ⁽¹⁰⁾	
M5	Plantweb LCD display	*
M7 ⁽¹⁷⁾	Remote mount LCD display and interface, Plantweb housing, no cable, SST bracket	*
M8	Remote mount LCD display and interface, Plantweb housing, 50 ft. (15,2 m) cable, SST bracket	*
M9	Remote mount LCD display and interface, Plantweb housing, 100 ft. (30,5 m) cable, SST bracket	*
Pressure te	esting	
P1	Hydrostatic testing with certificate	
Special clea	aning ⁽¹¹⁾	
P2	Cleaning for special services	
Р3	Cleaning for less than 1 PPM chlorine/fluorine	
NACE certi	ficate ⁽³⁾	
Q15	Certificate of compliance to NACE [®] MR0175/ISO 15156 for wetted materials	*
Q25	Certificate of compliance to NACE MR0103 for wetted materials	*
Typical mo	del number: 3051SAM 1 S T 2A 2 E11 A 2A	

1. For detailed specifications see "Specifications" on page 126. The Rosemount 3051S ERS System offers three performance class options; classic, ultra, and enhanced ERS system performance. The classic and ultra performance classes are suited to lower static pressure and stable temperature conditions. The enhanced ERS system performance class provides better performance across temperature (-40 to 185 °F) with improved performance at higher static pressure.

2. The pressure range should be specified based on the maximum static pressure, not differential pressure.

3. Materials of construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments. Order with Q15 or Q25 to receive a NACE certificate.

- 4. Not available with pressure sensor/module codes T or E.
- 5. Tantalum diaphragm material is only available with pressure sensor/module code G.
- 6. "Assemble to" items are specified separately and require a completed model number.
- 7. Consult an Emerson[™] representative for performance specifications.
- 8. Maximum cable distance for SIS installations. See Rosemount 3051S ERS <u>Reference Manual</u> for more information.
- 9. Maximum cable distance for IS (Intrinsically safe) installations. Other options may not be valid at longer distances.
- 10. Not available with configuration type code S.
- 11. Not available with process connection code A11.
- 12. This assembly is included with options E1, N1, K1, ND, E4, E7, N7, K7, E2, KA, KC, KD, K2, T1, EP, and KP.
- 13. Not available with M20 or G ¹/2 conduit entry size.

- 14. Q16 is only available when the diaphragm seal has surface finish options.
- 15. The QZ report quantifies the performance of the entire ERS system. One report is provided per ERS system. The QZ option is specified on the primary transmitter (configuration type code P).
- 16. Silicone fill fluid is standard.
- 17. See the Rosemount 3051S Reference Manual for cable requirements. Contact an Emerson representative for additional information.

Rosemount DP Level



Rosemount 3051SAL Transmitter for ERS applications

- Integrated transmitter and direct mount diaphragm seal system in a single model number
- Variety of process connections including flanged, threaded, and hygienic remote seals
- Available with 15-year limited warranty

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

A Rosemount 3051SAL Scalable ERS Level Transmitter consists of three parts. First, specify the transmitter model codes found on page 14. Then, specify a direct mount seal found on page 69. Finish the model number by specifying all desired options on page 18.



Table 2. Rosemount 3051SAL Transmitter for ERS Applications Ordering Information

Rosemount model	Transmitter type				
3051SAL	Scalable advanced level tr	ansmitter			
Performan	ce class ⁽¹⁾				
1	Ultra: 0.055% span accura	cy, 150:1 rangedown, 15-year	limited warranty		*
2	Classic: 0.065% span accu	racy, 150:1 rangedown			*
4	Enhanced ERS System per	formance, 15-year limited war	ranty		*
Configurat	ion type				
Р	ERS - primary				*
S	ERS - secondary				*
Pressure m	sure module type Pressure sensor type				
G	Coplanar	Gage			*
Т	In-line	Gage			*
E	In-line	Absolute	Absolute 7		
А	Coplanar	Absolute			
Pressure ra	inge ⁽²⁾				
	Coplanar gage	In-line gage	In-line absolute	Coplanar absolute	
1A	N/A	–14.7 to 30 psig (–1.01 to 2.06 bar)	0 to 30 psia (0 to 2.06 bar)	0 to 30 psia (0 to 2.06 bar)	*
2A	-250 to 250 inH ₂ O (-621.60 to 621.60 mbar)	–14.7 to 150 psig (–1.01 to 10.34 bar)	0 to 150 psia (0 to 10.34 bar)	0 to 150 psia (0 to 10.34 bar)	*
3A	–393 to 1000 inH ₂ O (–0.97 to 2.48 bar)	–14.7 to 800 psig (–1.01 to 55.15 bar)	0 to 800 psia (0 to 55.15 bar)	0 to 800 psia (0 to 55.15 bar)	*
4A	–14.2 to 300 psig (–0.97 to 20.68 bar)	–14.7 to 4000 psig (–1.01 to 275.79 bar)	0 to 4000 psia (0 to 275.79 bar)	0 to 4000 psia (0 to 275.79 bar)	*
5A	–14.2 to 2000 psig (–0.97 to 137.89 bar)	–14.7 to 10000 psig (–1.01 to 689.47 bar)	0 to 10000 psia (0 to 689.47 bar)	N/A	*

Transm	nitter output			
A	4–20 mA with digital signal based on	HART Protocol		*
Housin	g style	Material	Conduit entry size	
Housing	js for ERS primary - configuration type co	ode P	<u>`</u>	
1A	Plantweb housing	Aluminum	1/2-14 NPT	*
1B	Plantweb housing	Aluminum	M20 × 1.5 (CM 20)	*
1J	Plantweb housing	SST	¹ /2–14 NPT	*
1K	Plantweb housing	SST	M20 ×1.5 (CM 20)	*
2E	Junction box with remote display output	Aluminum	1/2-14 NPT	*
2F	Junction box with remote display output	Aluminum	M20 ×1.5 (CM 20)	*
2M	Junction box with remote display output	SST	¹ /2–14 NPT	*
1C	Plantweb housing	Aluminum	G ¹ /2	
1L	Plantweb housing	SST	G ¹ /2	
2G	Junction box with remote display output	Aluminum	G1/2	
Housing	js for ERS secondary - configuration type	code S		
2A	Junction box	Aluminum	¹ /2–14 NPT	*
2B	Junction box	Aluminum	M20 × 1.5 (CM 20)	*
2J	Junction box	SST	¹ /2–14 NPT	*
2C	Junction box	Aluminum	G ¹ /2	
Seal sy	stem type			
Coplana	ir pressure module type			
1	Single direct mount seal system		Welded-repairable	*
2	Single direct mount seal system		All welded	*
In-line p	pressure module type			
1	Single direct mount seal system		All welded	*
High si	de connection type			
Single d	irect mount seal system (between trans	mitter and remote seal)		
0	No extension			*
2	2-in. (50 mm) extension			*
4	4-in. (100 mm) extension			*
5 ⁽³⁾	Thermal optimizer			*
6(4)	Thermal range expander - Silicone 20	0 secondary fill fluid		*
7(5)(4)	Thermal range expander - Syltherm [™]	XLT secondary fill fluid		*

Low side connection type (reference pressure connection)							
Single direct mount seal system							
00	None (In-line pressure mo	None (In-line pressure module type only)					*
20	316L SST isolator/SST tran	316L SST isolator/SST transmitter flange					*
30	Alloy C-276 isolator/SST tr	ansmitter flan	ge				*
		Specific		Temperat	ture limits ⁽⁶⁾⁽⁷⁾		
Seal fill fluid		gravity at 77 °F (25 °C)	No extension	2-in. (50 mm) extension	4-in. (100 mm) extension	Thermal range expander (process temperature) ⁽⁸⁾	
D	Silicone 200	0.934	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	N/A	*
F	Silicone 200 for vacuum applications	0.934	For use in vacuur pressure cu	m applications bel rves in Rosemount <u>Techni</u>	ow 14.7 psia (1 ba t DP Level Fill Fluid i <u>cal Note</u>	r-a), refer to vapor Specification	*
J ⁽⁹⁾	Tri-Therm 300	0.795	–40 to 401 °F (–40 to 205 °C)	–40 to 464 °F (–40 to 240 °C)	–40 to 572 °F (–40 to 300 °C)	N/A	*
Q ⁽⁹⁾	Tri-Therm 300 for vacuum applications	0.795	For use in vacuur pressure cu	n applications bel rves in Rosemount <u>Techni</u>	ow 14.7 psia (1 ba t DP Level Fill Fluid ical Note	r-a), refer to vapor Specification	*
L	Silicone 704	1.07	32 to 401 °F (0 to 205 °C)	32 to 464 °F (0 to 240 °C)	32 to 572 °F (0 to 300 °C)	Up to 599 °F (315 °C)	*
С	Silicone 704 for vacuum applications	1.07	For use in vacuur pressure cu	m applications bel rves in Rosemount <u>Techni</u>	ow 14.7 psia (1 ba t DP Level Fill Fluid ical Note	r-a), refer to vapor Specification	*
R	Silicone 705	1.09	68 to 401 °F (20 to 205 °C)	68 to 464 °F (20 to 240 °C)	68 to 572 °F (20 to 300 °C)	Up to 698 °F (370 °C)	*
V	Silicone 705 for vacuum applications	1.09	For use in vacuur pressure cu	m applications bel rves in Rosemount <u>Techni</u>	ow 14.7 psia (1 ba t DP Level Fill Fluid cal Note	r-a), refer to vapor Specification	*
A	Syltherm XLT	0.85	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	N/A	*
Н	Inert (halocarbon)	1.85	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	N/A	*
G ⁽⁹⁾⁽¹⁰⁾	Glycerin and water	1.13	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	N/A	*
N ⁽⁹⁾	Neobee [®] M-20	0.94	5 to 401 °F (–15 to 205 °C)	5 to 437 °F (–15 to 225 °C)	5 to 437 °F (–15 to 225 °C)	N/A	*
P ⁽⁹⁾⁽¹⁰⁾	Propylene glycol and water	1.02	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	N/A	*
Y (11)	UltraTherm [™] 805	1.20	N/A	N/A	N/A	Up to 770 °F (410 °C)	*
Z ⁽¹¹⁾	UltraTherm 805 for vacuum applications	1.20	For use in vacuur pressure cu	m applications bel rves in Rosemount <u>Techni</u>	ow 14.7 psia (1 ba t DP Level Fill Fluid ical Note	r-a), refer to vapor Specification	*

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Continue specifying a completed model number by choosing a remote seal type below:

Seal style			Process connections
6.	page 35	FF flush flanged seal	2-in./DN 50/ 50A 3-in./DN 80/80A 4-in./DN 100/100A
S	page 38	EF extended flanged seal	3-in./DN 80/80A 4-in./DN 100/100A
83	page 40	RF remote flanged seal	^{1/2-} in. ^{3/} 4-in. 1-in./DN 25/25A 1 ¹ /2-in./DN 40/40A
	page 43	PF pancake seal	2-in./DN 50/50A 3-in./DN 80/80A
B	page 45	FC flush flanged seal - ring type joint (RTJ) gasket surface	2-in. 3-in.
0	page 47	RC remote flange seal - RJT gasket surface	¹ /2-in ³ /4-in 1-in. 1 ¹ /2-in.
	page 49	RT remote threaded seal	¹ /4–18 NPT ¹ /2–14 NPT ³ /4–14 NPT 1–11.5 NPT 1 ¹ /4–11.5 NPT
	page 51	SC hygienic Tri-Clamp [®] seal	11/2-in. 2-in. 3-in.
	page 52	SS hygienic tank spud seal	4-in.

Extended	product warranty				
WR3	3-year limited warranty	*			
WR5	5-year limited warranty	*			
ERS conne	ection cable ⁽¹²⁾				
R02	25 ft. (7,62 m) spool of ERS cable (gray color)	Τ			
R05	50 ft. (15,2 m) spool of ERS cable (gray color)	*			
R10	100 ft. (30,5 m) spool of ERS cable (gray color)	*			
R15	150 ft. (45,7 m) spool of ERS cable (gray color)	*			
R20 ⁽¹³⁾	200 ft. (60,96 m) spool of ERS cable (gray color)				
R22 ⁽¹⁴⁾	225 ft. (68,58 m) spool of ERS cable (gray color)				
R30	300 ft. (91,44 m) spool of ERS cable (gray color)				
R40	400 ft. (121,9 m) spool of ERS cable (gray color)				
R50	500 ft. (152,4 m) spool of ERS cable (gray color)				
H02	25 ft. (7,62 m) spool of ERS cable (blue color)				
H05	50 ft. (15,2 m) spool of ERS cable (blue color)				
H10	100 ft. (30,5 m) spool of ERS cable (blue color)				
H15	150 ft. (45,7 m) spool of ERS cable (blue color)				
H20 ⁽¹³⁾	200 ft. (60,96 m) spool of ERS cable (blue color)				
H22 ⁽¹⁴⁾	225 ft. (68,58 m) spool of ERS cable (blue color)				
J02	25 ft. (7,62 m) spool of ERS armored cable with 1/2 in. armor cable gland				
J05	50 ft. (15,2 m) spool of ERS armored cable with 1/2 in. armor cable gland				
J07	75 ft. (22,8 m) spool of ERS armored cable with 1/2 in. armor cable gland				
J10	100 ft. (30,5 m) spool of ERS armored cable with 1/2 in. armor cable gland				
J12 ⁽¹⁴⁾	125 ft. (38,1 m) spool of ERS armored cable with 1/2 in. armor cable gland				
Software	configuration ⁽¹⁵⁾				
C1	Custom software configuration (requires Configuration Data Sheet)	*			
Gage pres	sure calibration				
C3	Gage pressure calibration on Rosemount 3051SALA4 only	*			
Alarm limi	it ⁽¹⁵⁾				
C4	NAMUR alarm and saturation levels, high alarm	*			
C5	NAMUR alarm and saturation levels, low alarm	*			
C6	Custom alarm and saturation levels, high alarm (requires C1 and Configuration Data Sheet)	*			
C7	Custom alarm and saturation levels, low alarm (requires C1 and Configuration Data Sheet)	*			
C8	Low alarm (standard Rosemount alarm and saturation levels)	*			
Ground screw ⁽¹⁶⁾					
D4	External ground screw assembly	*			

Conduit plug			
DO	316 SST conduit plug	*	
Product ce	rtifications		
E1	ATEX Flameproof	*	
11	ATEX Intrinsic Safety	*	
N1	ATEX Type n	*	
K1	ATEX Flameproof and Intrinsically Safe, Type n, Dust	*	
ND	ATEX Dust	*	
E4	TIIS Flameproof	*	
E5	FM Explosion-proof, Dust Ignition-proof	*	
15	FM Intrinsically Safe; Nonincendive	*	
К5	FM Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*	
E6 ⁽¹⁷⁾	CSA Explosion-proof, Dust Ignition-proof, Division 2	*	
16	CSA Intrinsically Safe	*	
K6 ⁽¹⁷⁾	CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*	
E7	IECEx Flameproof	*	
17	IECEx Intrinsic Safety	*	
N7	IECEx Type n	*	
Product ce	rtifications		
К7	IECEx Flameproof, Intrinsic Safety, Type n	*	
E2	INMETRO Flameproof	*	
12	INMETRO Intrinsically Safe	*	
К2	INMETRO Flameproof, Intrinsic Safety	*	
EP	Korea Flameproof	*	
Product ce	rtifications		
E3	China Flameproof	*	
13	China Intrinsic Safety	*	
IP	Korea Intrinsic Safety	*	
КР	Korea Flameproof, Intrinsic Safety	*	
EM	Technical Regulations Customs Union (EAC) Flameproof	*	
IM	Technical Regulations Customs Union (EAC) Intrinsic Safety	*	
KM	Technical Regulations Customs Union (EAC) Flameproof, Intrinsic Safety	*	
KA ⁽¹⁷⁾	ATEX and CSA Flameproof, Intrinsically Safe, Division 2	*	
KB ⁽¹⁷⁾	FM and CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*	
КС	FM and ATEX Explosion-proof, Intrinsically Safe, Division 2	*	
KD ⁽¹⁷⁾	FM, CSA, and ATEX Explosion-proof, Intrinsically Safe	*	

Shipboard	approvals			
SBS	American Bureau of Shipping (ABS) Type Approval	*		
SBV	Bureau Veritas (BV) Type Approval	\star		
SDN	Det Norske Veritas (DNV) Type Approval	\star		
SLL	Lloyds Register (LR) Type Approval	*		
Sensor fill	fluid ⁽¹⁸⁾			
L1	Inert sensor fill fluid	\star		
O-ring				
L2	Graphite-filled PTFE O-ring	*		
Bolting ma	iterial			
L4	Austenitic 316 SST bolts	*		
Display typ	pe (ERS primary only) ⁽¹⁵⁾			
M5	Plantweb LCD display	*		
M7 ⁽¹⁹⁾	Remote mount LCD display and interface, Plantweb housing, no cable, SST bracket	*		
M8	Remote mount LCD display and interface, Plantweb housing, 50 ft. (15,2 m) cable, SST bracket	*		
M9	Remote mount LCD display and interface, Plantweb housing, 100 ft. (30,5 m) cable, SST bracket	*		
Pressure te	esting			
P1	Hydrostatic testing with certificate			
Special clea	aning			
P2	Cleaning for special services			
Р3	Cleaning for less than 1 PPM chlorine/fluorine			
Calibration	ncertification			
Q4	Calibration certificate	\star		
QP	Calibration certificate with tamper evident seal	*		
Material tr	aceability certification			
Q8	Material traceability certification per EN 10204 3.1	\star		
Quality cer	rtification for safety			
QS	Prior-use certificate of FMEDA data	\star		
QT	Safety certified to IEC 61508 with certificate of FMEDA data	*		
Toolkit per	formance reports ⁽²⁰⁾			
QZ	Remote seal system performance calculation report	\star		
Transient protection ⁽¹⁵⁾				
T1	Transient terminal block	*		

NACE certificate ⁽²¹⁾				
Q15	Certificate of Compliance to NACE MR0175/ISO 15156 for wetted materials	*		
Q25	Certificate of Compliance to NACE MR0103 for wetted materials	*		
Typical model number: 3051SAL 1 P G 4A A 1A 1 0 20 D FF 7 1 DA 0 0 M5				

- 1. For detailed specifications see "Specifications" on page 126. The Rosemount 3051S ERS System offer three performance class options; classic, ultra, and enhanced ERS system performance. The classic and ultra performance classes are suited to lower static pressure and stable temperature conditions. The enhanced ERS system performance class provides better performance across temperature (–40 to 185 °F) with improved performance at higher static pressure.
- 2. Not suitable for vacuum applications.
- 3. Maximum working pressure (MWP) of the Thermal Optimizer is 4000 psi (275 bar).
- 4. Maximum working pressure (MWP) of the thermal range expander is 3750 psi (258,6 bar).
- 5. Thermal range expander with Syltherm XLT secondary fill fluid is not recommended for use in vacuum applications below 6 psia (400 mbar-a).
- 6. At ambient pressure of 14.7 psia (1 bar-a) and ambient temperature of 70 °F (21 °C). Temperature limits are reduced in vacuum service and may be limited by seal selection.
- 7. Due to heat transfer to the transmitter, the maximum process temperature of the transmitter will be de-rated if ambient or process temperatures exceed 185 °F (85 °C). Consult Instrument Toolkit to verify the application.
- 8. For complete process and ambient temperature limits, see thermal range expander temperature operating range on page 135.
- 9. This is a food grade fill fluid.
- 10. Not suitable for vacuum applications.
- 11. Only available with thermal range expander.
- 12. The pressure range should be specified based on the maximum static pressure, not differential pressure.
- 13. Maximum cable distance for SIS installations. See Rosemount 3051S ERS Reference Manual for more information.
- 14. Maximum cable distance for IS (Intrinsically safe) installations. Other options may not be valid at longer distances.
- 15. Not available with configuration type code S.
- 16. This assembly is included with options EP, KP, E1, N1, K1, ND, E4, E7, N7, K7, E2, KA, KC, KD, K2, T1, E3, EM, KM.
- 17. Not available with M20 or G¹/2 conduit entry size.
- 18. Silicone fill fluid is standard.
- 19. See the Rosemount 3051S <u>Reference Manual</u> for cable requirements. Contact an Emerson representative for additional information.
- 20. The QZ report quantifies the performance of the entire ERS system. One report is provided per ERS system. The QZ option is specified on the primary transmitter (configuration type code P).
- 21. Materials of construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.

Rosemount 3051S Scalable[™] Level Transmitter



Rosemount 3051SAL In-Line with "FF" Flanged Seal

Rosemount 30 51SAL Coplanar[™] with "SS" Hygienic Tank Spud Seal



Rosemount 3051SAL Tuned-System Assembly with Thermal Range Expander

Rosemount 3051SAL Balanced System Rosemount 3051S Level Transmitters combine the features and benefits of a high-performance Rosemount 3051S Pressure Transmitter with the durability and reliability of diaphragm seals all in a single model number.

Product features and capabilities include:

- Variety of process connections including flanged, threaded, and hygienic seals
- Quantified performance for the entire transmitter/seal assembly (QZ option)
- HART, FOUNDATION[™] Fieldbus, and wireless Protocols

Additional information

Specifications: page 126 Certifications: page 142 Dimensional drawings: page 169

Rosemount 3051SAL Scalable Level Transmitter

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

A Rosemount 3051SAL Scalable Level Transmitter consists of three parts. First, specify the transmitter model codes found on page 22.

Then, specify a direct mount seal found on page 69. Finish the model number by specifying all desired options on page 30.



Table 3. Rosemount 3051SAL Scalable Level Transmitter Ordering Information

Rosemount model	Transmitter type			
3051SAL	Scalable level transmitter			
Performan	ce class ⁽¹⁾			
1	Ultra: 0.055% span accuracy, 150:1 rangedown, 15-year limited warranty	\star		
2	Classic: 0.065% span accuracy, 150:1 rangedown	*		
Configuration type				
С	Liquid level transmitter	\star		

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Pressure m	Pressure module type						
D	Coplanar	Differential	*				
G	Coplanar	Gage	*				
Т	In-line	Gage	*				
E	In-line	Absolute	*				
A	Coplanar	Absolute					

Pressure range

	Coplanar DP	Coplanar gage	In-line gage	In-line absolute	Coplanar absolute	
1A	N/A	N/A	-14.7 to 30 psig (-1,01 to 2,06 bar)	0 to 30 psia (0 to 2,06 bar)	0 to 30 psia (0 to 2,06 bar)	*
2A	–250 to 250 inH ₂ O (–621,60 to 621,60 mbar)	-250 to 250 inH ₂ O (-621,60 to 621,60 mbar)	-14.7 to 150 psig (-1,01 to 10,34 bar)	0 to 150 psia (0 to 10,34 bar)	0 to 150 psia (0 to 10,34 bar)	*
ЗA	-1000 to 1000 inH ₂ O (-2,48 to 2,48 bar)	-393 to 1000 inH ₂ O (-0,97 to 2,48 bar)	–14.7 to 800 psig (–1,01 to 55,15 bar)	0 to 800 psia (0 to 55,15 bar)	0 to 800 psia (0 to 55,15 bar)	*
4A	-300 to 300 psi (-20,68 to 20,68 bar)	–14.2 to 300 psig (–0,97 to 20,68 bar)	-14.7 to 4000 psig (-1,01 to 275,79 bar)	0 to 4000 psia (0 to 275,79 bar)	0 to 4000 psia (0 to 275,79 bar)	*
5A	-2000 to 2000 psi (-137,89 to 137,89 bar)	-14.2 to 2000 psig (-0,97 to 137,89 bar)	-14.7 to 10000 psig (-1,01 to 689,47 bar)	0 to 10000 psia (0 to 689,47 bar)	N/A	*

Transmitter output

A	4–20 mA with digital signal based on HART Proto	4–20 mA with digital signal based on HART Protocol					
F ⁽²⁾	FOUNDATION Fieldbus Protocol	FOUNDATION Fieldbus Protocol					
X ⁽³⁾	Wireless (requires wireless options and wireless P	Wireless (requires wireless options and wireless Plantweb housing)					
Housing	style	Material	Conduit entry				
1A	Plantweb housing	Aluminum	¹ /2–14 NPT	*			
1B	Plantweb housing	Aluminum	M20×1.5	*			
1J	Plantweb housing	SST	1/2-14 NPT	*			
1K	Plantweb housing	SST	M20 × 1.5	*			
2A	Junction box housing	Aluminum	1/2-14 NPT	*			
2B	Junction box housing	Aluminum	M20 × 1.5	*			
2E	Junction box with output for remote interface	Aluminum	¹ /2–14 NPT	*			

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Junction box with output for remote interface	Aluminum	M20 × 1.5	*
Junction box housing	SST	¹ /2–14 NPT	*
Wireless Plantweb housing	Aluminum	¹ /2–14 NPT	*
Wireless Plantweb housing	SST	¹ /2–14 NPT	*
Quick connect (A size mini, 4-pin male termination)	SST	N/A	*
Plantweb housing	Aluminum	G1/2	
Plantweb housing	316L SST	G ¹ /2	
Junction box housing	Aluminum	G1/2	
Junction box with output for remote interface	Aluminum	G1/2	
	Junction box with output for remote interface Junction box housing Wireless Plantweb housing Quick connect (A size mini, 4-pin male termination) Plantweb housing Plantweb housing Junction box housing Junction box with output for remote interface	Junction box with output for remote interfaceAluminumJunction box housingSSTWireless Plantweb housingAluminumWireless Plantweb housingSSTQuick connect (A size mini, 4-pin male termination)SSTPlantweb housingAluminumPlantweb housing316L SSTJunction box housingAluminumJunction box with output for remote interfaceAluminum	Junction box with output for remote interfaceAluminumM20 × 1.5Junction box housingSST1/2–14 NPTWireless Plantweb housingAluminum1/2–14 NPTWireless Plantweb housingSST1/2–14 NPTQuick connect (A size mini, 4-pin male termination)SSTN/APlantweb housingAluminumG1/2Plantweb housing316L SSTG1/2Junction box housingAluminumG1/2Junction box with output for remote interfaceAluminumG1/2

Seal system type

Coplanar pressure module type			In-line pressure module type		
1	Direct mount single seal system	Welded- repairable	Direct mount single seal system	Welded-repairable	*
2	Direct mount single seal system	All welded	N/A	N/A	*
3(6)	Tuned-system assembly - one direct mount and one remote mount seal with capillary	Welded- repairable	N/A	N/A	*
4 ⁽⁶⁾	Tuned-system assembly - one direct mount and one remote mount seal with capillary	All welded	N/A	N/A	*
5(6)	Balanced system - two remote mount seals with equal lengths of capillary	Welded- repairable	N/A	N/A	*
6(6)	Balanced system - two remote mount seals with equal lengths of capillary	All welded	N/A	N/A	*
7	Remote mount single seal system with capillary - 316L low side transmitter isolator	Welded- repairable	Remote mount single seal system with capillary	All welded	*
8	Remote mount single seal system with capillary - 316L low side transmitter isolator	All welded	N/A	N/A	*
9	Remote mount single seal system with capillary - Alloy C-276 low side transmitter isolator	Welded- repairable	N/A	N/A	*
A	Remote mount single seal system with capillary - Alloy C-276 low side transmitter isolator	All welded	N/A	N/A	*

High side o	connection typ	e [select based	l on seal syste	m type chosen]			
		Single se	al system	C	Dual seal system		
	Direct	t mount	Remote mour	Remote mount with capillary		Balanced system	
	Coplanar	In-line	Coplanar	In-line	Coplanar	Coplanar	
0	No extension	No extension	Standard	Standard	No extension/ standard	Standard	*
2	2-in. (50 mm) extension	N/A	N/A	N/A	2-in. (50 mm) extension	N/A	*
4	4-in. (100 mm) extension	4-in. (100 mm) extension ⁽⁷⁾	N/A	N/A	4-in. (100 mm) extension	N/A	*
6 ⁽⁸⁾	Thermal range expander - Silicone 200 secondary fill	Thermal range expander - Silicone 200 secondary fill	Thermal range expander - Silicone 200 secondary fill fluid single capillary	Thermal range expander - Silicone 200 secondary fill single capillary	Thermal range expander - Silicone 200 secondary fill with low side capillary	Thermal range expander - Silicone 200 secondary fill with low side capillary	*
7(8)	Thermal range expander - Syltherm XLT secondary fill fluid	Thermal range expander - Syltherm XLT secondary fill fluid	Thermal range expander - Syltherm XLT secondary fill fluid single capillary	Thermal range expander - Syltherm XLT secondary fill fluid single capillary	Thermal range expander - Syltherm XLT secondary fill with low side capillary	Thermal range expander - Syltherm XLT secondary fill with Iow side capillary	*
Low side c	onnection typ	e or capillary I.I	D				
	Material for lo conn	w side reference lection			Capillary I.D.		
	Direct	tmount	Remote mount with capillary		Tuned-system assembly	Balanced system	
	Coplanar	In-line	Coplanar or in	line	Coplanar	Coplanar	
0	N/A	No reference connection	N/A		N/A	N/A	*
1 ⁽⁹⁾⁽¹⁰⁾	Assemble to one Rosemount 1199 Remote seal	N/A	N/A		N/A	N/A	*
2	316L SST isolator and SST transmitter flange	N/A	N/A		N/A	N/A	*
3	Alloy C-276 isolator and SST transmitter flange	N/A	N/A		N/A	N/A	*

В	N/A	N/A	0.03-in. (0,711 mm) ID capillary	0.03-in. (0,711 mm) ID capillary	0.03-in. (0,711 mm) ID capillary	*
С	N/A	N/A	0.04-in. (1,092 mm) ID capillary	0.04-in. (1,092 mm) ID capillary	0.04-in. (1,092 mm) ID capillary	*
D	N/A	N/A	0.075-in. (1,905 mm) ID capillary	0.075-in. (1,905 mm) ID capillary	0.075-in. (1,905 mm) ID capillary	*
E(11)	N/A	N/A	0.03-in. (0,711 mm) ID capillary, PVC coated with closed end	0.03-in. (0,711 mm) ID capillary, PVC coated with closed end	0.03-in. (0,711 mm) ID capillary, PVC coated with closed end	*
F(11)	N/A	N/A	0.04-in. (1,092 mm) ID capillary, PVC coated with closed end	0.04-in. (1,092 mm) ID capillary, PVC coated with closed end	0.04-in. (1,092 mm) ID capillary, PVC coated with closed end	*
G ⁽¹¹⁾	N/A	N/A	0.075-in. (1,905 mm) ID capillary, PVC coated with closed end	0.075-in. (1,905 mm) ID capillary, PVC coated with closed end	0.075-in. (1,905mm) ID capillary, PVC coated with closed end	*
Capillary le	ength ⁽¹²⁾					
0	No capillary (re	quired for direct n	nount single seal system)			*
А	1 ft. (0,3 m)					*
В	5 ft. (1,5 m)					*
С	10 ft. (3,0 m)					*
D	15 ft. (4,5 m)					*
E	20 ft. (6,1 m)					*
F	25 ft. (7,6 m)					*
G	30 ft. (9,1 m)					*
Н	35 ft. (10,7 m)					*
J	40 ft. (12,2 m)					*
К	45 ft. (13,7 m)					*
L	50 ft. (15,2 m)					*
М	0,5 m (1.6 ft.)					*
Ν	1,0 m (3.3 ft.)					*
Р	1,5 m (4.9 ft.)					*
R	2,0 m (6.6 ft.)					*
Т	2,5 m (8.2 ft.)					*
U	3,0 m (9.8 ft.)					*
V	3,5 m (11.5 ft.)					*

W	4,0 m (13.1 ft.)						*	
Y	5,0 m (16.4 ft.)							*
Z	6,0 m (19.7 ft.)							*
1	7,0 m (23 ft.)							*
2	8,0 m (26.2 ft.)	I						*
3	9,0 m (29.5 ft.))						*
4	10,0 m (32.8 ft	.)						*
5	11,0 m (36.1 ft	.)						*
6	12,0 m (39.4 ft	.)						*
7	13,0 m (42.6 ft	.)						*
8	14,0 m (45.9 ft	.)						*
9	15,0 m (49.2 ft	.)						*
				Temperature	limits ⁽¹³⁾⁽¹⁴⁾			
Seal fill flui	id	Specific gravity at 77 °F (25 °C)	No extension	2-in. (50 mm) extension	4-in. (100 mm) extension	Thermal range expander (process temperature) ⁽¹⁵⁾	Capillary	
D	Silicone 200	0.934	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	N/A	–49 to 401 °F (–45 to 205 °C)	*
F	Silicone 200 for vacuum applications	0.934	For use in vacuu curves in	um applications be Rosemount DP Le	elow 14.7 psia (1 evel Fill Fluid Spe	l bar-a), refer to cification <u>Techn</u>	vapor pressure <u>ical Note</u> .	*
J ⁽¹⁷⁾	Tri-Therm 300	0.795	–40 to 401 °F (–40 to 205 °C)	-40 to 464 °F (-40 to 240 °C)	–40 to 572 °F (–40 to 300 °C)	N/A	−40 to 572 °F (−40 to 300 °C)	*
Q ⁽¹⁷⁾	Tri-Therm 300 for vacuum applications	0.795	For use in vacuu curves in	um applications be Rosemount DP Le	elow 14.7 psia (1 evel Fill Fluid Spe	l bar-a), refer to cification <u>Techn</u>	vapor pressure <u>ical Note</u> .	*
L	Silicone 704	1.07	32 to 401 °F (0 to 205 °C)	32 to 464 °F (0 to 240 °C)	32 to 572 °F (0 to 300 °C)	Up to 599 °F (315 °C)	−32 to 599 °F (0 to 315 °C)	*
С	Silicone 704 for vacuum applications	1.07	For use in vacu curves in	um applications b Rosemount DP Le	elow 14.7 psia (* evel Fill Fluid Spe	I bar-a), refer to cification <u>Techn</u>	vapor pressure <u>ical Note</u> .	*
R	Silicone 705	1.09	68 to 401 °F (20 to 205 °C)	68 to 464 °F (20 to 240 °C)	68 to 572 °F (20 to 300 °C)	Up to 698 °F (370 °C)	68 to 698 °F (20 to 370 °C)	*
V	Silicone 705 for vacuum applications	1.09	For use in vacu curves in	um applications b Rosemount DP Le	elow 14.7 psia (* evel Fill Fluid Spe	l bar-a), refer to cification <u>Techn</u>	vapor pressure <u>ical Note</u> .	*
γ (16)	UltraTherm 805	1.20	N/A	N/A	N/A	Up to 770 °F (410 °C)	N/A	*
Z ⁽¹⁶⁾	UltraTherm 805 for vacuum applications	1.20	For use in vacuu curves in	um applications b Rosemount DP Le	elow 14.7 psia (* evel Fill Fluid Spe	l bar-a), refer to cification <u>Techn</u>	vapor pressure ical Note.	*

А	Syltherm XLT	0.85	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	N/A	–157 to 293 °F (–105 to 145 °C)	*
н	Inert (halocarbon)	1.85	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	N/A	–49 to 320 °F (–45 to 160 °C)	*
N ⁽¹⁷⁾	Neobee M-20	0.94	5 to 401 °F (–15 to 205 °C)	5 to 437 °F (–15 to 225 °C)	5 to 437 °F (–15 to 225 °C)	N/A	5 to 437 °F (–15 to 225 °C)	*
G ⁽¹⁰⁾⁽¹⁷⁾	Glycerin and water	1.13	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	N/A	5 to 437 °F (–15 to 225 °C)	*
P ⁽¹⁰⁾⁽¹⁷⁾	Propylene glycol and water	1.02	5 to 203 °F (−15 to 95 °C)	5 to 203 °F (−15 to 95 °C)	5 to 203 °F (−15 to 95 °C)	N/A	5 to 203 °F (−15 to 95 °C)	*

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Seal style			Process connections
67	page 35	FF flush flanged seal	2-in./DN 50/ 50A 3-in./DN 80/80A 4-in./DN 100/100A
S.	page 38	EF extended flanged seal	3-in./DN 80/80A 4-in./DN 100/100A
83	page 40	RF remote flanged seal	^{1/} 2-in. ³ /4-in. 1-in./DN 25/25A 1 ¹ /2-in./DN 40/40A
:	page 43	PF pancake seal	2-in./DN 50/50A 3-in./DN 80/80A
B	page 45	FC flush flanged seal - RTJ gasket surface	2-in. 3-in.
6	page 47	RC remote flange seal - RJT gasket surface	¹ /2-in ³ /4-in 1-in. 1 ¹ /2-in.
	page 49	RT remote threaded seal	¹ /4–18 NPT ¹ /2–14 NPT ³ /4–14 NPT 1–11.5 NPT 1 ¹ /4–11.5 NPT
	page 51	SC hygienic Tri-Clamp seal	1 ¹ /2-in. 2-in. 3-in.
	page 52	SS hygienic tank spud Seal	4-in.

Continue specifying a completed model number by choosing a remote seal type below:

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Wireless options (requires option code X and wireless Plantweb housing)

Update rat	Jpdate rate ⁽⁴⁾							
WA	User configurable update rate	*						
Operating	Operating frequency and protocol							
3	2.4 GHz DSSS, IEC 62591 (WirelessHART [®])	*						
Omni-dire	ctional wireless antenna							
WK ⁽⁴⁾	External antenna	*						
WM ⁽⁴⁾	Extended range, external antenna	*						
WN	High-gain, remote antenna							
SmartPow	er ⁽¹⁸⁾⁽¹⁹⁾							
1	Adapter for Black Power Module (I.S. Power Module sold separately)	*						

Options (include with selected model number)

Extended p	product warranty	
WR3	3-year limited warranty	*
WR5	5-year limited warranty	*
Plantweb o	control functionality ⁽¹⁹⁾⁽²⁰⁾⁽²¹⁾	
A01	FOUNDATION Fieldbus advanced control function block suite	*
Plantweb o	diagnostic functionality	
D01 ⁽¹⁹⁾⁽²⁰⁾	FOUNDATION Fieldbus diagnostics suite	*
DA2 ⁽²²⁾	Advanced HART diagnostics suite	*
Mounting	bracket	
B4	Bracket, all SST, 2-in. pipe panel	*
BE	316SST B4-style bracket with 316SST bolting	*
Software c	onfiguration ⁽²³⁾	
C1	Custom software configuration (requires Configuration Data Sheet)	*
Gage press	ure calibration	
С3	Gage pressure calibration on Rosemount 3051SALA4 only	*
Alarm limi	t ⁽²⁰⁾⁽²³⁾	
C4	NAMUR alarm and saturation levels, high alarm	*
C5	NAMUR alarm and saturation levels, low alarm	*
C6	Custom alarm and saturation signal levels, high alarm (requires C1 and Configuration Data Sheet)	*
С7	Custom alarm and saturation signal levels, low alarm (requires C1 and Configuration Data Sheet)	★

C8	Low alarm (standard Rosemount alarm and saturation levels)		
Hardware adjustments ⁽²⁰⁾⁽²³⁾⁽²⁴⁾			
D1	Hardware adjustments (zero, span, alarm, security)		
Flange ada	pter		
D2	¹ /2-14 NPT flange adapter	*	
D9	RC 1/2 SST flange adapter		
Ground scr	ew ⁽²⁵⁾		
D4	External ground screw assembly	*	
Drain/vent	valve		
D5	Delete transmitter drain/vent valves (install plugs)	*	
Conduit plu	ום ⁽²⁶⁾		
DO	316 SST conduit plug	*	
Product certifications ⁽²⁷⁾			
E1	ATEX Flameproof	*	
11	ATEX Intrinsic Safety	\star	
IA	ATEX FISCO Intrinsic Safety (FOUNDATION Fieldbus Protocol only)	*	
N1	ATEX Type n	*	
K1	ATEX Flameproof, Intrinsic Safety, Type n, Dust		
ND	ATEX Dust	*	
E4	TIIS Flameproof	*	
E5	FM Explosion-proof, Dust Ignition-proof		
15	FM Intrinsically Safe; Nonincendive		
IE	FM FISCO Intrinsically Safe (FOUNDATION Fieldbus Protocol only)		
К5	FM Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2		
E6 ⁽²⁸⁾	CSA Explosion-proof, Dust Ignition-proof, Division 2		
16	CSA Intrinsically Safe		
IF	CSA FISCO Intrinsically Safe (FOUNDATION Fieldbus Protocol only)	*	
K6 ⁽²⁸⁾	CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*	
D3 ⁽²⁹⁾	Measurement Canada Accuracy Approval	*	
E7	IECEx Flameproof, Dust Ignition-proof	*	
17	IECEx Intrinsic Safety	*	
IG	IECEx FISCO Intrinsic Safety (FOUNDATION Fieldbus Protocol only)	*	
N7	IECEx Type n	*	
К7	IECEx Flameproof, Dust Ignition-proof, Intrinsic Safety, Type n		
E2	INMETRO Flameproof	\star	

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

12	INMETRO Intrinsic Safety			
IB	INMETRO FISCO Intrinsic Safety			
К2	INMETRO Flameproof, Intrinsic Safety	*		
E3	China Flameproof	*		
13	China Intrinsic Safety, Dust Ignition-proof	*		
EP	Korea Flameproof	*		
IP	Korea Intrinsic Safety	*		
КР	Korea Flameproof, Intrinsic Safety	*		
EM	Technical Regulations Customs Union (EAC) Flameproof	*		
IM	Technical Regulations Customs Union (EAC) Intrinsic Safety	*		
КМ	Technical Regulations Customs Union (EAC) Flameproof, Intrinsic Safety	*		
KA ⁽²⁸⁾	ATEX and CSA Flameproof, Intrinsically Safe, Division 2	*		
KB ⁽²⁸⁾	FM and CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*		
КС	FM and ATEX Explosion-proof, Intrinsically Safe, Division 2	★		
KD ⁽²⁸⁾	FM, CSA, and ATEX Explosion-proof, Intrinsically Safe	*		
Shipboard	approvals			
SBS	American Bureau of Shipping (ABS) Type Approval	*		
SBV	Bureau Veritas (BV) Type Approval	*		
SDN	Det Norske Veritas (DNV) Type Approval	*		
SLL	Lloyds Register (LR) Type Approval			
Stainless st	teel tagging			
Y2	316SST nameplate, top tag, wire-on tag(s), and fasteners	*		
Sensor fill f	fluid ⁽³⁰⁾			
L1	Inert sensor fill fluid	*		
O-ring				
L2	Graphite-filled PTFE O-ring	*		
Bolting ma	terial			
L4	Austenitic 316 SST bolts	*		
L5 ⁽³¹⁾	ASTM A193, grade B7M bolts	*		
L6	Alloy K–500 bolts			
L7 ⁽³¹⁾	ASTM A453, Class D, grade 660 bolts	★		
L8	ASTM A193, Class 2, grade B8M bolts	*		
Display type ⁽²⁰⁾⁽³²⁾⁽³³⁾				
M5 ⁽³⁴⁾	Plantweb LCD display	*		

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

M7	Remote mount LCD display and interface, Plantweb housing, no cable, SST bracket			
M8	Remote mount LCD display and interface, Plantweb housing, 50 ft. (15 m) cable, SST bracket			
M9	Remote mount LCD display and interface, Plantweb housing, 100 ft. (31 m) cable, SST bracket			
Pressure te	Pressure testing			
P1	Hydrostatic testing with certificate			
Special clea	aning			
P2	Cleaning for special services			
Р3	Cleaning for less than 1PPM chlorine/fluorine			
Calibration	certification			
Q4	Calibration certificate	*		
QP	Calibration certificate and tamper evident seal	*		
Material tra	aceability certification			
Q8	Material traceability certification per EN 10204 3.1	*		
Quality cer	tification for safety			
QS ⁽²⁰⁾⁽²³⁾	Prior-use certificate of FMEDA Data	*		
QT ⁽³⁵⁾	Safety-certified to IEC 61508 with certificate of FMEDA data	*		
Toolkit per	formance reports			
QZ	Remote seal system performance calculation report	*		
Transient p	protection ⁽³⁶⁾⁽³⁷⁾			
T1	Transient terminal block	*		
Conduit ele	ectrical connector ⁽³⁸⁾			
GE	M12, 4-pin, male connector (eurofast [®])	*		
GM	A size Mini, 4-pin, male connector (minifast®)	*		
NACE certi	ficate ⁽³¹⁾			
Q15	Certificate of Compliance to NACE MR0175/ISO 15156 for wetted materials	*		
Q25	Certificate of Compliance to NACE MR0103 for wetted materials	*		
Typical mo	del number: 3051SAL 1 C G 2A A 1A 10 20 D FF G 1 DA 0 0			

^{1.} For detailed specifications see "Specifications" on page 126. The Rosemount 3051S ERS System offers three performance class options; classic, ultra, and enhanced ERS system performance. The classic and ultra performance classes are suited to lower static pressure and stable temperature conditions. The enhanced ERS system performance class provides better performance across temperature (–40 to 185 °F) with improved performance at higher static pressure.

2. Requires Plantweb housing.

3. Only intrinsically safe approval codes apply.

4. Only available with output code X.

5. Available with output code A only. Available approvals are FM Intrinsically Safe; Nonincendive (option code 15), CSA Intrinsically Safe (option code 16), ATEX Intrinsic Safety (option code 11), or IECEx Intrinsic Safety (option code 17). Contact an Emerson Process Management representative for additional information.

6. Low side seal identical to high side seal.

7. Maximum working pressure is 4000 psi (275 bar).

Emerson.com/Rosemount

- 8. MWP of the thermal range expander is 3750 psi (258,6 bar).
- 9. Requires separate Rosemount 1199 model number to be selected. With option code 1, user must select Seal Location Option code M (low side of transmitter) in the Rosemount 1199 Remote Mount Seal System Model.
- 10. Not suitable for vacuum applications.
- 11. PVC coating should not be exposed to temperatures above 212 °F (100 °C) to avoid possibility of thermal breakdown.
- 12. Capillary length applies to both high and low side for balanced systems. Applies to low side only for tuned-system assemblies. Applies to high side only for remote mount single seal systems with capillary.
- 13. At ambient pressure of 14.7 psia (1 bar-a) and ambient temperature of 70 °F (21 °C). Temperature limits are reduced in vacuum service and may be limited by seal selection.
- 14. Due to heat transfer to the transmitter, the maximum process temperature of the transmitter will be de-rated if ambient or process temperatures exceed 185 °F (85 °C). Consult Instrument Toolkit to verify the application.
- 15. For complete process and ambient temperature limits, see "Thermal Range Expander Temperature Operating Range" on page 135.
- 16. Only available with thermal range expander.
- 17. This is a food grade fill fluid.
- 18. Long-life power module must be shipped separately, order power module 701PBKKF.
- 19. Not available with output code A.
- 20. Not available with output code X.
- 21. With option code 10, user must select seal location option code M in Table 18 on page 76.
- 22. Requires Plantweb housing and output code A. Includes hardware adjustments as standard.
- 23. Not available with output code F.
- 24. Not available with housing style codes 2E, 2F, 2G, 2M, 5A, 5J, or 7J.
- 25. This assembly is included with options EP, KP, E1, N1, K1, ND, E4, E7, N7, K7, E2, E3, KA, KC, KD. IA, IB, IE. IF, IG, K2, T1, EM, and KM.
- 26. Transmitter is shipped with 316 SST conduit plug (uninstalled) in place of carbon steel conduit plug.
- 27. Valid when SuperModule[™] Platform and housing have equivalent approvals.
- 28. Not available with M20 or G¹/2 conduit entry size.
- 29. Requires Plantweb housing and hardware adjustments option code D1. Limited availability depending on transmitter type and range. Contact an Emerson representative for additional information.
- 30. Silicone fill fluid is standard.
- 31. Materials of construction comply with metallurgical requirements highlighted within NACE MR0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR0103 for sour refining environments. Order with Q15 or Q25 to receive a NACE certificate.
- 32. Not available with housing code 01 or 7J.
- 33. Not available with output code F, option code DA2, or option code QT.
- 34. See the Rosemount 3051S Reference Manual for cable requirements. Contact an Emerson representative for additional information.
- 35. Not available with output code F or X. Not available with housing code 7J.
- 36. The T1 option is not needed with FISCO Product Certifications; transient protection is included in the FISCO product certification codes IA, IB, IE, IF, and IG.
- 37. Not available with Housing code 5A, 5J, or 7J.
- 38. Not available with Housing code 5A, 5J, or 7J. Available with Intrinsically Safe approvals only. For FM Intrinsically Safe; Nonincendive (option code I5) or FM FISCO Intrinsically Safe (option code IE), install in accordance with Rosemount drawing 03151-1009.

Diaphragm seals for Rosemount 3051SAL



FF flush flanged seal

- Most common seal
- Good for use in general applications
- Easy installation on flanged connections ranging from 2-in. (DN 50) to 4-in. (DN 100)

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

Table 4. FF flush flanged Seal Ordering Information

Model	Process connection				
FF	Flush flanged seal				
Process connection size					
	ANSI/ASME B16.5	EN 1092-1/GOST 33259-15	JIS B2238		
G	2-in.	DN 50	50 A	*	
7	3-in.	N/A	80 A	*	
J	N/A	DN 80	N/A	*	
9	4-in.	DN 100	100 A	*	
Flange/pressure rating					
1	ANSI/ASME B16.5 Class 150				
2	ANSI/ASME B16.5 Class 300				
4	ANSI/ASME B16.5 Class 600				
G	PN 40 per EN 1092-1			*	
5	ANSI/ASME B16.5 Class 900				
6	ANSI/ASME B16.5 Class 1500				
7	ANSI/ASME B16.5 Class 2500				
Н	PN 63 per EN 1092-1				
J	PN 100 per EN 1092-1				
А	10K per JIS B2238				
В	20K per JIS B2238				
D	40K per JIS B2238				
E	PN 10/16 per EN 1092-1, available w	ith DN 100 only			
Materials o	of construction				
	Isolating diaphragm	Upper housing	Flange		
CA	316L SST	316L SST	CS	*	
DA	316L SST	316L SST	316 SST	*	
CB ⁽¹⁾	Alloy C-276	316L SST	CS	*	

Table 4. FF flush flanged Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Materials of construction					
DB ⁽¹⁾	Alloy C-276	316L SST	316 SST	*	
СС	Tantalum	316L SST	CS	*	
DC	Tantalum	316L SST	316 SST	*	
Flushing connection ring (lower housing)					
0	None			*	
A ⁽²⁾	316 SST			*	
B ⁽²⁾	Alloy C-276			*	
Flushing connection quantity and size					
0	None				
1	One ¹ /4–18 NPT flushing connection			*	
3	Two 1/4–18 NPT flushing connections			*	
7	One 1/2–14 NPT flushing connection			*	
9	Two 1/2–14 NPT flushing connections				

Options (include with selected model number)

Cold temperature remote seal applications				
RB	Extra fill fluid for cold temperature applications			
Remote se	Remote seal diaphragm thickness ⁽³⁾			
SC	0.006-in. (150 μm) diaphragm thickness			
Flushing connection ring plugs				
SF	Alloy C-276 plug(s) for flushing connection(s)	*		
SG	SST plug(s) for flushing connection(s)	*		
SH	SST drain/vent(s) for flushing connection(s)	*		
Lower housing alignment clamp				
SA	Lower housing alignment clamp	*		
Flushing connection ring gaskets				
S0	No gasket for lower housing	*		
SY	Thermo-tork® TN-9000	*		
SJ	PTFE gasket	*		
SK	Barium sulfate-filled PTFE gasket			
SN	GRAFOIL [®] gasket			
Table 4. FF flush flanged Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Remote seal diaphragm coating		
SZ ⁽³⁾	0.0002-in. (5 µm) gold plated diaphragm	
SV	PTFE coated diaphragm for non-stick purposes	

Complete the Rosemount 3051SAL model number by specifying options as needed:

page 14	ERS transmitter options	
page 22	Scalable level transmitter options	

1. Not available with option code SC.

2. Supplied with Thermo-tork TN-9000 gasket if no other flushing connection ring gasket option is selected.

3. Not available with tantalum diaphragms (material of construction codes CC and DC).



EF extended flanged seal

- Good for use in viscous applications with plugging issues
- Seal diaphragm installed flush with inner tank wall to prevent process plugging
- Easy installation on 3-in. (DN 80) and 4-in. (DN 100) flanged connections

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

Table 5. EF extended flanged Seal Ordering Information

Model	Process connection				
EF	Extended flanged seal				
Process co	nnection size				
	ANSI/ASME B16.5	EN 1092-1/GOST 33259-15	JIS B2238	Extension diameters	
7	3-in. schedule 80	DN 80	80A	2.58-in. (66 mm)	*
9	4-in. schedule 80	DN 100	100A	3.50-in. (89 mm)	*
Flange/pre	ssure rating				
1	ANSI/ASME B16.5 Class 150				*
2	ANSI/ASME B16.5 Class 300				*
4	ANSI/ASME B16.5 Class 600				*
G	PN 40 per EN 1092-1				*
5	ANSI/ASME B16.5 Class 900				
6	ANSI/ASME B16.5 Class 1500				
7	ANSI/ASME B16.5 Class 2500				
Н	PN 63 per EN 1092-1				
J	PN 100 per EN 1092-1				
А	10K per JIS B2238				
В	20K per JIS B2238				
D	40K per JIS B2238				
E	PN 10/16 per EN 1092-1, available w	ith DN 100 only			
Materials o	of construction				
	Isolating diaphragm	Extension/gasket surface	Mounting fl	ange	
CA	316L SST	316L SST	CS		*
DA	316L SST	316L SST	316 SST		*
СВ	Alloy C-276	Alloy C-276	CS		*
DB	Alloy C-276	Alloy C-276	316 SST		*
Seal extens	sion length				
20	2-in. (50 mm)				*
40	4-in. (100 mm)				*
60	6-in. (150 mm) *			*	

Table 5. EF extended flanged Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Options (include with selected model number)

Cold temperature remote seal applications		
RB	Extra fill fluid for cold temperature applications	*
Remote sea	al diaphragm thickness	
SC	0.006-in. (150 μm) diaphragm thickness	
Remote sea	al diaphragm coating	
SZ	0.0002-in. (5 μm) gold plated diaphragm	
SV	PTFE coated diaphragm for non-stick purposes	

Complete the Rosemount 3051SAL model number by specifying options as needed:

page 14	ERS transmitter options	
page 22	Scalable level transmitter options	



RF remote flanged seal

- Designed to improve performance on smaller process connections
- Easy installation on flanged connections ranging from 1- to 1.5-in. (DN 25–DN 40)
- Lower housing/flushing ring required.

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

Table 6. RF Remote Flanged Seal Ordering Information

Model	Process connection			
RF	Remote flanged seal			
Process co	nnection size			
	ANSI/ASME B16.5	EN 1092-1/GOST 33259-15	JIS B2238	
2	1-in.	N/A	25A	*
4	1 ¹ /2in.	N/A	40A	*
D	N/A	DN 25	N/A	*
F	N/A	DN 40	N/A	*
1	¹ /2-in.	N/A	N/A	
А	³ /4-in.	N/A	N/A	
Flange/pro	essure rating			
1	ANSI/ASME B16.5 Class 150			*
2	ANSI/ASME B16.5 Class 300			*
4	ANSI/ASME B16.5 Class 600			*
G	PN 40 per EN 1092-1			*
5	ANSI/ASME B16.5 Class 900			
6	ANSI/ASME B16.5 Class 1500			
7	ANSI/ASME B16.5 Class 2500			
А	10K per JIS B2238			
В	20K per JIS B2238			
D	40K per JIS B2238			
Materials	of construction			
	Isolating diaphragm	Upper housing	Flange	
CA	316L SST	316L SST	CS	*
DA	316L SST	316L SST	316 SST	*
СВ	Alloy C-276	316L SST	CS	*
DB	Alloy C-276	316L SST	316 SST	*
СС	Tantalum	316L SST	CS	*
DC	Tantalum	316L SST	316 SST	*

Table 6. RF Remote Flanged Seal Ordering Information

Flushing c	onnection ring material (lower housing) ⁽¹⁾	
А	316L SST	*
В	Alloy C-276	
Flushing c	onnection quantity and size	
5	None	*
1	One 1/4–18 NPT flushing connection	*
3	Two 1/4–18 NPT flushing connections	*
7	One 1/2–14 NPT flushing connection	
9	Two 1/2–14 NPT flushing connections	
Options	(include with selected model number)	
Cold temp	erature remote seal application	
RB	Extra fill fluid for cold temperature applications	*
Remote se	al diaphragm thickness ⁽²⁾	
SC	0.006-in. (150 μm) diaphragm thickness	
Large diap	hragm size	
S9	4.1-in. (104 mm) diaphragm diameter	
Flushing c	onnection ring plugs	
SF	Alloy C-276 plug(s) for flushing connection(s)	*
SG	316 SST plug(s) for flushing connection(s)	*
SH	316 SST drain vent(s) for flushing connection(s)	*
Flushing ri	ng connection gaskets	
SY	C-4401 gasket	*
SJ	PTFE gasket	*
SR	Ethylene propylene gasket	
SN	GRAFOIL gasket	
S6	TopChem 2000	
SK	Barium sulfate-filled PTFE gasket	
Remote se	al bolt material	
S3	304 SST bolts	*
S4	316 SST bolts	
Remote se	al diaphragm coating	
SZ ⁽²⁾	0.0002-in. (5 µm) gold plated diaphragm	
SV	PTFE coated diaphragm for non-stick purposes	

Table 6. RF Remote Flanged Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Complete the Rosemount 3051SAL model number by specifying options as needed:

page 14	ERS transmitter options	
page 22	Scalable level transmitter options	

1. Supplied with C-4401 aramid fiber gasket if no other remote seal gasket material is selected.

2. Not available with tantalum diaphragms (material of construction codes CC and DC).



PF pancake seal

Table 7. PF Pancake Seal Ordering Information

Model	Process connection				
PF	Pancake seal				*
Process co	nnection size				
	ANSI		EN 1092-1/GOST 332	59-15	
G	2-in.		DN 50		*
7	3-in.		N/A		*
J	N/A		DN 80		*
Flange/pro	essure rating				
	ANSI		EN 1092-1/GOST 332	59-15	
0	No flanged supplied, seal maximum pressure (MWP) based on customer	working supplied flange	N/A		*
9	N/A		No flanged supplied, s supplied flange	eal MWP based on customer	*
1	Class 150		N/A		*
2	Class 300		N/A		*
4	Class 600		N/A		*
G	N/A		PN40		*
5	Class 900		N/A		
6	Class 1500		N/A		
7	Class 2500		N/A		
Н	N/A		PN63		
J	N/A		PN100		
Diaphragr	n and wetted, upper housing, fla	ange material			
	Diaphragm and wetted	Upper housing		Flange	
LA ⁽¹⁾	316L SST	316L SST		None	*
CA ⁽¹⁾	316L SST	316L SST		CS	*
DA ⁽¹⁾	316L SST	316L SST		316 SST	*
LB	Alloy C-276, seam welded	316L SST		None	*
BB	Alloy C-276, seam welded	Alloy C-276		None	*
СВ	Alloy C-276, seam welded	316L SST		CS	*
DB	Alloy C-276, seam welded	316L SST		316 SST	*
LC	Tantalum, seam welded	316L SST		None	*
СС	Tantalum, seam welded	316L SST		CS	*
DC	Tantalum, seam welded	316L SST		316 SST	*

Table 7. PF Pancake Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Flushing c	onnection ring (lower housing)	
0	None	*
A ⁽²⁾	316 SST	*
B ⁽²⁾	Alloy C-276	\star
Flushing c	onnection quantity and size	
0	None	*
1	One 1/4–18 NPT flushing connection	*
3	Two 1/4–18 NPT flushing connections	*
7	One 1/2–14 NPT flushing connection	\star
9	Two 1/2–14 NPT flushing connections	*

Options (include with selected model number)

Lower hou	Lower housing alignment clamp		
SA	Lower housing alignment clamp	*	
Flushing c	onnection ring gaskets ⁽²⁾		
S0	No gasket for lower housing	*	
SY	Thermo-tork TN-9000	*	
SJ	PTFE gasket	*	
SK	Barium sulfate-filled PTFE gasket		
SN	GRAFOIL gasket		
Flushing c	onnection ring plugs		
SF	Alloy C-276 plug(s) for flushing connection(s)	*	
SG	SST plug(s) for flushing connection(s)	*	
SH	SST drain/vent(s) for flushing connection(s)	*	
Remote se	al diaphragm thickness ⁽³⁾		
SC	0.006-in. (150 μm) diaphragm thickness		
Cold temp	erature remote seal applications		
RB	Extra fill fluid for cold temperature applications		
Remote se	al diaphragm coating		
SZ ⁽³⁾	0.0002-in. (5 µm) gold plated diaphragm		
SV	PTFE coated diaphragm for non-stick purposes		

Complete the Rosemount 3051SAL model number by specifying options as needed:

page 22	Scalable level transmitter options
---------	------------------------------------

1. For use with customer supplied spiral metallic gaskets.

2. Supplied with Thermo-tork TN-9000 gasket if no other flushing connection ring gasket option is selected.

3. Not available with tantalum diaphragms (material of construction codes CC and DC).

FC flush flanged seal - RTJ gasket surface



Table 8. FC Flush Flanged Seal - RTJ Gasket Surface Ordering Information

Model	Process connection			
FC	Flush flanged seal - RTJ gasket surface			
Process co	Process connection size			
G	2-in.			
7	3-in.			
9	4-in.			
Flange/pre	essure rating			
1	Class 150			
2	Class 300			
4	Class 600			
5	Class 900			
6	Class 1500			
7	Class 2500			
Diaphragn	n and wetted, upper housing, fla	ange material		
	Diaphragm and wetted	Upper housing	Flange	
DA	316L SST	316L SST	316 SST	
KB	Alloy C-276	316L SST	316 SST	
MB	Alloy C-276	316L SST	CS	
CA	316L SST	316L SST	CS	
Flushing c	onnection ring material (lower h	nousing)		
0	None			
А	316 SST			
В	Alloy C-276			
Flushing c	onnection quantity and size			
0	None			
1	One 1/4–18 NPT flushing connection			
3	Two 1/4–18 NPT flushing connections	5		
7	One 1/2–14 NPT flushing connection			
9	Two 1/2–14 NPT flushing connections	5		

Table 8. FC Flush Flanged Seal - RTJ Gasket Surface Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Options (include with selected model number)

Flushing ring connection plugs			
SF	Alloy C-276 plug(s) for flushing connection(s)		
SG	316 SST plug(s) for flushing connection(s)		
SH	316 SST drain vent for flushing connection(s)		
Remote seal diaphragm thickness			
SC	0.006-in. (150 μm) available with 316L SST, Alloy C-276, and duplex 2507 SST for abrasive applications		
Cold temp	Cold temperature remote seal application		
RB	Extra fill for cold temp application		
Remote seal diaphragm coating ⁽¹⁾			
SZ	0.002-in. (5 μm) gold plated diaphragm		
SV	PTFE coated diaphragm for nonstick purposes only		

Complete the Rosemount 3051SAL model number by specifying options as needed:

page 14	ERS transmitter options	
page 22	Scalable level transmitter options	

1. Only available on 316LSST and alloy C-276.



RC flush flanged seal - RTJ gasket surface

Table 9. RC Flush Flanged Seal - RTJ Gasket Surface Ordering Information

Model	Process connection			
RC	Flush flanged seal - RTJ gasket surface			
Process co	nnection size			
1	$^{1}/_{2}$ -in. (Class 150 to 1500 includes mo	unting ring bolts and mounting studs)		
А	³ / ₄ -in. (Class 150 includes mounting ri	ng bolts and mounting studs)		
2	1-in.			
4	1 ¹ / ₂ -in.			
Flange/pre	essure rating			
1	Class 150			
2	Class 300			
4	Class 600			
5	Class 900			
6	Class 1500			
7	Class 2500			
Diaphragn	n and wetted, upper housing, flar	nge material		
	Diaphragm and wetted	Upper housing	Flange	
DA	316L SST	316L SST	316 SST	
DB	Alloy C-276	316L SST	316 SST	
DC	Tantalum	316L SST	316 SST	
Flushing c	onnection ring material (lower ho	ousing) ⁽¹⁾		
А	316L SST			
В	Alloy C-276			
Flushing ri	ng connection and size			
0	None			
1	One 1/4–18 NPT flushing connection			
3	Two 1/4–18 NPT flushing connections			
7	One 1/2–14 NPT flushing connection			
9	Two 1/2–14 NPT flushing connections			

Table 9. RC Flush Flanged Seal - RTJ Gasket Surface Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Options (include with selected model number)

Flushing c	Flushing connection ring gaskets		
SY	C-4401 gasket	*	
SJ	PTFE gasket	*	
SR	Ethylene propylene gasket		
SN	GRAFOIL gasket		
S6	TopChem 2000		
SK	Barium sulfate-filled PTFE gasket		
Flushing c	onnection ring plugs		
SF	Alloy C-276 plug(s) for flushing connection(s)		
SG	316 SST plug(s) for flushing connection(s)		
SH	316 SST vent/drain for flushing connection(s)		
Remote se	al diaphragm thickness		
SC	0.006-in. (150 μm) available with 316L SST, alloy C-276, and duplex 2507 SST for abrasive applications		
Remote se	al bolt material		
S3 ⁽²⁾	304 SST bolts (only available for stud bolt design)		
S4	316 SST bolts (only available for stud bolt design)	*	
Large diap	hragm size		
S9	4.1-in. (104 mm) diaphragm diameter		
Cold temp	erature remote seal application		
RB	Extra fill for cold temp application		
Remote se	al diaphragm coating ⁽³⁾		
SZ	0.002-in. (5 µm) gold plated diaphragm		
SV	PTFE coated diaphragm for nonstick purposes only		

Complete the Rosemount 3051SAL model number by specifying options as needed:

page 14	ERS transmitter options	
page 22	Scalable level transmitter options	

1. Supplied with C-4401 aramid fiber gasket if no other remote seal gasket material is selected.

2. Standard stud bolts are carbon steel.

3. Only available on 316LSST and Alloy C-276.



RT remote threaded seal

- For use with threaded process connections (1/4–18 to 1–111/2 NPT)
- Rated for use in high-pressure applications (up to 2500 PSI)
- Optional flushing connections available

Table 10. RT Remote Threaded Seal Ordering Information

Process connection style				
RT	Remote threaded seal			*
Process con	nection size			
3	¹ /2–14 NPT			*
4	³ /4–14 NPT			*
5	1–11 ¹ /2 NPT			*
1	¹ /4–18 NPT			
6	1 ¹ /4 – 11 ¹ /2 NPT			
Pressure rat	ing			
0	2500 psi			*
8	1500 psi (Only available with 4.1-in.	[104 mm] diaphragm (Large diaph	ragm size code S9))	*
Isolating diaphragm material Upper housing material Flange		Flange		
CA	316L SST	316L SST	CS	*
DA	316L SST	316L SST	316 SST	*
СВ	Alloy C-276	316L SST	CS	*
DB	Alloy C-276	316L SST	316 SST	*
СС	Tantalum	316L SST	CS	*
DC	Tantalum	316L SST	316 SST	*
Flushing cor	nection ring material (lower ho	using) ⁽¹⁾⁽²⁾		
A	316L SST			*
В	Alloy C-276			*
Flushing ring	g connection quantity and size			
1	One ¹ /4-in. flushing connection			*
3	Two 1/4-in. flushing connections			*
5	None			*
7	One 1/2–14 NPT flushing connection			*
9	Two 1/2–14 NPT flushing connections	;		*

Table 10. RT Remote Threaded Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Options (include with selected model number)

Cold temperature remote seal application			
RB	Extra fill fluid for cold temperature applications	*	
Remote seal	Remote seal diaphragm thickness ⁽³⁾		
SC	0.006-in. (150 μm) diaphragm thickness		
Remote seal	flushing plug, drain/vent		
SF	Alloy C-276 plug(s) for flushing connection(s)	*	
SG	316 SST plug(s) for flushing connection(s)	*	
SH	316 SST drain/vent(s) for flushing connection(s)	*	
Remote seal	gasket material		
SY	C-4401 gasket (for use with flushing connection ring)	*	
SJ	PTFE gasket (for use with flushing connection ring)	*	
SR	Ethylene propylene gasket (for use with flushing connection ring)	*	
SN	GRAFOIL gasket (for use with flushing connection ring)	*	
S6	TopChem 2000 (for use with flushing connection ring)		
SK	Barium sulfate-filled PTFE gasket (for use with flushing connection ring)		
Remote seal	bolt		
S3	304 SST bolts	*	
S4	316 SST bolts		
Large diaph	ragm size		
S9	4.1-in. [104 mm] diaphragm diameter (Only available with Pressure Rating code 8)		
Remote seal	diaphragm coating		
SZ ⁽³⁾	0.0002-in. (5 μm) gold plated diaphragm		
SV	PTFE coated diaphragm for non-stick purposes		
Special three	ads in lower housing		
R9	Male lower housing threads		

Complete the Rosemount 3051SAL model number by specifying options as needed:

page 14	ERS transmitter options	
page 22	Scalable level transmitter options	

1. Supplied with C-4401 aramid fiber gasket if no other remote seal gasket material is selected.

2. Flushing connection ring/lower housing assembly bolts provided as standard are carbon steel.

3. Not available with tantalum diaphragms (material of construction codes CC and DC).



SC hygienic Tri-Clamp seal

- Good for use in hygienic applications
- Easy installation on tri-clover style Tri-Clamp connections (1.5- to 3-in.)
- Conforms to 3-A[®] Standard 74-06

Table 11. SC Hygienic Tri-Clamp Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Process connection ⁽¹⁾				
SC	Hygienic Tri-Clamp seal		*	
Process co	Process connection size			
3(2)	1 ¹ /2-in.		*	
5 ⁽³⁾	2-in.		*	
7	3-in.		*	
MWP				
0	1000 PSI		*	
Isolating di	Isolating diaphragm material Upper housing material			
LA00	316L SST	316L SST	*	
LB00	Alloy C-276	316L SST		

Options (include with selected model number)

Remote seal diaphragm polishing		
RE	Electropolishing	
Remote sea	al diaphragm surface finish	
RD	10 μin. (0.25 μm) R _a diaphragm surface finish	
RG	15 μin. (0.375 μm) R _a diaphragm surface finish	
RH	20 µin. (0.5 µm) R_a diaphragm surface finish	
Surface finish certification ⁽⁴⁾		
Q16	Surface finish certification for hygienic remote seals	*

Complete the Rosemount 3051SAL model number by specifying options as needed:

page 14	ERS transmitter options
page 22	Scalable level transmitter options

1. Clamp and gasket furnished by user. The MWP is dependent upon the clamp pressure rating.

2. Min-span is 1000 in H_2O or 2490 mbar for $1^1/2$ -in. Tri-Clamp seal.

3. Min-span is 150 inH₂O or 373 mbar for 2-in. Tri-Clamp Seal.

4. Q16 is only available when the diaphragm seal has surface finish options (RD, RG, and RH).



SS hygienic tank spud seal

- Commonly used in hygienic level applications
- Seal diaphragm installed flush with inner tank wall
- Conforms to 3-A standard 74-06

Table 12. SS Hygienic Tank Spud Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Process connection ⁽¹⁾					
SS	Hygienic tank spud seal		*		
Process conr	Process connection size				
А	4-in. Sch. 5 Tri-Clamp		*		
MWP (clamp	o rating)				
0	600 PSI (41,37 bar)		*		
Upper housi	ng				
А	316L SST		*		
Diaphragm a	and wetted	Extension material			
AL ⁽²⁾	316L SST	316L SST	*		
BB	Alloy C-276	316L SST			
Extension le	ngth				
2	2-in. (50 mm) extension		*		
6	6-in. (150 mm) extension		*		

Options (include with selected model number)

Remote seal diaphragm thickness				
SC	0.006-in. (150 μ m) diaphragm thickness			
Tank spud in	Tank spud included with shipment			
S1	SST tank spud included with shipment	*		
Remote seal	diaphragm polishing			
RE	Electropolishing			
Remote seal	diaphragm surface finish			
RH	20 μin. (0.5 μm) R _a diaphragm surface finish			
RG ⁽³⁾	15 μin. (0.375 μm) R _a diaphragm surface finish			
Surface finish certification ⁽⁴⁾				
Q16	Surface finishing certification for hygienic remote seals	*		

Table 12. SS Hygienic Tank Spud Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Complete the Rosemount 3051SAL model number by specifying options as needed:

page 14	ERS transmitter options
page 22	Scalable level transmitter options

1. Clamp and ethylene propylene o-ring (conforms to 3-A standard 74 and USP Class VI) supplied.

2. Diaphragm brazed and TIG-welded to extension.

3. Require option code R6 (electropolishing).

4. Q16 is only available when the diaphragm seal has surface finish options (RG and RH).

Rosemount 3051L Level Transmitter



Rosemount 3051L Level Transmitter

The Rosemount 3051L Level Transmitter combines the performance and capabilities of Rosemount 3051 Transmitters with the reliability and quality of a direct mount seal in one model number. Rosemount 3051L Level Transmitters offer a variety of process connections, configurations, and fill fluid types to meet a breadth of level applications. Capabilities of a Rosemount 3051L Level Transmitter include:

- Quantify and optimize total system performance (option code QZ)
- Tuned-system assembly (option code S1)
- Power advisory can pro actively detect degraded electrical loop integrity issues (option code DA0)
- Local Operator Interface (LOI) with straightforward menus and built-in configuration buttons (option code M4)

Additional information:

Specifications: page 126 Certifications: page 142 Dimensional drawings: page 169

See Specifications and options for more details on each configuration. Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

Table 13. Rosemount 3051L Level Transmitter Ordering Information

Rosemount model	Transmitter type ⁽¹⁾			
3051L	Level transmitter			
Pressure ra	nge			
2	–250 to 250 inH ₂ O (–621,60 to 621,60 mbar)		*	
3	–1000 to 1000 inH ₂ O (–2,48 to 2,48 bar)		*	
4	-300 to 300 psi (-20,68 to 20,68 bar)		*	
Transmitte	r output			
A ⁽²⁾	4–20 mA with digital signal based on HART Protocol			
F	FOUNDATION Fieldbus Protocol			
W ⁽³⁾	PROFIBUS [®] PA		*	
X ⁽⁴⁾	Wireless (requires wireless options and engineered polymer housing)		*	
M ⁽⁵⁾	Low-power 1–5 Vdc with digital signal based on HART Protocol			
Process cor	nnection size, diaphragm material (high side)			
Code	Process connection size	Diaphragm		
G ⁽⁶⁾	2-in./DN 50	316L SST	*	
H ⁽⁶⁾	2-in./DN 50	Alloy C-276	*	
]	2-in./DN 50	Tantalum	*	

Proces	s connection size,	, diaphragm material (high sid	e)		
A ⁽⁶⁾	3-in./DN 80		316L SST		*
B(6)	4-in./DN 100		316L SST		*
C ⁽⁶⁾	3-in./DN 80	3-in./DN 80			*
D ⁽⁶⁾	4-in./DN 100		Alloy C-276		*
E	3-in./DN 80		Tantalum		*
F	4-in./DN 100		Tantalum		*
Seal ex	tension length (h	igh side)			
0	None, flush me	ount			*
2	2-in./50 mm				*
4	4-in./100 mm				*
6	6-in./150 mm				*
Mount	ing flange size, ra	ting, material (high side)			
	Size	Rating		Material	
М	2-in.	ANSI/ASME B16.5 Class 150		CS	*
А	3-in.	ANSI/ASME B16.5 Class 150		CS	*
В	4-in.	ANSI/ASME B16.5 Class 150		CS	*
Ν	2-in.	ANSI/ASME B16.5 Class 300		CS	*
С	3-in.	ANSI/ASME B16.5 Class 300		CS	*
D	4-in.	ANSI/ASME B16.5 Class 300		CS	*
Р	2-in.	ANSI/ASME B16.5 Class 600		CS	*
E	3-in.	ANSI/ASME B16.5 Class 600		CS	*
X(6)	2-in.	ANSI/ASME B16.5 Class 150		316 SST	*
F(6)	3-in.	ANSI/ASME B16.5 Class 150		316 SST	*
G ⁽⁶⁾	4-in.	ANSI/ASME B16.5 Class 150		316 SST	*
Y(6)	2-in.	ANSI/ASME B16.5 Class 300		316 SST	*
H(6)	3-in.	ANSI/ASME B16.5 Class 300		316 SST	*
J (6)	4-in.	ANSI/ASME B16.5 Class 300		316 SST	*
Z ⁽⁶⁾	2-in.	ANSI/ASME B16.5 Class 600		316 SST	*
L(6)	3-in.	ANSI/ASME B16.5 Class 600		316 SST	*
Q	DN 50	PN 10-40 per EN 1092-1		CS	*
R	DN 80	PN 40 per EN 1092-1		CS	*
S	DN 100	PN 40 per EN 1092-1		CS	*
V	DN 100	PN 10/16 per EN 1092-1		CS	*
K ⁽⁶⁾	DN 50	PN 10–40 per EN 1092-1		316 SST	*

Mounting flange size, rating, material (high side)							
T (6)	DN 80	PN 40 per EN 109	92-1		316 SS	Т	*
U (6)	DN 100	PN 40 per EN 109	92-1		316 SS	Т	*
W ⁽⁶⁾	DN 100	PN 10/16 per EN	1092	-1	316 SS	Т	*
7(6)	4-in.	ANSI/ASME B16.5	5 Clas	s 600	316 SS	Т	*
1	N/A	10K per JIS B2238	3		CS		
2	N/A	20K per JIS B2238	3		CS		
3	N/A	40K per JIS B2238	3		CS		
4(6)	N/A	10K per JIS B2238	3		316 SS	Т	
5 ⁽⁶⁾	N/A	20K per JIS B2238	3		316 SS	Т	
6(6)	N/A	40K per JIS B2238	3		316 SS	Т	
Seal fill flui	d (high side)	Specific gravit	у	Temperature limits ⁽	7)(8)		
D	Silicone 200	0.934		–49 to 401 °F (–45 to 20	05 °C)		*
F	Silicone 200 for vacuum applications	0.934	0.934 For use in vacuu vapor pressure o Specification Te		plications below 14.7 psia (1 bar-a), refer to in Rosemount DP Level Fill Fluid al Note.		*
J ⁽⁹⁾	Tri-Therm 300	0.795		–40 to 401 °F(–40 to 20)5 °C)		*
Q ⁽⁹⁾	Tri-Therm 300 for vacuum applications	0.795		–40 to 401 °F(–40 to 20	5 °C)		*
L	Silicone 704	1.07		32 to 401 °F (0 to 205 °C	()		*
C	Silicone 704 for vacuum applications	1.07	For use in vac 1.07 vapor pressu Specification		ications n Rosen <u>Note</u> .	below 14.7 psia (1 bar-a), refer to nount DP Level Fill Fluid	*
А	Syltherm XLT	0.85		–157 to 293 °F (–105 to	145 °C)	*
Н	Inert (halocarbon)	1.85		–49 to 320 °F (–45 to 10	60 °C)		*
G ⁽⁹⁾⁽¹⁰⁾	Glycerin and water	1.13		5 to 203 °F (–15 to 95 °C	2)		*
N ⁽⁹⁾	Neobee M-20	0.94		5 to 401 °F (–15 to 205 °	°C)		*
P ⁽⁹⁾⁽¹⁰⁾	Propylene glycol and water	1.02		5 to 203 °F (–15 to 95 °C	2)		*
Low pressu	ıre side						
	Configuration	Flange adapter	Dia	phragm material		Sensor fill fluid	
11 ⁽⁶⁾	Gage	SST	316	LSST		Silicone	*
21	Differential	SST 316L SST		LSST		Silicone	*
22	Differential	SST Alloy C-276 (SST valve seat)		y C-276 (SST valve seat)		Silicone	*
27 ⁽⁶⁾	Differential	SST Alloy C-276 (Alloy C-276 values seat))		e	Silicone	*	
2A ⁽¹¹⁾	Differential	SST	316	LSST		Inert (halocarbon)	*

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

2B ⁽¹¹⁾	Differential	SST	Alloy C-276 (SST valve seat)	Inert (halocarbon)	*
31(6)	Tuned-system assembly with remote seal	None	316L SST	Silicone (requires option code S1)	*
O-ring					
A	Glass-filled PTFE				*
Housing material		Conduit entry size			
A	Aluminum		¹ /2–14 NPT		*
В	Aluminum		M20×1.5		*
J	SST		1/2-14 NPT		*
К	SST		M20 imes 1.5		*
P ⁽¹²⁾	Engineered polymer		No conduit entries		*
D ⁽¹³⁾	Aluminum		G ¹ /2		
M ⁽¹³⁾	SST		G ¹ /2		

Wireless options (requires wireless output code X and engineered polymer housing code P)

Wireless transmit rate, operating frequency, and protocol			
WA3	User configurable transmit rate, 2.4 GHz WirelessHART Protocol	*	
Antenna and SmartPower			
WP5	Internal antenna, compatible with Green Power module (I.S. Power Module sold separately)	*	

HART Revision configuration⁽²⁾ (requires HART output code A)

HR5	Configured for HART Revision 5	*
HR7	Configured for HART Revision 7	*

Options (include with selected model number)

Extended product warranty				
WR3	3-year limited warranty	*		
WR5	5-year limited warranty	*		
Plantweb o	control functionality			
A01 ⁽¹⁴⁾	FOUNDATION Fieldbus Control Function Block Suite	*		
DA0 ⁽²²⁾	Power Advisory HART Diagnostic	*		
D01 ⁽¹⁴⁾	FOUNDATION Fieldbus Diagnostics Suite	*		
Seal assem	Seal assemblies ⁽¹⁵⁾			
S1	Assembled to one Rosemount 1199 Seal	*		

Product ce	rtifications	
E8	ATEX Flameproof and Dust Certification	*
 1 ⁽¹⁶⁾	ATEX Intrinsic Safety and Dust	*
IA	ATEX FISCO Intrinsic Safety; for FOUNDATION Fieldbus or PROFIBUS PA protocols only	*
N1	ATEX Type n Certification and Dust	*
K8	ATEX Flameproof, Intrinsic Safety, Type n, Dust (combination of E8, I1 and N1)	*
E4 ⁽¹⁷⁾	TIIS Flameproof	*
Product ce	rtifications	
E5	FM Explosion-proof, Dust Ignition-proof	*
15 ⁽¹⁸⁾	FM Intrinsically Safe, Nonincendive	*
IE	FM FISCO Intrinsically Safe; for FOUNDATION Fieldbus or PROFIBUS PA protocols only	*
K5	FM Explosion-proof, Dust Ignition-Proof, Intrinsically Safe, and Division 2	*
C6	CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, and Division 2	*
I6 ⁽¹²⁾	CSA Intrinsic Safety	*
K6	CSA and ATEX Explosion-proof, Intrinsically Safe, and Division 2 (combination of C6, E8, and I1)	*
E7	IECEx Flameproof, Dust Ignition-proof	*
17	IECEx Intrinsic Safety	*
N7	IECEx Type n Certification	*
K7	IECEx Flameproof, Dust Ignition-proof, Intrinsic Safety, and Type n (combination of I7, N7 and E7)	*
E2	INMETRO Flameproof	*
12	INMETRO Intrinsic Safety	*
IB	INMETRO FISCO intrinsically safe; for FOUNDATION Fieldbus or PROFIBUS PA protocols only	*
K2	INMETRO Flameproof, Intrinsic Safety	*
E3	China Flameproof	*
13	China Intrinsic Safety	*
N3	China Type n	*
EM	Technical Regulations Customs Union (EAC) Flameproof	*
IM	Technical Regulations Customs Union (EAC) Intrinsic Safety	*
KM	Technical Regulations Customs Union (EAC) Flameproof and Intrinsic Safety	*
КВ	FM and CSA Explosion-proof, Dust Ignition Proof, Intrinsically Safe, and Division 2 (combination of K5 and C6)	*
KD	FM, CSA, and ATEX Explosion-proof, Intrinsically Safe (combination of K5, C6, I1, and E8)	*
Shipboard	approvals	
SBS ⁽¹¹⁾	American Bureau of Shipping	*
SBV ⁽⁷⁾⁽¹⁹⁾	Bureau Veritas (BV)	
SDN ⁽⁷⁾	Det Norske Veritas	
SLL ⁽⁷⁾⁽¹⁹⁾	Lloyds Register (LR)	

Bolting ma	iterial	
L4	Austenitic 316 SST bolts	*
L5	ASTM A 193, Grade B7M bolts	*
L6	Alloy K–500 bolts	*
L8	ASTM A 193 Class 2, grade B8M bolts	*
Display an	d interface options	
M4 ⁽²⁰⁾	LCD display with Local Operator Interface	*
M5	LCD display	*
Calibration	n certification	
Q4	Calibration Certificate	*
QP	Calibration Certificate and tamper evident seal	*
QG ⁽²¹⁾	Calibration Certificate and GOST 33259-15 Verification Certificate	*
Material tr	aceability certification	
Q8	Material Traceability Certification per EN 10204 3.1	*
Quality cer	rtification for safety ⁽²²⁾	
QS	Prior-use certificate of FMEDA data	*
QT	Safety certified to IEC 61508 with certificate of FMEDA	*
Toolkit tot	al system performance reports	
QZ	Seal System Performance Calculation Report	*
Conduit el	ectrical connector ⁽¹¹⁾	
GE	M12, 4-pin, male connector (eurofast)	*
GM	A size mini, 4-pin, male connector (minifast)	*
Configurat	ion buttons	
D4 ⁽²²⁾	Analog zero and span	*
DZ ⁽²³⁾	Digital zero trim	*
Transient p	protection ⁽¹¹⁾⁽²⁴⁾	
T1	Transient protection	*
Software o	configuration ⁽²³⁾	
C1	Custom software configuration (completed Rosemount 3051 <u>Configuration Data Sheet</u> for wired and Rosemount 3051 Wireless <u>Configuration Data Sheet</u> for wireless required with order)	*
Low powe	r output	
C2	0.8–3.2 Vdc Output with digital signal based on HART protocol (available with Output code M only)	

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Alarm levels ⁽²²⁾					
C4	NAMUR alarm and saturation levels, high alarm				
CN	NAMUR alarm and saturation levels, lo	w alarm		*	
CR	Custom alarm and saturation signal lev	/els, high alarm (requ	uires C1 and Configuration Data Sheet)	*	
CS	Custom alarm and saturation signal lev	els, low alarm (requi	ires C1 and Configuration Data Sheet)	*	
СТ	T Rosemount standard low alarm				
Conduit plu	ug ⁽¹¹⁾				
DO	316 SST conduit plug			*	
Ground scr	ew ⁽¹¹⁾⁽²⁵⁾				
V5	External ground screw assembly			*	
Lower hou	sing flushing connection options ⁽⁷	26)			
	Ring material	Number	Size (NPT)		
F1	316 SST	1	¹ /4–18 NPT	*	
F2	316 SST	2	1/4–18 NPT	*	
F3	Alloy C-276	1	1/4–18 NPT	*	
F4	Alloy C-276	2	1/4–18 NPT	*	
F7	316 SST	1	¹ /2–14 NPT	*	
F8	316 SST	2	¹ /2–14 NPT	*	
F9	Alloy C-276	1	1/2-14 NPT	*	
FO	Alloy C-276	2	¹ /2–14 NPT	*	
Lower hou	sing alignment clamp				
SA	Lower housing alignment clamp			*	
Lower hou	sing intermediate gasket materia	l			
S0	No gasket for lower housing			*	
SY	Thermo-Tork TN-9000				
NACE certi	ficate ⁽²⁷⁾				
Q15	Certificate of compliance to NACE MRC)175/ISO 15156 for v	wetted materials	*	
Q25	Certificate of compliance to NACE MRC)103 for wetted mate	erials	*	
Typical mo	del number: 3051L 2 A A0 D 21 A /	\F1			

1. Select Configuration Buttons (option code D4 or DZ) or Local Operator Interface (option code M4) if local configuration buttons are required.

2. Option HR5 configures the HART output to HART Revision 5. Option HR7 configures the HART output to HART Revision 7. The device can be field configured to HART Revision 5 or 7 if desired. HART Revision 5 is the default HART output.

3. Option code M4 - LCD Display with Local Operator Interface required for local addressing and configuration.

4. Requires wireless options and engineered polymer housing. Available approvals are FM Intrinsically Safe, (option code I5), CSA Intrinsically Safe (option code I6), ATEX Intrinsic Safety (option code I1), IECEx Intrinsic Safety (option code I7) and EAC Intrinsic Safety (option code IM).

5. Only available with C6, E2, E5, I5, K5, KB and E8 approval. Not available with GE, GM, SBS, DA0, M4, D4, DZ, QT, HR5, HR7, CR, CS, CT.

- 6. Materials of Construction comply with metallurgical requirements highlighted within NACE MR0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR0103 for sour refining environments.
- 7. At ambient pressure of 14.7 psia (1 bar-a) and ambient temperature of 70 °F (21 °C). Temperature limits are reduced in vacuum service.
- 8. Due to heat transfer to the transmitter, the maximum process temperature of the transmitter will be de-rated if ambient or process temperatures exceed 185 °F (85 °C). Consult Instrument Toolkit to verify the application.
- 9. This is a food grade fill fluid.
- 10. Not suitable for vacuum applications.
- 11. Not available with Wireless output (code X).
- 12. Only available with Wireless output (code X).
- 13. Not available with Product certifications options E8, K8, E5, K5, C6, K6, E7, K7, E2, K2, E3, KB, KD.
- 14. Only valid with FOUNDATION Fieldbus output (code F).
- 15. "Assemble-to" items are specified separately and require a completed model number.
- 16. Dust approval not applicable to output code X. See "Rosemount 3051 Wireless" on page 165 for wireless approvals.
- 17. Only available with output codes A 4–20mA HART, F FOUNDATION Fieldbus, and W PROFIBUS PA. Also only available with G¹/2 housing thread types.
- 18. Nonincendive certification not provided with Wireless output option code (X).
- 19. Only available with product certifications E7, E8, I1, I7, IA, K7, K8, KD, N1, N7.
- 20. Not available with FOUNDATION Fieldbus (Output Code F) or Wireless output (code X) or Low Power (output code M).
- 21. Contact an Emerson representative for availability.
- 22. Only available with HART 4–20 mA output (code A).
- 23. Only available with 4–20 mA HART output (code A) and Wireless output (code X).
- 24. The T1 option is not needed with FISCO Product Certifications; transient protection is included in the FISCO product certification codes IA, IB, and IE.
- 25. The V5 option is not needed with the T1 option; external ground screw assembly is included with the T1 option.
- 26. Supplied with C-4401 aramid fiber gasket.
- 27. NACE compliant wetted materials are identified by Footnote 6.

Rosemount 2051L Liquid Level Transmitter



Rosemount 2051L Liquid Level Transmitter



Configuration	Transmitter output code
4–20 mA HART Rosemount 2051 Rosemount 2051 with Selectable HART ⁽¹⁾	А
Lower power Rosemount 2051 Rosemount 2051 with Selectable HART ⁽¹⁾	М
FOUNDATION Fieldbus	F
PROFIBUS	W
Wireless	Х

1. The 4–20mA with Selectable HART device can be ordered with Transmitter Output option code A plus any of the following options codes: M4, QT, DZ, CR, CS, CT, HR5, HR7.

Additional information Specifications: page 126

Certifications: page 159 Dimensional drawings: page 169

See Specifications and options for more details on each configuration. Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

Table 14. Rosemount 2051L Liquid Level Transmitter Ordering Information

Model	Transmitter type			
2051L	Liquid Level Transmitter ***			
Pressure rang	je			
2	–250 to 250 inH ₂ O (–0,6 to 0,6 bar)		*	
3	–1000 to 1000 inH ₂ O (–2,5 to 2,5 bar)		*	
4	-300 to 300 psi (-20,7 to 20,7 bar)		*	
Transmitter o	putput			
A ⁽¹⁾	4–20 mA with Digital Signal Based on HART Protocol ★			
F	FOUNDATION Fieldbus Protocol			
W	PROFIBUS PA Protocol			
Х	Wireless *			
М	Low-power, 1–5 Vdc with Digital Signal Based on HART Protocol			
Process conn	ection size, diaphragm material (high side)			
Code	Process connection size	Diaphragm		
G ⁽²⁾	2-in./DN 50	316L SST	*	
H ⁽²⁾	2-in./DN 50	Alloy C-276	*	
J	2-in./DN 50	Tantalum	*	

Process connection size, diaphragm material (high side)						
Code	Process connection size	2	Diaphragm			
A ⁽²⁾	3-in./DN 80		316L SST		*	
B ⁽²⁾	4-in./DN 100		316L SST		*	
C ⁽²⁾	3-in./DN 80		Alloy C-276		*	
D ⁽²⁾	4-in./DN 100		Alloy C-276		*	
E	3-in./DN 80		Tantalum	ıtalum		
F	4-in./DN 100		Tantalum		*	
Seal exten	sion length (high side)					
0	None, flush mount				*	
2	2-in./50 mm				*	
4	4-in./100 mm				*	
6	6-in./150 mm				*	
Mounting	flange size, rating, mate	rial (high side)				
	Size	Rating		Material		
М	2-in.	ANSI/ASME B16.5 Clas	s 150	CS	*	
А	3-in.	ANSI/ASME B16.5 Class 150		CS	*	
В	4-in.	ANSI/ASME B16.5 Class 150		CS	*	
Ν	2-in.	ANSI/ASME B16.5 Clas	s 300	CS	*	
С	3-in.	ANSI/ASME B16.5 Clas	s 300	CS	*	
D	4-in.	ANSI/ASME B16.5 Clas	s 300	CS	*	
X ⁽²⁾	2-in.	ANSI/ASME B16.5 Clas	s 150	SST	*	
F ⁽²⁾	3-in.	ANSI/ASME B16.5 Clas	s 150	SST	*	
G ⁽²⁾	4-in.	ANSI/ASME B16.5 Clas	s 150	SST	*	
Y(2)	2-in.	ANSI/ASME B16.5 Clas	s 300	SST	*	
H ⁽²⁾	3-in.	ANSI/ASME B16.5 Clas	s 300	SST	*	
J ⁽²⁾	4-in.	ANSI/ASME B16.5 Clas	s 300	SST	*	
Q	DN50	PN 10-40 per EN 1092	2-1	CS	*	
R	DN80	PN 40 per EN 1092-1		CS	*	
K ⁽²⁾	DN50	PN 10-40 per EN 1092	2-1	SST	*	
T ⁽²⁾	DN80	PN 40 per EN 1092-1		SST	*	

Seal fill fluid (high side)		Specific gravity at 77 °F (25 °C)	Temperature limits ⁽³⁾⁽⁴⁾	
D	Silicone 200	0.934	–49 to 401 °F (–45 to 205 °C)	*
F	Silicone 200 for vacuum applications	0.934	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u> .	*
J ⁽⁵⁾	Tri-Therm 300	0.795	–40 to 401 °F (–45 to 205 °C)	*
Q ⁽⁵⁾	Tri-Therm 300 for vacuum Applications	0.795	–40 to 401 °F (–45 to 205 °C)	*
L	Silicone 704	1.07	32 to 401 °F (0 to 205 °C)	*
С	Silicone 704 for vacuum applications	1.07	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note.</u>	*
А	Syltherm XLT	0.85	–157 to 293 °F (–105 to 145 °C)	*
Н	Inert (Halocarbon)	1.85	–49 to 320 °F (–15 to 160 °C)	*
G ⁽⁵⁾⁽⁶⁾	Glycerin and water	1.13	5 to 203 °F (–15 to 95 °C)	*
N ⁽⁵⁾	Neobee M-20	0.94	5 to 401 °F (–15 to 205 °C)	*
P (5)(6)	⁵⁾ Propylene Glycol and water		5 to 203 °F (–15 to 95 °C)	*
Sensor modu	le configuration, flang	e adapter (low side)		
	Configuration		Flange adapter	
1	Gage		SST	*
2	Differential		SST	*
3(7)	Tuned-System with remo	te seal	None	*
Sensor modu	le diaphragm material	, sensor fill fluid (low	v side)	
	Diaphragm material		Sensor fill fluid	
1	316L SST		Silicone	*
2	Alloy C-276 (SST Valve sea	at)	Silicone	*
7 ⁽²⁾	Alloy C-276 (Alloy C-276)	/alve seat)	Silicone	*
A ⁽⁸⁾	316L SST		Inert (Halocarbon)	*
B ⁽⁵⁾	Alloy C-276 (SST Valve sea	at)	Inert (Halocarbon)	*
O-ring				
A	Glass-filled PTFE			*
Housing mat	erial		Conduit entry size	
A	Aluminum		¹ /2–14 NPT	*
В	Aluminum		M20 × 1.5	*
J	SST		1/2-14 NPT	*

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

K ⁽⁹⁾	SST	M20 imes 1.5	*
P ⁽¹⁰⁾	Engineered polymer	No conduit entries	*
Housing mat	erial	Conduit entry size	
D	Aluminum	G ¹ /2	
M ⁽⁵⁾	SST	G ¹ /2	

Wireless options (requires Wireless output code X and Engineered Polymer housing code P)

Wireless transmit rate, operating frequency and protocol				
WA3	WA3 User configurable transmit rate, 2.4 GHz <i>Wireless</i> HART \star			
Antenna and SmartPower				
WP5Internal antenna, compatible with Green Power Module (I.S. Power Module sold separately)★				

Options (include with selected model number)

Extended product warranty					
WR3	3-year limited warranty	*			
WR5	5-year limited warranty	*			
Plantweb cor	ntrol functionality ⁽¹¹⁾				
A01	FOUNDATION Fieldbus advanced control function block suite	*			
Seal assembl	ies ⁽¹²⁾				
S1	Assemble to one Rosemount 1199 Seal (requires Rosemount 1199M)	*			
Product certi	fications				
E1 ⁽⁵⁾	ATEX Flameproof	*			
E2 ⁽⁵⁾	INMETRO Flameproof	*			
E3 ⁽⁵⁾	China Flameproof	*			
E4	TIIS Flameproof	*			
E5	FM Explosion-proof, Dust Ignition-proof	*			
E6	CSA Explosion-proof, Dust Ignition-proof, Division 2	*			
E7 ⁽⁵⁾	IECEx Flameproof	*			
EW ⁽⁵⁾	India (CCOE) Flameproof Approval	*			
1(5)	ATEX Intrinsic Safety	*			
I2 ⁽⁵⁾	INMETRO Intrinsically Safe	*			
I3 ⁽⁵⁾	China Intrinsic Safety	*			
I4 ⁽⁵⁾⁽⁶⁾	TIIS Intrinsic Safety	*			
15	FM Intrinsically Safe, Division 2	*			
16	CSA Intrinsically Safe	*			

IECEx Intrinsic Safety	*	
ATEX FISCO Intrinsic Safety; for FOUNDATION Fieldbus and PROFIBUS PA Protocol only	*	
FM FISCO Intrinsically Safety; for FOUNDATION Fieldbus and PROFIBUS PA Protocol only	*	
CSA FISCO Intrinsically Safety; for FOUNDATION Fieldbus and PROFIBUS PA Protocol only		
IECEx FISCO Intrinsically Safety; for FOUNDATION Fieldbus and PROFIBUS PA Protocol only	*	
India (CCOE) Intrinsically Safety Approval	*	
ATEX Flameproof, Intrinsic Safety, Type n, Dust	*	
INMETRO Flameproof and Intrinsic Safety	*	
FM Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*	
CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*	
IECEx Flameproof, Intrinsic Safety, Type n and Dust	*	
ATEX and CSA Flameproof, Intrinsically Safe, Division 2	*	
FM and CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2	*	
FM and ATEX Explosion-proof, Intrinsically Safe, Division 2	*	
FM, CSA, and ATEX Explosion-proof, Intrinsically Safe	*	
ATEX Type n	*	
IECEx Type n	*	
ATEX Dust	*	
Technical Regulations Customs Union (EAC) Flameproof	*	
Technical Regulations Customs Union (EAC) Intrinsic Safety	*	
Technical Regulations Customs Union (EAC) Flameproof and Intrinsic Safety	*	
provals ⁽⁵⁾		
American Bureau of Shipping (ABS) Type Approval	*	
Bureau Veritas (BV) Type Approval	*	
Det Norske Veritas (DNV) Type Approval	*	
Lloyds Register (LR) Type Approval	*	
nterface options ⁽¹³⁾		
LCD display with Local Operator Interface	*	
LCD display	*	
justments		
Zero and span configuration buttons	*	
Digital zero trim	*	
ers ⁽¹⁶⁾		
1/2–14 NPT flange adapters	*	
	IECEx Intrinsic Safety ATEX TRSC0 Intrinsic Safety; for FOUNDATION Fieldbus and PROFIBUS PA Protocol only CSA FISC0 Intrinsically Safety; for FOUNDATION Fieldbus and PROFIBUS PA Protocol only IECEX FISC0 Intrinsically Safety; for FOUNDATION Fieldbus and PROFIBUS PA Protocol only IECEX FISC0 Intrinsically Safety; for FOUNDATION Fieldbus and PROFIBUS PA Protocol only IECEX FISC0 Intrinsically Safety; for FOUNDATION Fieldbus and PROFIBUS PA Protocol only IECEX FISC0 Intrinsically Safety, for FOUNDATION Fieldbus and PROFIBUS PA Protocol only IECEX FISC0 Intrinsically Safety, Type n, Dust INMETRO Flameproof, Intrinsic Safety FM Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2 CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2 FM and CSA Falmeproof, Intrinsically Safe, Division 2 FM and CSA Falmeproof, Intrinsically Safe, Division 2 FM and CSA Explosion-proof, Dust Ignition-proof, Intrinsically Safe, Division 2 FM and CSA Explosion-proof, Intrinsically Safe, Division 2 FM and ATEX Explosion-proof, Intrinsically Safe, Division 2 FM and Safety Supposed IECEX Type n ATEX Dust Technical Regulations Customs Union (EAC) Flameproof and Intrinsic Safety provals (9) American Bureau Of Shipping (ABS) Type Approval LUoyds Register (RJ) Type Approval LUO	

Conduit plug ⁽⁵⁾⁽¹⁷⁾					
DO	316 SST conduit plug			*	
Ground screw	V ⁽⁵⁾⁽¹⁸⁾				
V5	External ground screw assembly			*	
Transient pro	tection ⁽⁵⁾⁽¹⁹⁾				
T1	Transient terminal block			*	
Software con	figuration ⁽¹¹⁾				
C1	Custom software configuration (requires completed Conf	iguration Data Shee	et)	*	
Alarm limit ⁽¹⁰))				
C4 ⁽²⁰⁾	NAMUR alarm and saturation levels, high alarm			*	
CN ⁽¹⁶⁾	NAMUR alarm and saturation levels, low alarm			*	
CR	Custom alarm and saturation signal levels, high alarm (rec	quires C1 and Config	guration Data Sheet)	*	
CS	Custom alarm and saturation signal levels, low alarm (requ	uires C1 and Config	uration Data Sheet)	*	
СТ	Low alarm (standard Rosemount alarm and saturation leve	els)		*	
Calibration ce	ertification				
Q4	Calibration certificate *			*	
QG	Calibration certificate and GOST 33259-15 Verification Certificate			*	
GP	Calibration certificate and tamper evident seal			*	
Material trace	eability certification				
Q8	28 Material Traceability Certification per EN 10204 3.1			*	
Quality certif	ication for safety				
QS ⁽²¹⁾	Prior-use certificate of FMEDA data			*	
QT ⁽¹⁷⁾	Safety certified to IEC 61508 with certificate of FMEDA *			*	
Toolkit total s	system performance reports				
QZ	Z Remote seal system performance calculation report *				
Conduit elect	rical connector ⁽⁵⁾				
GE	M12, 4-pin, male connector (eurofast)			*	
GM	A size mini, 4-pin, male connector (minifast)			*	
Lower housin	g flushing connection options ⁽²²⁾				
	Ring material	Number	Size (NPT)		
F1	316 SST	1	¹ /4–18 NPT	*	
F2	316 SST	2	¹ /4–18 NPT	*	
F3 ⁽²³⁾	Alloy C-276	1	¹ /4–18 NPT	*	

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

F4 ⁽¹⁹⁾	Alloy C-276	2	¹ /4–18 NPT	*				
F7	316 SST	1	¹ /2–14 NPT	*				
Lower housir	Lower housing alignment clamp							
SA	Lower housing alignment clamp			*				
Lower housir	ng flushing connection options ⁽²²⁾							
F8	316 SST	2	¹ /2–14 NPT	*				
F9	Alloy C-276	1	¹ /2–14 NPT	*				
FO	Alloy C-276	2	¹ /2–14 NPT	*				
Lower housir	ng intermediate gasket material							
S0	No gasket for lower housing			*				
SY	Thermo-Tork TN-9000							
NACE certific	NACE certificate							
Q15 ⁽²⁴⁾	Certificate of compliance to NACE MR0175/ISO 15156 for	wetted materials		*				
Q25 ⁽¹⁸⁾	Certificate of compliance to NACE MR0103 for wetted ma	iterials		*				
Typical mode	Typical model number: 2051L 2 A A0 X D 21 A A B4 M5 F1							

1. HART Revision 5 is the default HART output. The Rosemount 2051 with Selectable HART can be factory or field configured to HART Revision 7. To order HART Revision 7 factory configured, add option code HR7.

- Materials of Construction comply with metallurgical requirements highlighted within NACE MR0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR0103 for sour refining environments. Order with Q15 or Q25 to receive a NACE certificate.
- 3. At ambient pressure of 14.7 psia (1 bar-a) and ambient temperature of 70 °F (21 °C). Temperature limits are reduced in vacuum service.
- 4. Due to heat transfer to the transmitter, the maximum process temperature of the transmitter will be de-rated if ambient or process temperatures exceed 185 °F (85 °C). Consult Instrument Toolkit to verify the application.
- 5. This is a food grade fill fluid.
- 6. Not suitable for vacuum applications.
- 7. Requires option code S1.
- 8. Not available with output code X.
- 9. Not available with Low Power output code m
- 10. Only available with output code X.
- 11. Only valid with FOUNDATION Fieldbus output code F.
- 12. "Assemble-to" items are specified separately and require a completed model number.
- 13. Not valid with FOUNDATION Fieldbus output code F and Wireless Output Code X.
- 14. Only available with 4–20 mA HART (output codes A and M).
- 15. Only available with HART 4–20 mA output (output codes A) and Wireless output (output code X).
- 16. Not available with Remote Mount Seal Assembly option S1.
- 17. Transmitter is shipped with 316 SST conduit plug (uninstalled) in place of standard carbon steel conduit plug.
- 18. The V5 option is not needed with the T1 option; external ground screw assembly is included with the T1 option.
- 19. The T1 option is not needed with FISCO Product Certifications; transient protection is included in the FISCO product certification codes IA, IE, IF, and IG.
- 20. NAMUR-Compliant operation is pre-set at the factory.
- 21. Only available with HART 4–20 mA output (output code A).
- 22. Supplied with C-4401 aramid fiber gasket.
- 23. Not available with Option Codes A0, B0, and G0.
- 24. NACE Compliant wetted materials are identified by Footnote 2.

Rosemount 1199 Direct Mount Seal Systems



Tuned-System Assembly Comprised of Rosemount 1199 Direct Mount Seal combined with Rosemount 1199 Remote Mount Seal Rosemount 1199 Direct Mount Seals reduce installation costs by eliminating mounting hardware. Their advanced design also minimizes oil volume improving performance.

Product features and capabilities include:

- Direct Mount gage or absolute seal system can be used for open or vented to atmosphere tank applications
- Tuned-System Assembly order codes can be used to improve performance for DP measurements in closed or pressurized tank applications
- Variety of process connections
- Quantified performance for the entire transmitter/seal assembly (QZ option)

Additional Information:

Specifications: page 126 Dimensional drawings: page 169

Rosemount 1199 Direct Mount Seal

The Rosemount 1199 Direct Mount Seal also requires specification of a Rosemount pressure device. See the appropriate Product Data Sheet for the desired device and include the option indicated in the table below for the configuration desired.

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

When ordering Rosemount 1199 Direct and Remote Mount Seals, add the correct seal system ordering code to the transmitter or gage model.

Table 15. Direct Mount Seal Attach To Code Per Transmitter or Gage Model

Rosemount model	Two seals	One seal
3051S_C	B12	B11
3051C	S2	S1
2051C	S2	S1
3051S_T	N/A	B11
3051T, 3051HT, 2051T, 2088	N/A	S1
WPG, SPG	N/A	S1

A Rosemount 1199 Direct Mount Seal consists of two parts. First, specify the direct mount connection model codes found on page 70. Then, specify a remote seal found on page 72.



Table 16. Rosemount 1199 Direct Mount Seal Systems Ordering Information

Model	Product description								
1199	Seal systems								
Connection type			Seal system		Seal location				
All coplanar devices (Rosemount 3051S_C, 3051C, and 2051C)									
W	Welded-repairat	ole	One or two seal s	ystem	High side of transm	*			
R ⁽¹⁾	All welded		One seal system		High side of transm	*			
T ⁽¹⁾	All welded		Two seal system		High side of transm	*			
All In-line devices (Rosemount 3051S_T, 3051T, 3051HT, 2051T, 2088, WPG and SPG)									
W	All welded		One seal system		N/A	*			
Seal fill fluid Seal fill fluid 77 °F (25 °C)		Temperature limits ⁽²⁾⁽³⁾							
		gravity at 77 °F (25 °C)	No extension	on 2-in. (50 mm) 4-in. (100 mm) Thermony extension extension optim		Thermal optimizer			
D	Silicone 200	0.934	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	*		
F	Silicone 200 for vacuum applications	0.934	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u> .						
J ⁽⁴⁾	Tri-Therm 300	0.795	–40 to 401 °F (–40 to 205 °C)	–40 to 464 °F (–40 to 240 °C)	–40 to 572 °F (−40 to 300 °C)	N/A	*		
Q ⁽⁴⁾	Tri-Therm 300 for vacuum Applications	0.795	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u> .						
L	Silicone 704	1.07	32 to 401 °F (0 to 205 °C)	32 to 464 °F (0 to 240 °C)	32 to 572 °F (0 to 300 °C)	32 to 599 °F (0 to 315 °C)	*		
с	Silicone 704 for vacuum applications	1.07	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u> .						
R	Silicone 705	1.09	68 to 401 °F (20 to 205 °C)	68 to 464 °F (20 to 240 °C)	68 to 572 °F (20 to 300 °C)	68 to 698 °F (20 to 370 °C)	*		
v	Silicone 705 for vacuum applications	1.09	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u> .						
А	Syltherm XLT	0.85	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	*		
н	Inert (Halocarbon)	1.85	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	*		
G ⁽⁴⁾⁽⁵⁾	Glycerine and water	1.13	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	*		

Table 16. Rosemount 1199 Direct Mount Seal Systems Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

N ⁽⁴⁾	Neobee M-20	0.94	5 to 401 °F (–15 to 205 °C)	5 to 437 °F (–15 to 225 °C)	5 to 437 °F (–15 to 225 °C	5 to 437 °F) (–15 to 225 °C)	*		
P(4)(5)	Propylene Glycol and water	1.02	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (-15 to 95 °C)	*		
Seal con	Seal connection type								
A	Direct mount								
Direct mount connection type									
	Extension length			Seal system		Connection type			
All copla	All coplanar devices (Rosemount 3051S_C, 3051C and 2051C)								
94	Direct mount, no extension			Tuned-System Asse	mbly, two seals	Welded-repairable	*		
93	Direct mount, no extension			One seal system		Welded-repairable	*		
96	Direct mount, no extension			Tuned-System Asse	mbly, two seals	All welded	*		
97	Direct mount, no extension			One seal system		All welded	*		
B4	Direct mount, 2-in. (50 mm) extension			Tuned-System Asse	mbly, two seals	Welded-repairable	*		
B3	Direct mount, 2-in. (50 mm) extension			One seal system		Welded-repairable	*		
B6	Direct mount, 2-in. (50 mm) extension			Tuned-System Asse	mbly, two seals	All welded	*		
B7	Direct mount, 2-in. (50 mm) extension			One seal system	All welded	*			
D4	Direct mount, 4-in. (100 mm) extension			Tuned-System Asse	Welded-repairable	*			
D3	Direct mount, 4-in. (100 mm) extension			One seal system Welded-repairable					
D6	Direct mount, 4-in. (100 mm) extension			Tuned-System Asse	All welded	*			
D7	Direct mount, 4-in. (100 mm) extension			One seal system		All welded	*		
All In-line devices (Rosemount 3051S_T, 3051T, 3051HT, 2051T, 2088, WPG, and SPG)									
95	Direct mount, no extension			One seal system	All welded	*			
C5 ⁽⁶⁾	In-line direct mo	ount, 4-in. (100mr	(100mm) extension One seal system			All welded			
D5 ⁽⁶⁾	Thermal optimizer			One seal system All welded					

1. All welded system connection types require either a 316L SST or Alloy C-276 isolating diaphragm in the pressure transmitter model codes.

2. At ambient pressure of 14.7 psia (1 bar-a) and ambient temperature of 70 °F (21 °C).

3. Due to heat transfer to the transmitter, the maximum process temperature of the transmitter will be de-rated if ambient or process temperatures exceed 185 °F (85 °C). Consult Instrument Toolkit to verify the application.

4. This is a food grade fill fluid.

5. Not suitable for vacuum applications.

6. Maximum working pressure is 4000 psi (275 bar)

Continue specifying a completed model number by choosing a remote seal type below:

Flanged seal assemblies			● = Transmitter availability – = Unavailable						
			In-Line	Coplanar extensions		ır ns	Process connections		
				0-in.	2-in.	4-in.			
6.	page 82	FFW flush flanged seal	•	-	•	•	2-in./DN 50/50A 3-in./DN 80/80A 4-in./DN 100/100A	*	
83	page 86	RFW remote flanged seal	•	_	•	•	¹ /2-in./DN 15 ³ /4-in. 1-in./DN 25/25A 1 ¹ /2-in./DN 40/40A	*	
S	page 90	EFW extended flanged seal	•	(1)	•	•	1 ¹ /2-in./DN 40/40A 2-in./DN 50/50A 3-in./Headbox/DN 80/80A 4-in./Headbox/DN 100/100A	*	
Po	page 96	FCW flush flanged seal - RTJ gasket surface	•	(1)	•	•	2-in. 3-in.		
6	page 98	RCW remote flanged seal - RTJ gasket surface	•	-	•	•	¹ /2-in. ³ /4-in. 1-in. 1 ¹ /2-in.		
60.	page 101	FUW and FVW flush flanged type seals	•	(2)	•	•	DN 50 DN 80		
Threaded seal assemblies		● = Transmitter availability - = Unavailable							
---	----------------	---	---------	---------	------------------	---------	---	---	
The due u see	11 03501101103		In-Line	C ex	oplana tensio	r ns	Process connections		
	page 103	RTW threaded seal	•	_	•	•	¹ /4–18 NPT ³ /8–18 NPT ¹ /2–14 NPT ³ /4–14 NPT 1–11 ¹ /2NPT 1 ¹ /4–11 ¹ /2 NPT 1 ¹ /2–11 ¹ /2 NPT G ¹ /2 A DIN 16288 R ¹ /2 per ISO 7/1	*	
	page 107	HTS male threaded seal	•	•	•	•	G1 G1 1/2 G2 1–11 1/2 NPT 11/2–11 1/2 NPT 2–11 1/2 NPT		
Hygienic sea	assemblies								
	page 108	SCW hygienic tri-clover style Tri-Clamp seal	•	•	•	•	1 ¹ /2-in. 2-in. 2 ¹ /2-in. 3-in. 4-in.	*	
	page 110	SSW hygienic tank spud seal	•	•	•	•	2-in. extension 6-in. extension	*	
	page 113	STW hygienic thin wall tank spud seal	•	-	•	•	0.8-in. extension		
6	page 114	EES hygienic flanged tank spud extended seal	•	•	•	•	DN 50 DN 80		
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	page 115	VCS Tri-Clamp in-line seal	•	-	-	-	1-in. 1 ¹ /2-in. 2-in. 3-in. 4-in.		
	page 116	SVS VARIVENT [®] compatible hygienic connection seal	•	•	•	•	Tuchenhagen VARIVENT Compatible		

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Hygienic seal assemblies		● = Transmitter availability - = Unavailable						
			In-line	C ex	oplana tensio	ır ns	Process connections	
	page 117	SHP hygienic Cherry-Burrell [®] "I" line seal	•	-	_	_	2-in. 3-in.	
	page 118	SLS dairy process connection - female thread seal per DIN 11851	•	_	_	_	DN 40 DN 50	
Specialty sea	lassemblies							
	page 119	WSP saddle seal	•	-	•	•	2-in. 3-in. 4-in. or larger	
	page 121	UCP male threaded pipe mount seals and PMW paper mill sleeve seals	•	_	_	_	1 ¹ /2-in. with threaded knurled nut 1-in. with cap screw retainer	
	page 122	CTW chemical tee seal	•	_	•	•	Retro-fit	
Co	page 123	TFS wafer style in-line seal	•	-	_	-	1-in./DN 25 1 ¹ /2-in./DN 40 2-in./DN 50 3-in./DN 80 4-in./DN 100	
	page 124	WFW flow-thru flanged seal	•	_	•	•	1-in. 2-in. 3-in.	

1. Available with ANSI Class 300 or EN 1092-1 PN 40 or JIS B2238 20K or lower flange ratings.

2. FUW and FVW with diaphragm options DA and DC are only available with one piece design (option code E).

# **Rosemount 1199 Remote Mount Seal Systems**



Tuned-System Assembly Comprised of Rosemount 1199 Direct Mount Seal combined with Rosemount 1199 Remote Mount Seal Rosemount 1199 Remote Mount Seals are used commonly at the top of the vessel when a DP measurement is required. The capillary that is used is available in three different diameters to optimize time response and reduce temperature effects.

Product features and capabilities include:

- Remote Mount Seals can be used for high temperature applications.
- Remote Mount Seals are used on the low pressure side of the transmitter for Tuned-System Assemblies that can be used for DP measurements in closed or pressurized tank applications.
- Variety of process connections.
- Quantified performance for the entire transmitter/seal assembly (QZ option).

#### Additional Information:

Specifications: page 126 Certifications: page 159 Dimensional drawings: page 169

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 140 for more information on material selection.

## **Rosemount 1199 Remote Mount Seal**

The Rosemount 1199 Remote Mount Seal also requires specification of a Rosemount pressure transmitter. See the appropriate product data sheet for the desired transmitter and include the option indicated in the table below for the configuration desired.

When ordering Rosemount 1199 Direct and Remote Mount Seals, make sure to add the correct seal system ordering code to the transmitter or gage model.

#### Table 17. Direct Mount Seal Attach To Code Per Transmitter or Gage Model

Rosemount model	Two seals	One seal
3051S_C	B12	B11
3051C	S2	S1
2051C	S2	S1
3051S_T	N/A	B11
3051T, 3051HT, 2051T, 2088	N/A	S1
WPG, SPG	N/A	S1

A Rosemount 1199 Remote Mount Seal consists of two parts. First, specify the capillary model codes found on page 76. Then, specify a remote seal found on page 79.





## Capillary/fill fluid

### Note

Use Table 18 on page 76 for Capillary Type Connections. Use Table 16 on page 70 for Direct Mount Type Connections.

Г

## Table 18. Rosemount 1199 Remote Mount Seal Systems Ordering Information

Model	Product description			
1199	Seal system			
Conne	ction type	Seal system	Seal location	
All cop	lanar devices (Rosemount 3	051S_C, 3051C, and	2051C)	-
w	Welded-repairable	One or two seal system	High side of transmitter	*
М	Welded-repairable	One or two seal system	Low side of transmitter	*
D	Welded-repairable	Two seal system	Balanced system - same seal on low and high side	*
R ⁽¹⁾	All welded	One seal system	High side of transmitter	*
T ⁽¹⁾	All welded	Two seal system	High side of transmitter	*
S ⁽¹⁾	All welded	Two seal system	Low side of transmitter	*
All In-li	ne devices (Rosemount 305	1S_T, 3051T, 3051H	r, 2051T, 2088, WPG, and SPG)	
W	All welded	One seal system	N/A	*
Seal fil	l fluid	Specific gravity at 77 °F (25 °C)	Temperature limits ⁽²⁾⁽³⁾	
D	Silicone 200	0.934	–49 to 401 °F (–45 to 205 °C)	*
F	Silicone 200 for vacuum applications	0.934	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u> .	*
J ⁽⁶⁾	Tri-Therm 300	0.795	–40 to 572 °F (–40 to 300 °C)	*
Q ⁽⁶⁾	Tri-Therm 300 for vacuum Applications	0.795	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u> .	*
L ⁽⁴⁾	Silicone 704	1.07	32 to 599 °F (0 to 315 °C)	*
C ⁽⁴⁾	Silicone 704 for vacuum applications	1.07	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u> .	*
R ⁽⁴⁾	Silicone 705	1.09	68 to 698 °F (20 to 370 °C)	*
V ⁽⁵⁾	Silicone 705 for vacuum applications	1.09	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u> .	*
А	Syltherm XLT	0.85	–157 to 293 °F (–105 to 145 °C)	*
н	Inert (Halocarbon)	1.85	–49 to 320 °F (–45 to 160 °C)	*
G ⁽⁶⁾⁽⁷⁾	Glycerin and water	1.13	5 to 203 °F (–15 to 95 °C)	*
N ⁽⁶⁾	Neobee M-20	0.94	5 to 437 °F (–15 to 225 °C)	*
P(6)(7)	Propylene Glycol and water	1.02	5 to 203 °F (–15 to 95 °C)	*

Table 18. Rosemount 1199 Remote Mount Seal Systems Ordering Information

Seal co	onnection type/capillary ID, description	
В	0.03-in. (0,711 mm) ID	*
С	0.04-in. (1,092 mm) ID	*
D	0.075-in. (1,905 mm) ID	*
E ⁽⁸⁾	0.03-in. (0,711 mm) ID, PVC coated with closed end	*
F ⁽⁸⁾	0.04-in. (1,092 mm) ID, PVC coated with closed end	*
G ⁽⁸⁾	0.075-in. (1,905 mm) ID, PVC coated with closed end	*
Н	0.03-in. (0,711 mm) ID, 4-in. support tube	*
J	0.04-in. (1,092 mm) ID, 4-in. support tube	*
К	0.075-in. (1,905 mm) ID, 4-in. support tube	*
M ⁽⁸⁾	0.03-in. (0,711 mm) ID, PVC coated, 4-in. support tube with closed end	*
N ⁽⁸⁾	0.04-in. (1,092 mm) ID, PVC coated, 4-in. support tube with closed end	*
P ⁽⁸⁾	0.075-in. (1,905 mm) ID, PVC PVC coated, 4-in. support tube with closed end	*
Capilla	ary length	
01	1 ft. (0,3 m)	*
05	5 ft. (1,5 m)	*
10	10 ft. (3,0 m)	*
15	15 ft. (4,5 m)	*
20	20 ft. (6,1 m)	*
51	1.6 ft. (0,5 m)	*
52	3.3 ft. (1,0 m)	*
53	4.9 ft. (1,5 m)	*
54	6.6 ft. (2,0 m)	*
55	8.2 ft. (2,5 m)	*
56	9.8 ft. (3,0 m)	*
57	11.5 ft. (3,5 m)	*
58	13.1 ft. (4,0 m)	*
59	16.4 ft. (5,0 m)	*
60	19.7 ft. (6,0 m)	*
25	25 ft. (7,6 m)	
30	30 ft. (9,1 m)	
35	35 ft. (10,7 m)	
40	40 ft. (12,2 m)	
45	45 ft. (13,7 m)	
50	50 ft. (15,2 m)	

#### Table 18. Rosemount 1199 Remote Mount Seal Systems Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

61	23 ft. (7,0 m)	
62	26.2 ft. (8,0 m)	
63	29.5 ft. (9,0 m)	
64	32.8 ft. (10,0 m)	
65	36.1 ft. (11,0 m)	
66	39.4 ft. (12,0 m)	
67	42.6 ft. (13,0 m)	
68	45.9 ft. (14,0 m)	
69	49.2 ft. (15,0 m)	

1. All welded system connection types require either a 316L SST or Alloy C-276 isolating diaphragm in the pressure transmitter model codes.

2. At ambient pressure of 14.7 psia (1 bar-a) and ambient temperature of 70 °F and must be further derated if ambient, temperature exceeds 70 °F (21 °C).

3. Due to heat transfer to the transmitter, the maximum process temperature of the transmitter will be de-rated if ambient or process temperatures exceed 185 °F (85 °C). Consult Instrument Toolkit to verify the application.

4. Only available with Seal Connection Type/Capillary ID, Description Codes C, D, F, G, J, K, N, and P.

5. Only available with Seal Connection Type/Capillary ID, Description Codes D, G, K, and P.

6. This is a food grade fill fluid.

7. Not suitable for vacuum applications.

8. PVC coating should not be exposed to temperatures above 212 °F (100 °C) to avoid the possibility of thermal breakdown.

Continue specifying a completed model number by choosing a remote seal type below:

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject
to additional delivery lead time.

Flanged seal assemblies			Process connections	
	page 82	FFW flush flanged seal	2-in./DN 50/50A 3-in./DN 80/80A 4-in./DN 100/100A	*
83	page 86	RFW flanged seal	^{1/2-} in./DN 15 ^{3/4-} in. 1-in./DN 25/25A 1 ¹ /2-in./DN 40/40A	*
- Second Second	page 90	EFW extended flanged seal	11/2-in./DN 40/40A 2-in./DN 50 50A 3-in./headbox/DN 80/80A 4-in./headbox/DN 100/100A	*
	page 93	PFW pancake seal	2-in./DN50 3-in./DN 80	*
8	page 96	FCW flush flanged seal – RTJ gasket surface	2-in. 3-in.	
6	page 98	RCW RTJ flanged seal	¹ /2-in. ³ /4-in. 1-in. 1 ¹ /2-in.	
.0.	page 101	FUW and FVW flush flanged type seals	DN 50 DN 80	
Threaded se	al assemblies		Process connections	
	page 103	RTW threaded seal	1/4–18 NPT 3/8–18 NPT 1/2–14 NPT 3/4–14 NPT 1–111/2 NPT 11/4–111/2 NPT 11/2 –111/2 NPT G ¹ /2 ADIN 16288 R ¹ /2 per ISO 7/1	*

	page 107	HTS male threaded seal	G1 G1 ¹ /2 G2 1–11 ¹ /2 NPT 1 ¹ /2 –11 ¹ /2 NPT 2–11 ¹ /2 NPT	
Hygienic seal	assemblies			
	page 108	SCW hygienic tri-clover style Tri-Clamp seal	1 ¹ /2-in. 2-in. 2 ¹ /2-in. 3-in. 4-in.	*
	page 110	SSW hygienic tank spud seal	2-in. extension 6-in. extension	*
	page 113	STW hygienic thin wall tank spud seal	0.8-in. extension	
	page 114	EES hygienic flanged tank spud extended seal	DN 50 DN 80	
	page 115	VCS Tri-Clamp in-line seal	1-in. 1 ¹ /2-in. 2-in. 3-in. 4-in.	
	page 116	SVS VARIVENT compatible hygienic connection seal	Tuchenhagen VARIVENT Compatible	
0	page 117	SHP hygienic Cherry-Burrell "I" line seal	2-in. 3-in.	
	page 118	SLS dairy process connection - female thread seal per DIN 11851	DN 40 DN 50	
Specialty sea	lassemblies			
	page 119	WSP saddle seal	2-in. 3-in. 4-in. or larger	

page 121	UCP male threaded pipe mount seals and PMW paper mill sleeve seals	1 ¹ /2-in. with threaded knurled nut 1-in. with cap screw retainer	
page 122	CTW chemical tee seal	Retro-fit	
page 123	TFS wafer style in-line seal	1-in./DN 25 1 ¹ /2-in./DN 40 2-in./DN 50 3-in./DN 80 4-in./DN 100	
page 124	WFW flow-thru flanged seal	1-in. 2-in. 3-in.	

# **Flanged seals**



## FFW flush flanged seal

## Table 19. FFW Flush Flanged Seal – Ordering Information

Code	Industry standards			
А	ANSI/ASME B16.5 (American Natio	nal Standards Institute/American Soci	iety of Mechanical Engineers)	*
D	EN 1092-1 (European Standard)			*
Т	GOST 33259-15 (Russian Standard	)		*
J	JIS B2238 (Japanese Industrial Stan	dard)		
Process con	nection style			
FFW	Flush flanged seal			*
Process con	nection size			
	ANSI/ASME B16.5	EN 1092-1/GOST 33259-15	JIS B2238	
G	2-in.	DN 50	50 A	*
7	3-in.	N/A	80 A	*
J	N/A	DN 80	N/A	*
9	4-in.	DN 100	100 A	*
Flange/pres	ssure rating			
1	Class 150	N/A	10K	*
2	Class 300	N/A	20K	*
4	Class 600	N/A	40K	*
G	N/A	PN 40	N/A	*
E	N/A	PN 10/16 (DN 100 only)	N/A	
5	Class 900	N/A	N/A	
6	Class 1500	N/A	N/A	
7	Class 2500	N/A	N/A	
Н	N/A	PN 63	N/A	
J	N/A	PN 100	N/A	
К	N/A	PN 160	N/A	
Diaphragm	and wetted, upper housing, fl	ange material		
	Diaphragm and wetted	Upper housing	Flange	
CA ⁽¹⁾⁽²⁾	316L SST	316L SST	CS	*
DA ⁽²⁾	316L SST	316L SST	316 SST	*
CB ⁽¹⁾	Alloy C-276, seam welded	316L SST	CS	*

## Table 19. FFW Flush Flanged Seal – Ordering Information

Diaphragm	and wetted, upper housing, fl	ange material		
DB	Alloy C-276, seam welded	316L SST	316 SST	*
CC ⁽¹⁾	Tantalum, seam welded	316L SST	CS	*
DC	Tantalum, seam welded	316L SST	316 SST	*
C3 ⁽¹⁾⁽²⁾⁽³⁾⁽⁴⁾	Tantalum, brazed	316L SST	CS	*
D3 ⁽¹⁾⁽²⁾⁽³⁾⁽⁴⁾	Tantalum, brazed	316L SST	316 SST	*
MB ⁽¹⁾⁽²⁾	Alloy C-276, solid faceplate	Alloy C-276/316L SST	CS	
KB ⁽¹⁾⁽²⁾	Alloy C-276, solid faceplate	Alloy C-276/316L SST	316 SST	
DJ	Alloy B, seam welded	316L SST	316 SST	
DF	304L SST, seam welded	316L SST	316 SST	
DV	Alloy 400, seam welded	316L SST	316 SST	
RH ⁽²⁾⁽⁵⁾	Titanium Grade 4	Titanium GR.4	316 SST	
DH ⁽⁶⁾	Titanium Grade 4, seam welded	316L SST	316 SST	
DE	Alloy 600, seam welded	316L SST	316 SST	
DP	Nickel 201, seam welded	316L SST	316 SST	
WW ⁽²⁾⁽⁷⁾	316Ti SST (WNr 1.4571)	316Ti SST (WNr 1.4571)	316Ti SST (WNr 1.4571)	
DZ ⁽⁶⁾	Zirconium 702, seam welded	316L SST	316 SST	
D4	Alloy C-22, seam welded	316L SST	316 SST	
D5	Duplex 2507 SST, seam welded	316L SST	316 SST	
СР	Nickel 201	316L SST	CS	
CV	Alloy 400	316L SST	CS	
CH ⁽⁶⁾	Titanium Grade 4	316L SST	CS	
C5	Duplex 2507 SST	316L SST	CS	
Flushing co	nnection ring material (lower	housing) ⁽⁸⁾		
0	None			*
А	316L SST			*
В	Alloy C-276			*
2	Duplex 2205 SST			
Н	Titanium Grade 4			
6	Nickel 201			
V	Alloy 400			
Flushing co	nnection options, quantity (siz	ze)		
0	None			*
1	1 (1/4–18 NPT)			*
3	2 (1/4–18 NPT)			*
7	1 ( ¹ /2–14 NPT)			*
9	2 (1/2–14 NPT)			*

## Table 19. FFW Flush Flanged Seal – Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

## **Options** (Include with selected model number)

Extended p	roduct warranty	
WR3	3-year limited warranty	*
WR5	5-year limited warranty	*
Intermedia	te gasket material	
0	No gasket for flushing connection ring (lower housing)	*
Υ	Thermo-tork TN-9000 (for use with flushing connection ring)	*
J	PTFE gasket (for use with flushing connection ring)	*
Ν	GRAFOIL gasket (for use with flushing connection ring)	
К	Barium sulfate filled PTFE gasket (for use with flushing connection ring)	
Lower hous	ing alignment clamp	
SA	Lower housing alignment clamp	*
Flushing plu	ıg, vent/drain valve	
D	Alloy C-276 plug(s) for flushing connection(s)	*
G	316 SST plug(s) for flushing connection(s)	*
Н	316 SST vent/drain for flushing connection(s)	*
Diaphragm	thickness	
С	0.006-in. (150 $\mu m$ ) available with 316L SST, Alloy C-276, and Duplex 2507 SST for abrasive applications	
7	0.002-in. (50 $\mu m$ ) available with 316L SST and Alloy C-276	
Mounting f	lange ⁽⁹⁾	
4	Flat face, flush flanged	
NACE certif	icate ⁽¹⁰⁾	
Q15	Certificate of Compliance to NACE MR0175/ISO 15156 for wetted materials	*
Q25	Certificate of Compliance to NACE MR0103 for wetted materials	*
Gasket surfa	ace finish	
1	Gasket Surface Ra 125 Max./EN 1092-1 Type B2	
Cold tempe	rature application	
В	Extra fill for cold temp application	*
Diaphragm	coating ⁽¹¹⁾	
Z	0.0002-in. (5 μm) gold plated diaphragm	
V	PTFE coated diaphragm for nonstick purposes only	
Capillary ch	lange	
2	Radial capillary connection	

 $\star$ 

#### Table 19. FFW Flush Flanged Seal – Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

### Alternate design

Е

One piece design

## Typical model number: 1199 W DC 1 0 A FFW 7 1 DA 0 0

- 1. Only available with two piece design.
- 2. For use with spiral wound metallic gaskets.
- 3. Not available with option code C.
- 4. Only available in Process Connection Size code G, 7, and J.
- 5. Not available with welded capillary connections or direct mount.
- 6. Operating temperature limited to 302 °F (150 °C).
- 7. Only available with one-piece design, option code E.
- 8. Supplied standard with Thermo-tork TN-9000 if no other gasket option is selected.
- 9. The mounting flange and upper housing are a single item for the one-piece design. Only available with diaphragm and wetted part material codes DA, DB, DJ, DF, DV, DH, DE, DP, WW, DZ, D4, DC, and D5.
- 10. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.
- 11. Only available on 316LSS, Alloy 400 and Alloy C-276.



## **RFW remote flanged seal**

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

#### Table 20. RFW Flanged Seal Ordering Information

Code	Industry standard				
А	ANSI/ASME B16.5 (American National Standards Institute/American Society of Mechanical Engineers)				
D	EN 1092-1 (European Standard)			*	
Т	GOST 33259-15 (Russian Standard)			*	
J	JIS B2238 (Japanese Industrial Standard)				
Process	connection style				
RFW	Flanged seal			*	
Process	connection size				
	ANSI/ASME B16.5	EN 1092-1/GOST 33259-15	JIS B2238		
2	1-in.	N/A	25A	*	
4	1 ¹ /2-in.	N/A	40A	*	
D	N/A	DN 25	N/A	*	
F	N/A	DN 40	N/A	*	
1	¹ /2-in.	N/A	N/A		
А	³ /4-in.	DN 10	10A		
В	N/A	DN 15	15A		
С	N/A	DN 20	20A		
Flange/p	pressure rating				
1	Class 150	N/A	10K	*	
2	Class 300	N/A	20K	*	
4	Class 600	N/A	40K	*	
G	N/A	PN 40	N/A	*	
5	Class 900	N/A	N/A		
6	Class 1500	N/A	N/A		
7	Class 2500	N/A	N/A		
С	N/A	PN 6	N/A		
Н	N/A	PN 63	N/A		
J	N/A	PN 100	N/A		
К	N/A	PN 160	N/A		

## Table 20. RFW Flanged Seal Ordering Information

Diaphi	ragm, upper housing, flange m	aterial		
	Diaphragm	Upper housing	Flange	
CA	316L SST	316L SST	CS	*
DA	316L SST	316L SST	316 SST	*
СВ	Alloy C-276	316L SST	CS	*
DB	Alloy C-276	316L SST	316 SST	*
СС	Tantalum	316L SST	CS	*
DC	Tantalum	316L SST	316 SST	*
DF	304L SST	316L SST	316 SST	
DJ	Alloy B	316L SST	316 SST	
DE	Alloy 600	316L SST	316 SST	
DV	Alloy 400	316L SST	316 SST	
DP	Nickel 201	316L SST	316 SST	
DK	Alloy 20	316L SST	316 SST	
RH ⁽¹⁾	Titanium Grade 4	Titanium Grade 4	316 SST	
DH	Titanium Grade 4	316L SST	316 SST	
D4	Alloy C-22	316L SST	316 SST	
D5	Duplex 2507 SST	316L SST	316 SST	
DZ	Zirconium 702	316L SST	316 SST	
CV	Alloy 400	316L SST	CS	
СР	Nickel 201	316L SST	CS	
Flushi	ng connection ring material (lo	wer housing) ⁽²⁾		
А	316L SST			*
В	Alloy C-276			*
2	Duplex 2205			
F	304L SST			
Н	Titanium grade 4			
V	Alloy 400			
С	Tantalum lined 316L SST (no flus	hing connection allowed)		
Flushi	ng connection options, quantit	y size		
5	None			*
1	1 (1/4–18 NPT)			*
3	2 (1/4–18 NPT)			*
7	1 (1/2–14 NPT)			
9	2 (1/2–14 NPT)			

### Table 20. RFW Flanged Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

## **Options** (Include with selected model number)

Extende	d product warranty	
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Interme	diate gasket material	
Y	C-4401 gasket (for use with flushing connection ring)	*
J	PTFE gasket (for use with flushing connection ring)	*
Ν	GRAFOIL gasket (for use with flushing connection ring)	
К	Barium sulfate filled PTFE gasket (for use with flushing connection ring)	
R	Ethylene propylene gasket (for use with flushing connection ring)	
Flushing	j plug, vent/drain valve	
D	Alloy C-276 plug(s) for flushing connection(s)	*
G	316 SST plug(s) for flushing connection(s)	*
Н	316 SST vent/drain for flushing connection(s)	*
Diaphra	gm thickness	
С	0.006-in. (150 $\mu m$ ) available with 316L SST, Alloy C-276, and Duplex 2507 SST for abrasive applications	
Bolt mat	terial	
3	304 SST bolts (only available for stud bolt design)	
FA	316 SST bolts (only available for stud bolt design)	
Gasket s	surface finish	
1	Gasket Surface Ra 125 Max./EN 1092-1 Type B2	
Cold ten	nperature application	
В	Extra fill for cold temp application	*
Diaphra	gm coating ⁽³⁾	
Z	0.0002-in. (5 μm) gold plated diaphragm	
V	PTFE coated diaphragm for nonstick purposes only	
Large di	aphragm size	
9	4.1-in. (104 mm) diaphragm diameter	
NACE ce	rtificate ⁽⁴⁾	
Q15	Certificate of compliance to NACE MR0175/ISO 15156 for wetted materials	*
Q25	Certificate of compliance to NACE MR0103 for wetted materials	*
Typical r	nodel number: 1199 W DC 1 0 A RFW 2 1 DA A 5	

1. Not available with welded capillary connections or direct mount.

2. Supplied with C-4401 Aramid fiber gasket if no other gasket option is selected.

3. Only available on 316LSS, Alloy 400 and Alloy C-276.

4. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.



## EFW extended flanged seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

## Table 21. EFW Extended Flanged Seal Ordering Information

Code	Industry standard			● = Available - = Unavailable	
А	ANSI/ASME B16.5 (American National Standards Institute/American Society of Mechanical Engineers)				
D	EN 1092-1 (European Standard)				*
Т	GOST 33259-15 (Russian Standard)				*
J	JIS B2238 (Japanese Industrial Standards)				
Process	connection style				
EFW	Extended flanged seal				*
Process	connection size				
	ANSI/ASME B16.5	EN 1092-1/GOST 33259-15	JIS B2238	Extension diameters	
7	3-in.	DN 80	80A 2	2.58-in. (66 mm)	*
9	4-in.	DN 100	100A 3	3.50-in. (89 mm)	*
4	1 ¹ /2-in.	DN 40	40A 1	I.45-in. (37 mm)	
G	2-in.	DN 50	50A 1	I.90-in. (48 mm)	
н	3-in. (Headbox)	DN 80 (Headbox)	- 2	2.875-in. (73 mm)	
к	4-in. (Headbox)	DN 100 (Headbox)	- 3	3.780-in. (96 mm)	
Flange/	pressure rating				
	ANSI/ASME B16.5	EN 1092-1/GOST 33259-15	JIS B2238		
1	Class 150	-	10K		*
2	Class 300	-	20К		*
4	Class 600	-	40K		*
G	-	PN 40	-		*
E	-	PN 10/16 (DN 100 only)	-		
5	Class 900	-	-		
6	Class 1500	-	-		
7	Class 2500	-	-		
Н	-	PN 63	-		
J	-	PN 100	-		
К	N/A	PN 160	N/A		

Γ

## Table 21. EFW Extended Flanged Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Diaphragm, extension and gasket surface, upper housing, flange material			Ava	ailab	le wit	h pro	ocess	conn	ection co	ode		
Code	Diaphragm	Extension/ gasket surface	Upper housing	Mounting flange	7	9	4	G	н	к		
DA	316L SST	316L SST	316L SST	316 SST	•	•	•	•	•	•		*
CA	316L SST	316L SST	316L SST	CS	•	•	•	•	•	•		*
DB	Alloy C-276	Alloy C-276	316L SST	316 SST	•	•	•	•	•	•		*
СВ	Alloy C-276	Alloy C-276	316L SST	CS	•	•	•	•	•	•		*
DM	Alloy C-276	316L SST	316L SST	316 SST	•	•	•	•	•	•		
DD	Tantalum	316L SST	316L SST	316 SST	•	•	-	-	-	-		
DC ⁽¹⁾	Tantalum	Tantalum lined	316L SST	316 SST	•	•	-	•	-	-		
D5	Duplex 2507 SST	Duplex 2205 SST	316L SST	316 SST	•	•	•	•	•	•		
D9	Duplex 2507 SST	316L SST	316L SST	316 SST	•	•	•	•	•	•		
Extens	ion length	•	· ·	•		·						
	ANICI/ACME D16	F	EN 1002	ו אסכררם אוו ו	COC	רככ	E0 16	=				

	ANSI/ASME B16.5	EN 1092-1/JIS B2238/GOST 33259-15	
2	2-in.	50 mm	*
4	4-in.	100 mm	*
6	6-in.	150 mm	*
8	8-in.	200 mm	
1	1-in.	25 mm	
3	3-in.	75 mm	
5	5-in.	125 mm	
7	7-in.	175 mm	
9	9-in.	225 mm	
Fractio	nal extension length		
	ANSI/ASME B16.5	EN 1092-1/JIS B2238/GOST 33259-15	
0	0-in.	0 mm	*

## **Options** (include with selected model number)

Extended product warranty				
WR3	3-year limited warranty	*		
WR5	5-year limited warranty	*		
Diaphra	ıgm thickness			
С	0.006-in. (150 $\mu m$ ) available with 316L SST, Alloy C-276, and Duplex 2507 SST for abrasive applications			

### Table 21. EFW Extended Flanged Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

NACE certificate ⁽²⁾					
Q15	Certificate of compliance to NACE MR0175/ISO 15156 for wetted materials				
Q25	Gasket surface Ra 125 maximum	*			
Gasket	surface finish				
1	Gasket Surface Ra 125 Max./EN 1092-1 Type B2				
Cold ter	Cold temperature application				
В	Extra fill for cold temperature application	*			
Diaphra	ngm coating ⁽³⁾				
Z	0.0002-in. (5 μm) gold plated diaphragm				
V	PTFE coated diaphragm for nonstick purposes only				
Typical	Typical model number: 1199 W DC 1 0 A EFW 7 1 DA 2 0				

1. Requires Gasket Surface Finish Code 1 Gasket Surface Finish Ra 125 Max. Available in extension lengths 2, 4, and 6-in. For all other lengths consult factory.

2. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.

3. Only available on 316LSS, Alloy 400 and Alloy C-276.



## **PFW pancake seal**

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

#### Table 22. PFW Pancake Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Code	Industry standard				
А	ANSI/ASME B16.5 (American National Standards Institute/American Society of Mechanical Engineers)	*			
D	EN 1092-1 (European Standard)	*			
Т	GOST 33259-15 (Russian Standard)	*			
Process	Process connection style				
PFW	Pancake seal	*			

### **Process connection size**

	ANSI	EN 1092-1/GOST 33259-15	
G	2-in.	DN 50	*
7	3-in.	N/A	★
J	N/A	DN 80	*

## Flange/pressure rating

	ANSI	EN 1092-1/GOST 33259-15	
0	No flange supplied, seal MWP based on customer supplied flange	No flange supplied, seal MWP based on customer supplied flange	*
1	Class 150	N/A	*
2	Class 300	N/A	*
4	Class 600	N/A	*
G	N/A	PN40	*
5	Class 900	N/A	
6	Class 1500	N/A	
7	Class 2500	N/A	
Н	N/A	PN 63	
J	N/A	PN 100	

## Diaphragm and wetted, upper housing, flange material

	Diaphragm and wetted	Upper housing	Flange	
LA ⁽¹⁾	316L SST	316L SST	None	*
CA ⁽¹⁾	316L SST	316L SST	CS	*
DA ⁽¹⁾	316L SST	316L SST	316 SST	*

## Table 22. PFW Pancake Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Diaphragm and wetted, upper housing, flange material					
LB	Alloy C-276, seam welded	316L SST	None	*	
СВ	Alloy C-276, seam welded	316L SST	CS	*	
DB	Alloy C-276, seam welded	316L SST	316 SST	*	
LC	Tantalum, seam welded	316L SST	None	*	
СС	Tantalum, seam welded	316L SST	CS	*	
DC	Tantalum, seam welded	316L SST	316 SST	*	
Flushing	connection ring material (lower housing)	(2)			
0	None			*	
А	316L SST			*	
В	Alloy C-276			*	
2	Duplex 2205 SST				
н	Titanium grade 4				
6	Nickel 201				
V	Alloy 400				
Flushing	connection options, quantity (size)				
0	None			*	
1	1 (1/4–14 NPT)			*	
3	2 (1/4–14 NPT)			*	
7	1 (1/2–14 NPT)			*	
9	2 (1/2–14 NPT)			*	

## **Options** (Include with selected model number)

Extended	Extended product warranty			
WR3	3-year limited warranty			
WR5	5-year limited warranty			
Intermed	liate gasket material			
0	No gasket for flushing connection ring (lower housing)	*		
Y	Thermo-tork TN-9000 (for use with flushing connection ring)	*		
J	PTFE gasket (for use with flushing connection ring)	*		
N	GRAFOIL gasket (for use with flushing connection ring)			
К	Barium sulfate filled PTFE gasket (for use with flushing connection ring)			
Lower ho	busing alignment clamp			
SA	Lower housing alignment clamp			

#### Table 22. PFW Pancake Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Flushing	plug, vent/drain valve	
D	Alloy C-276 plug(s) for flushing connection(s)	*
G	316 SST plug(s) for flushing connection(s)	*
Н	316 SST vent/drain for flushing connection(s)	*
Diaphrag	gm thickness	
С	0.006-in. (150 $\mu m$ ) available with 316L SST, Alloy C-276, and Duplex 2507 SST for abrasive applications	
NACE cer	tificate ⁽³⁾	
Q15	Certificate of compliance to NACE MR0175/ISO 15156 for wetted materials	*
Q25	Certificate of compliance to NACE MR0103 for wetted materials	*
Gasket s	urface finish	
1	Gasket Surface Ra 125 Max./EN 1092-1 Type B2	
Cold tem	perature application	
В	Extra fill for cold temp application	*
Diaphrag	ym coating ⁽⁴⁾	
Z	0.0002-in. (5 μm) gold plated diaphragm	
V	PTFE coated diaphragm for nonstick purposes only	
Typical n	nodel number: 1199 W DC 1 0 A PFW 7 1 DA 0 0	

1. For use with customer supplied spiral wound metallic gaskets.

2. Supplied with Thermo-tork TN-9000 gasket if no other gasket option is selected.

3. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.

4. Only available on 316LSST, Alloy 400, and Alloy C-276.



## FCW flush flanged seal – RTJ gasket surface

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

### Table 23. FCW Flush Flanged Seal – RTJ Gasket Surface Ordering Information

This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standards			
А	ANSI/ASME B16.5 (American National Standards Institute/American Society of Mechanical Engineers)			
Process	connection style			
FCW	Flush flanged seal - RTJ gasket surfac	re		
Process	connection size			
G	2-in.			
7	3-in.			
Flange/	pressure rating			
1	Class 150			
2	Class 300			
4	Class 600			
5	Class 900			
6	Class 1500			
7	Class 2500			
Diaphra	agm and wetted, upper housing,	flange material		
	Diaphragm and wetted	Upper housing	Flange	
DA	316L SST	316L SST	316 SST	
KB ⁽¹⁾	Alloy C-276	316L SST	316 SST	
K5 ⁽¹⁾	Duplex 2507 SST/Duplex 2205	316L SST	316 SST	
MB ⁽¹⁾	Alloy C-276	316L SST	CS	
CA ⁽¹⁾	316 L SST	316L SST	CS	
M5	316 L SST	316L SST	CS	
Flushin	g connection ring material (lowe	r housing)		
0	None			
А	316L SST			
В	Alloy C-276	Alloy C-276		
2	Duplex 2205 SST			

### Table 23. FCW Flush Flanged Seal – RTJ Gasket Surface Ordering Information

This seal is part of the Expanded offering and is subject to additional delivery lead time.

Flushing connection options		
0	None	
1	1 ( ¹ /4–18 NPT)	
3	2 ( ¹ /4–18 NPT)	
7	1 ( ¹ /2–14 NPT)	
9	2 ( ¹ /2–14 NPT)	

## **Options** (Include with selected model number)

Extended	d product warranty	
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Flushing	plug, vent/drain valve	
D	Alloy C-276 plug(s) for flushing connection(s)	
G	316 SST plug(s) for flushing connection(s)	
Н	316 SST vent/drain for flushing connection(s)	
Diaphrag	gm thickness	
С	0.006-in. (150 $\mu m$ ) available with 316L SST, Alloy C-276, and Duplex 2507 SST for abrasive applications	
7	0.002-in. (50 $\mu m$ ) available with 316L SST and Alloy C-276	
NACE cer	tificate ⁽²⁾	
Q15	Certificate of Compliance to NACE MR0175/ISO 15156 for wetted materials	*
Q25	Certificate of Compliance to NACE MR0103 for wetted materials	*
Cold tem	ip application	
В	Extra fill for cold temp application	
Diaphrag	gm coating ⁽³⁾	
Z	0.0002-in. (5 μm) gold plated diaphragm	
V	PTFE coated diaphragm for nonstick purposes only	
Alternate	design	
E	One-piece design	
Typical m	odel number: 1199 W DC 1 0 A FCW 7 1 DA 0 0	

1. Not available with one-piece design (option code E).

2. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.

3. Only available on 316LSST and Alloy C-276.



## RCW remote flange seal - RTJ gasket surface

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

### Table 24. RCW Remote Flange Seal Ordering Information

This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard		
А	ANSI/ASME B16.5 (American Natio	nal Standards Institute/American Soci	ety of Mechanical Engineers)
Process con	nection style		
RCW	Remote flanged seal - RTJ surface		
Process con	nection size		
1	¹ /2-in. (bolts and studs included for	ANSI Class 300 to 1500, not available	for ANSI Class 150)
А	³ /4-in. (not available for Class 150)		
2	1-in.		
4	1 ¹ /2-in.		
Flange/pres	ssure rating		
1	Class 150		
2	Class 300		
4	Class 600		
5	Class 900		
6	Class 1500		
7	Class 2500		
Diaphragm	, upper housing, flange materi	al	
	Diaphragm	Upper housing	Flange
CA	316L SST	316L SST	CS
DA	316L SST	316L SST	316 SST
СВ	Alloy C-276	316L SST	CS
DB	Alloy C-276	316L SST	316 SST
СС	Tantalum	316L SST	CS
DC	Tantalum	316L SST	316 SST
DE	Alloy 600	316L SST	316 SST
DF	304L SST	316L SST	316 SST
DJ	Alloy B316L SST	316L SST	316 SST
DV	Alloy 400	316L SST	316 SST
DP	Nickel 201	316L SST	316 SST
RH	Titanium grade 4	Titanium grade 4	316 SST

## Table 24. RCW Remote Flange Seal Ordering Information

This seal is part of the Expanded offering and is subject to additional delivery lead time.

Diaphragm, upper housing, flange material				
DH ⁽¹⁾	Titanium grade 4	316L SST	316 SST	
D4	Alloy 22	316L SST	316 SST	
D5	Duplex 2507 SST	316L SST	316 SST	
DZ ⁽¹⁾	Zirconium 702	316L SST	316 SST	
DK	Alloy 20	316L SST	316 SST	
Flushing co	nnection ring material (lower	housing) ⁽²⁾		
А	316L SST			
В	Alloy C-276			
F	304L SST			
Н	Titanium grade 4			
2	Duplex 2205 SST			
V	Alloy 400			
Flushing co	nnection options			
5	None			
1	1 (1/4–18 NPT)			
3	2 (1/4–18 NPT)			
7	1 (1/2–14 NPT)			
9	2 (1/2–14 NPT)			

## **Options** (include with selected model number)

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Intermedia	te gasket material	
Y	C-4401 gasket (for use with flushing connection ring)	*
J	PTFE gasket (for use with flushing connection ring)	
Ν	GRAFOIL gasket (for use with flushing connection ring)	
К	Barium sulfate filled PTFE gasket (for use with flushing connection ring)	
R	Ethylene propylene gasket (for use with flushing connection ring)	
Flushing plu	ıg, vent/drain valve	
D	Alloy C-276 plug(s) for flushing connection(s)	
G	316 SST plug(s) for flushing connection(s)	
Н	316 SST vent/drain for flushing connection(s)	

## Table 24. RCW Remote Flange Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Diaphragm thickness		
С	0.006-in. (150 $\mu m$ ) available with 316L SST, Alloy C-276, and Duplex 2507 SST for abrasive applications	
Bolt materi	al (optional)	
3	304 SST bolts (only available for stud bolt design)	
FA	316 SST bolts (only available for stud bolt design)	
NACE certif	icate ⁽³⁾	
Q15	Certificate of compliance to NACE MR0175/ISO 15156 for wetted materials	
Q25	Certificate of compliance to NACE MR0103 for wetted materials	
Cold tempe	rature application	
В	Extra fill for cold temp application	
Diaphragm	coating	
Z ⁽⁴⁾	0.0002-in. (5 μm) gold plated diaphragm	
V ⁽³⁾	PTFE coated diaphragm for nonstick purposes only	
Large diaph	iragm size	
9	4.1-in. (104 mm) diaphragm diameter	
Typical mod	lel number: 1199 W DC 1 0 A RCW 2 1 DA A 5	

1. Operating temperature is limited to 302 °F (150 °C).

2. Supplied with C-4401 aramid fiber gasket if no other gasket option is selected.

3. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.

4. Only available on 316LSS, Alloy 400, and Alloy C-276.



## FUW and FVW flush flanged type seals

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

Table 25. FUW and FVW Flush Flanged Type Seals – EN Ordering Information

This seal is part of the Expanded offering is subject to additional delivery lead time.

Code	Industry standard			
D	EN 1092-1 (European Standard)			
Т	GOST 33259-15 (Russian Standard)			
Proces	s connection style			
FUW	Flush flanged, EN 1092-1 Type D (groove)			
FVW	Flush flanged, EN 1092-1 Type C (tongue)			
Proces	s connection size			
G	DN 50			
J	DN 80			
Flange	/pressure rating			
G	PN 40			
Diaphr	agm and wetted, upper housing, flang	e material		
	Diaphragm and wetted	Upper housing	Flange	
DA ⁽¹⁾	316L SST	316L SST	316 SST	
KB ⁽²⁾	Alloy C-276	316L SST	316 SST	
DC ⁽¹⁾	Tantalum	316L SST	316 SST	
Flushing connection ring material (lower housing)				
0	None			
Flushing connection options, quantity (size)				
0	None			

## **Options** (include with selected model number)

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Cold temperature application		
В	Extra fill for cold temperature application	
Alternate design		
E	One piece design	

### Table 25. FUW and FVW Flush Flanged Type Seals – EN Ordering Information

This seal is part of the Expanded offering is subject to additional delivery lead time.

NACE certificate ⁽³⁾			
Q15	Certificate of compliance to NACE MR0175/ISO 15156 for wetted materials	*	
Q25	Certificate of compliance to NACE MR0103 for wetted materials	*	
Typical model number: 1199 W DC 1 0 A FUW J G DA 0 0			

1. Only available with one-piece design, option code E.

2. Only available with two-piece design.

3. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments.

Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.

# **Threaded seals**



## **RTW remote threaded seal**

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

### Table 26. RTW Remote Threaded Seal Ordering Information

Code	Industry standard				
А	ANSI/ASME B1.20.1 (American National Standards Institute/American Society of Mechanical Engineers)			*	
D	EN 10226-1 / ISO 228-1			*	
Process co	nnection style				
RTW	Threaded (standard thread is female, for ma	ale select Option code 9)		*	
Process co	nnection size				
	ANSI/ASME B1.20.1	EN 10226-1	ISO 228-1		
3	¹ /2-14 NPT	N/A	N/A	*	
4	³ /4–14 NPT	N/A	N/A	*	
5	1–11 ¹ /2 NPT	N/A	N/A	*	
7(1)	1 ¹ /2–11 ¹ /2 NPT	N/A	N/A	*	
1	¹ /4–18 NPT	N/A	N/A		
С	N/A	N/A	Parallel thread: G ¹ /2A DIN 16288		
2	³ /8–18 NPT	N/A	N/A		
6 ⁽¹⁾	1 ¹ /4–11 ¹ /2 NPT	N/A	N/A		
Ν	N/A	Tapered thread: R ¹ /2 per ISO 7/1	N/A		
Pressure ra	ating				
	ANSI/ASME B1.20.1	EN 10226-1	ISO 228-1		
0	2500 psi	172 bar H	172 bar H	*	
2 ⁽²⁾	5000 psi	344 bar	344 bar		
3(2)(3)	10000 psi	N/A	N/A		
8	1500 psi (4.1-in. [104 mm]) diaphragm	103 bar (4.1-in. [104 mm]) diaphragm	103 bar (4.1-in. [104 mm]) diaphragm		

## Table 26. RTW Remote Threaded Seal Ordering Information

Diaphragr	n, upper housing, flange material			
	Diaphragm	Upper housing	Flange	
CA	316L SST	316L SST	CS	*
DA	316L SST	316L SST	316 SST	*
СВ	Alloy C-276	316L SST	CS	*
DB	Alloy C-276	316L SST	316 SST	*
СС	Tantalum	316L SST	CS	*
DC	Tantalum	316L SST	316 SST	*
DJ	Alloy B	316L SST	316 SST	
DF	304L SST	316L SST	316 SST	
DP	Nickel 201	316L SST	316 SST	
DV	Alloy 400	316L SST	316 SST	
RH ⁽⁴⁾	Titanium grade 4	Titanium grade 4	316 SST	
DH ⁽⁵⁾	Titanium grade 4	316L SST	316 SST	
D4	Alloy 22	316L SST	316 SST	
D5	Duplex 2507 SST	316L SST	316 SST	
DE	Alloy 600	316L SST	316 SST	
DZ ⁽⁵⁾	Zirconium 702	316L SST	316 SST	
DK	Alloy 20	316L SST	316 SST	
RZ ⁽⁴⁾	Zirconium 702	Zirconium 702	316 SST	
Flushing c	onnection ring material (lower housi	ng) ⁽⁶⁾⁽⁷⁾		
A	316L SST			*
В	Alloy C-276			*
D	Plated carbon steel			
2	Duplex 2205 SST			
Н	Titanium grade 4			
V	Alloy 400			
F	304L SST			
Flushing c	onnection options			
5	None			*
1	1 (1/4–18 NPT)			*
3	2 (1/4-18 NPT)			*
7	1 (1/2–14 NPT)			
9	2 (1/2–14 NPT)			

#### Table 26. RTW Remote Threaded Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

## **Options** (include with selected model number)

Extended	product warranty				
WR3	3-year limited warranty				
WR5	VR5 5-year limited warranty				
Intermedi	ate gasket material				
Y	C-4401 gasket (for use with flushing connection ring)	*			
J	PTFE gasket (for use with flushing connection ring)	*			
Ν	GRAFOIL gasket (for use with flushing connection ring)	*			
R	Ethylene propylene gasket (for use with flushing connection ring)	*			
К	Barium sulfate filled PTFE gasket (for use with flushing connection ring)				
Flushing p	lug, vent/drain valve				
D	Alloy C-276 plug(s) for flushing connection(s)	*			
G	316 SST plug(s) for flushing connection(s)	*			
Н	316 SST vent/drain for flushing connection(s)	*			
Diaphragr	n thickness				
С	$0.006\text{-}\text{in.}$ (150 $\mu\text{m})$ available with 316L SST, Alloy C-276, and Duplex 2507 SST for abrasive applications				
Bolt mater	rial				
3	304 SST bolts	*			
4	316 SST bolts				
NACE cert	ificate ⁽⁸⁾				
Q15	Certificate of Compliance to NACE MR0175/ISO 15156 for wetted materials	*			
Q25	Certificate of Compliance to NACE MR0103 for wetted materials	*			
Cold temp	erature application				
В	Extra fill for cold temp application	*			
Diaphragr	n coating ⁽⁹⁾				
Z	0.0002-in. (5 μm) gold plated diaphragm				
V	PTFE coated diaphragm for nonstick purposes only				
Special th	reads in lower housing				
9	Male threads				
Typical mo	odel number: 1199 W DC 1 0 A RTW 3 0 DA A 5				

1. Flushing connection not available.

2. Consult an Emerson representative for pricing and availability on Pressure Rating codes 2 or 3.

- 3. The following process connection sizes are D rated: ³/4-in. (9000 psi/621 bar), 1-in. (8700 psi/600 bar), 1¹/4-in. (7000 psi/483 bar), and 1¹/2-in. (6000 psi/414 bar).
- 4. Not available with welded capillary connections or direct mount.
- 5. Operating temperature is limited to 302  $^\circ\text{F}$  (150  $^\circ\text{C}$ ).
- 6. Supplied with C-4401 aramid fiber gasket if no other gasket option is selected.
- 7. Flushing Connection Ring/Lower Housing assembly bolts provided as standard are carbon steel for ANSI and 304 SST for EN.
- 8. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.
- 9. Only available on 316LSS, Alloy 400, and Alloy C-276.

## HTS male threaded seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 140 for more information on material selection.

#### Table 27. HTS Male Threaded Seal Ordering Information

This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard		
А	ANSI/ASME B1.20.1 (American National Standards Institute/American Society of Mechanical Engineers)		
D	ISO 228-1		
Process connection style			
HTS	Male threaded seal		
Process connection size, pressure rating			
	ANSI/ASME B1.20.1	ISO 228-1	
5A ⁽¹⁾	1–11 ¹ /2 NPT, 8700 psi (600 bar)	N/A	
7A ⁽²⁾	1 ¹ /2–11 ¹ /2 NPT, 6000 psi (414 bar)	N/A	
9A ⁽³⁾	2–11 ¹ /2 NPT, 4000 psi (276 bar)	N/A	
EA ⁽¹⁾	N/A	G1, 455 bar (6600 psi)	
GA ⁽²⁾	N/A	G1 ¹ /2, BSP, 400 bar (5801 psi)	
JA ⁽³⁾	N/A	G2, BSP, 280 bar (4060 psi)	
Diaph	ragm and wetted, upper housing material		
	Diaphragm and wetted	Upper housing	
LA00	316L SST	316L SST	
Typical model number: 1199 W DC 1 0 A HTS 7 A LA 0 0			

## **Options** (Include with selected model number)

Exten	Extended product warranty		
WR3	3-year limited warranty		
WR5	5-year limited warranty		

1. Consult factory for calibrated spans lower than 300 psi (21 bar).

2. Consult factory for calibrated spans lower than 100 psi (7 bar).

3. Consult factory for calibrated spans lower than 50 psi (3.4 bar).

# **Hygienic seals**



## SCW hygienic tri-clover style Tri-Clamp seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

## Table 28. SCW Hygienic Tri-Clover Style Tri-Clamp Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Industry standard			
S	Hygienic seal (conforms to 3-A Standard 74-06 and EHEDG Type EL Class I)		*
Process co	onnection style		
SCW ⁽¹⁾	Tri-clover style Tri-Clamp seal		*
Process connection size			
30 ⁽²⁾	1 ¹ /2-in.		*
50 ⁽³⁾	2-in.		*
70	3-in.		*
60	2 ¹ /2-in.		
90	4-in.		
Diaphragm and wetted, upper housing material			
	Diaphragm and wetted	Upper housing	
LA00	316L SST	316L SST	*
LB00	Alloy C-276	316L SST	

## **Options** (include with selected model number)

Extended product warranty			
WR3	3-year limited warranty		
WR5	5-year limited warranty		
Surface finish			
D	10 μin. (0.25 μm) R _a surface finish		
G	15 μin. (0.375 μm) R _a surface finish		
Н	20 μin. (0.50 μm) R _a surface finish		
Non-hygienic fill fluid			
Р	Non-hygienic fill fluid (does not conform to 3-A Standard 74)		
Clamp and gasket material ⁽⁴⁾			
2 ⁽⁵⁾	High-Pressure Ladish [™] Clamp and Nitrile butadiene (NBR) Gasket		
3	Nitrile Butadiene (NBR) Gasket		
#### Table 28. SCW Hygienic Tri-Clover Style Tri-Clamp Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Polishing	
6	Electropolishing
Typical model number: 1199 W NC 1 0 S SCW 7 0 LA 0 0	

- 1. For gaskets furnished by the user, ensure EGEDG-approved gaskets are used to ensure conformity. EHEDG conformity is not retained if clamp and gasket material codes 2 or 3 are selected.
- 2. Consult factory for calibrated spans lower than 1000 in  $H_2O$  (2490 mbar).
- 3. Consult factory for calibrated spans lower than 150 inH₂O (373 mbar).
- 4. Not EHEDG approved.
- 5. See Table 29.

#### Table 29. High Pressure Ladish Clamp MWP

Process connection size	70 °F (21 °C)	250 °F (121 °C)
1¹/2-in.	1,500 psi (103 bar)	1,200 psi (83 bar)
2-in.	1,000 psi (69 bar)	800 psi (55 bar)
2 ¹ /2-in.	1,000 psi (69 bar)	800 psi (55 bar)
3-in.	1,000 psi (69 bar)	800 psi (55 bar)
4-in.	1,000 psi (69 bar)	800 psi (55 bar)



# SSW hygienic tank spud seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

## Table 30. SSW Hygienic Tank Spud Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Code	Industry standard			
S	Hygienic seal (conforms to 3-A Standard 74-06)		*	
Proces	s connection style			
SSW ⁽¹⁾	Tank spud seal		*	
Proces	s connection size, pressure rating			
A0	600 psi (41 bar)		*	
Upper	housing			
А	316L SST *		*	
Diaphr	Diaphragm and wetted, extension material			
	Diaphragm and wetted Extension			
AL	316L SST ⁽²⁾	316L SST ⁽²⁾	*	
BB	Alloy C-276 316L SST *			
Extension length				
2	2-in.		*	
6	6-in.		*	

# **Options** (Include with selected model number)

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Surface finish		
G ⁽³⁾	15 μin. (0.375 μm) diaphragm surface finish	
Н	20 μin.(0.5 μm) diaphragm surface finish	
Diaphragm thickness		
С	0.006-in. (150 μm)	
Tank spud		
1	SST Tank spud included with shipment	*
Non-hygienic fill fluid		
Р	Non-hygienic fill fluid (does not conform to 3-A Standard 74)	

#### Table 30. SSW Hygienic Tank Spud Seal Ordering Information

The starred offerings (*) represent the most common options and should be selected for best delivery. The non-starred offerings are subject to additional delivery lead time.

Special O-rings		
3	Nitrile butadiene (NBR) O-ring instead of standard ethylene propylene O-ring (conforms to 3-A Standard 74)	
4	Fluorocarbon (FMK) O-ring, instead of standard ethylene propylene O-ring (conforms to 3-A Standard 74)	
Polishing		
6 Electropolishing		
Typical model number: 1199 W NC 1 0 S SSW A 0 AA L 2		

1. Ethylene Propylene O-ring (conforms to 3-A standard 74 and USP Class VI) and clamp are supplied with the SSW Seal.

- 2. Diaphragm brazed and TIG-welded to extension.
- 3. Requires Option code 6, Electropolishing.

#### Figure 2. Sanitary Tank Spud Accessories

# Tank spud and clamp

# Rosemount 3051S with direct mount sanitary tank spud with clamp







Dimensions are in inches (millimeters).



Tank spud plug



### Table 31. Sanitary Tank Spud Optional Accessories⁽¹⁾

Model	Description
01199-0061-0001	2-in. SST sanitary tank spud
01199-0061-0002	6-in. SST sanitary tank spud

1. Welding procedures and material certifications are shipped with the tank spud. Standard material is cast equivalent of 316L SST per ASTM- A351 grade CF3M.

#### Table 32. Sanitary Tank Spud Spare Parts

Part number	Description
01199-0526-0002	Clamp
C53185-0070-0341	Ethylene propylene O-ring



# STW hygienic thin wall tank spud seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

### Table 33. STW Hygienic Thin Wall Tank Spud Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard			
S	Hygienic seal (conforms to 3-A Standard 74-06)			
Process connection style ⁽¹⁾				
STW	Thin wall tank spud seal			
Process connection size, pressure rating				
B0	4-in. Tri-Clamp, 600 psi (41 bar)			
Diaphragm and wetted, extension material				
	Diaphragm and wetted Extension			
LA00	316L SST	316L SST		
BB00	Alloy C-276	Alloy C-276		

#### **Options** (include with selected model number)

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Surface finish		
G ⁽²⁾	15 μin. (0.375 μm) diaphragm surface finish	
Н	20 μin.(0.5 μm) diaphragm surface finish	
Non-hygienic fill fluid		
Р	Non-hygienic fill fluid (does not conform to 3-A Standard 74)	
Polishing		
6	Electropolishing	
Typical model number: 1199 W NC 1 0 S STW B 0 LA 0 0		

1. For tank walls up to ³/16-in. thick. Ethylene Propylene O-ring (conforms to 3-A standard 74 and USP Class VI) and clamp are supplied with the STW Seal.

2. Requires Option code 6, Electropolishing.



# EES hygienic flanged tank spud extended seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

#### Table 34. EES Hygienic Flanged Tank Spud Extended Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard			
S	Hygienic seal (conforms to 3-A Standard 74-06)			
Process c	onnection style			
EES	Flanged tank spud seal			
Process connection size, pressure rating				
GG	DN 50, PN 40			
JG	DN 80, PN 40			
Diaphragm and wetted, extension material				
	Diaphragm and wetted Extension			
LA	316L SST	316L SST		
LB	Alloy C-276 316L SST			
Extension length ⁽¹⁾				
10	25 mm (1-in.)			

# **Options** (include with selected model number)

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Surface fi	nish	
G ⁽²⁾	15 μin. (0.375 μm) R _a surface finish	
Н	20 μin. (0.50 μm) R _a surface finish	
Gasket material		
1	Fluorocarbon (FMK) O-ring, instead of Standard Ethylene Propylene O-ring (conforms to 3-A Standard 74).	
Non-hygienic fill fluids		
Р	Non-hygienic fill fluid (does not conform to 3-a standard 74)	
Cold temperature application		
В	Extra fill for cold temperature application	
Polishing		
6	Electropolishing	
Typical model number: 1199 W NC 1 0 S EES J G LA 1 0		

1. Other extension lengths are available upon request.

2. Requires Option code 6, Electropolishing.



# VCS Tri-Clamp in-line seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

### Table 35. VCS Tri-Clamp In-Line Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard		
S	Hygienic seal (conforms to 3-A Standard 74-06 and EHEDG Type EL Class I)		
Process o	connection style		
VCS ⁽¹⁾	In-line tri-clover style Tri-Clamp seal		
Process o	Process connection size		
20 ⁽²⁾	1-in.		
30 ⁽³⁾	1¹/₂-in.		
50	2-in.		
70	3-in.		
90	4-in.		
Diaphragm and wetted, upper housing material			
	Diaphragm and wetted Upper housing		
LA00	316L SST	316L SST	

## **Options** (include with selected model number)

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Surface finish		
G ⁽⁴⁾	15 μ-in. (0.375 μm) Ra surface finish	
Н	20 μ-in. (0.50 μm) Ra surface finish	
Non-hygienic fill fluid		
Р	Non-hygienic fill fluid (does not conform to 3-A Standard 74)	
Polishing		
6	Electropolishing	
Typical model number: 1199 W NC 1 0 S VCS 7 0 LA 0 0		

1. Clamp and gasket to be furnished by user. Ensure to use EHEDG approved gasket if EHEDG conformity is needed. The MWP is dependent upon the clamp pressure rating.

2. Consult factory for calibrated spans lower than 15 psi (1034 mbar).

3. Consult factory for calibrated spans lower than 5 psi (345 mbar).

4. Requires Option code 6, Electropolishing.



# SVS VARIVENT compatible hygienic connection seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

#### Table 36. SVS VARIVENT Compatible Hygienic Connection Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard		
S	Hygienic seal (conforms to 3-A Standard 74-06 and EHEDG Type EL Class I)		
Process	Process connection style		
SVS ⁽¹⁾	Tuchenhagen VARIVENT Compatible Seal		
Process	Process connection size ⁽²⁾		
V0	VARIVENT Type N DN 40-125.		
Diaphragm and wetted, upper housing material			
	Diaphragm and wetted	Upper housing	
LA00	316L SST	316L SST	

# **Options** (include with selected model number)

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Non-hygienic fill fluid		
Р	Non-hygienic fill fluid (does not conform to 3-A Standard 74)	
Cold temperature application		
В	Extra fill for cold temperature application	
Polishing		
6	Electropolishing	
Typical model number: 1199 W NC 1 0 S SVS V 0 LA 0 0		

1. Gasket to be furnished by user. Ensure to use EHEDG approved gasket if EHEDG conformity is needed. The MWP is dependent upon the clamp pressure rating.

2. Consult factory for calibrated spans lower than 5,4 psi (373 mbar).



# SHP hygienic Cherry-Burrell "I" line seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

#### Table 37. SHP Hygienic Cherry-Burrell "I" Line Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard		
S	Hygienic seal (conforms to 3-A Standard 74-06)		
Process cor	Process connection style ⁽¹⁾		
SHP	Cherry-Burrell "I" line style seal		
Process connection size			
50 ⁽²⁾	2-in.		
70	3-in.		
Diaphragm and wetted, upper housing material			
	Diaphragm and wetted	Upper housing	
AA00	316L SST	316L SST	

# **Options** (include with selected model number)

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	
Non-hygienic fill fluid		
Р	Non-Hygienic fill fluid (does not conform to 3-A Standard 74)	
Typical model number: 1199 W NC 1 0 S SHP 7 0 AA 0 0		

1. Clamp and gasket furnished by user. MWP is the lesser of either clamp pressure rating or 500 psi.

2. Consult factory for calibrated spans lower than 5 psi (345 mbar).



# SLS dairy process connection - female thread seal per DIN 11851

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

#### Table 38. SLS Hygienic Dairy Process Connection Female Thread Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard	
S	Hygienic seal (conforms to 3-A Standard 74-06 and EHEDG Type EL Class I)	
Process connection style		
SLS ⁽¹⁾	Dairy process connection - female thread	
Process connection size, pressure rating, material		
F0 ⁽²⁾	DIN 11851 with coupling nut DN 40, PN 40, 304 SST	
G0 ⁽³⁾	DIN 11851 with coupling nut DN 50, PN 25, 304 SST	
Diaphragm and wetted, upper housing material		
	Diaphragm and wetted	Upper housing
LA00	316L SST	316L SST

# **Options** (include with selected model number)

Extended product warranty	
WR3	3-year limited warranty
WR5	5-year limited warranty
Polishing	
6	Electropolishing
Non-hygienic fill fluids	
Р	Non-hygienic fill fluid (does not conform to 3-A Standard 74)
Typical model number: 1199 W HC 1 0 S SLS J 0 LA 0 0	

1. Gasket to be furnished by user. Ensure to use EHEDG approved gasket if EHEDG conformity is needed.

2. Consult factory for calibrated spans lower than 15 psi (1034 mbar).

3. Consult factory for calibrated spans lower than 5 psi (345 mbar).

# **Specialty seals**



# WSP saddle seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

#### Table 39. WSP Saddle Seal Ordering Information

This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard	
N	Non-industry standard	
Process co	nnection style	
WSP	Saddle seal	
Process co	nnection size	
G	2-in. pipe size	
7	3-in. pipe size	
9	4-in. or larger pipe size	
Pressure ra	ating	
1	1500 psig at 100 °F (103 bar at 38 °C); eight bolt holes	
0	1250 psig at 100 °F (86 bar at 38 °C); six bolt holes	
Diaphragm, upper housing material		
	Diaphragm	Upper housing
LA	316L SST	316L SST
LB	Alloy C-276	316L SST
LC	Tantalum	316L SST
L5	Duplex 2507 SST	316 SST
Lower housing material ⁽¹⁾⁽²⁾		
00	None	
L5	316L SST	
B5	Alloy C-276	
D5	Plated carbon steel	

# **Options** (include with selected model number)

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	

### Table 39. WSP Saddle Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Intermediate gasket material			
Y	C-4401 gasket		
J	PTFE gasket		
Ν	GRAFOIL gasket		
NACE certi	NACE certificate ⁽³⁾		
Q15	Certificate of compliance to NACE MR0175/ISO 15156 for wetted materials	*	
Q25	Certificate of compliance to NACE MR0103 for wetted materials	*	
Diaphragm coating			
V	PTFE coated diaphragm for nonstick purposes (316L SST and Alloy C-276 diaphragms only)		
Typical model number: 1199 W DC 1 0 N WSP 7 1 LA L N			

1. Standard pipe schedule 40/40S, for other pipe schedules consult the factory.

2. Supplied with C-4401 Aramid fiber gasket if no gasket option is selected.

3. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.



# UCP male threaded pipe mount seals and PMW paper mill sleeve

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

# Table 40. UCP and PMW Threaded Pipe Mount Seal Ordering Information This seal is part of the Expanded offering and is subject to additional delivery lead time.

Industry standard				
N	Non-industry standard			
Process con	Process connection style			
UCP	Male threaded pipe mount seal	Male threaded pipe mount seal		
PMW	Paper mill sleeve			
Process con	Process connection size, pressure rating			
30(1)	1 ¹ /2-in., threaded knurled nut, 600 psi at 100 °F (41 bar at 38 °C) (UCP only)			
50 ⁽²⁾	1-in., cap screw retainer, 300 psi at 100 °F (21 bar at 38 °C) (PMW only)			
Diaphragm	and wetted, upper housing material			
	Diaphragm and wetted	Upper housing		
AA	316L SST	316L SST		
BB	Alloy C-276	Alloy C-276		
Lower housing material				
00	None			
A0	316L SST			
B0	Alloy C-276			

# **Options** (include with selected model number)

Extended product warranty	
WR3	3-year limited warranty
WR5	5-year limited warranty
Diaphragm coating	
V	PTFE coated diaphragm for nonstick purposes only
Typical model number: 1199 W DC 1 0 N UCP 3 0 AA A 0	

1. Only available with UCP process connection size. Consult factory for calibrated spans lower than 50 psi (3,4 bar).

2. Only available with PMW process connection size. Consult factory for calibrated spans lower than 100 psi (6,9 bar).



# **CTW chemical tee seal**

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

## Table 41. CTW Chemical Tee Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard		
N	Non-industry standard		
Process co	nnection style		
CTW	Chemical tee seal		
MWP (flan	ge rating)		
20	300 psi (21 bar)		
Diaphragm	Diaphragm and wetted, upper housing material		
	Diaphragm and wetted	Upper housing	
AA	316L SST	316L SST	
BB	Alloy C-276	Alloy C-276	
Lower housing			
00	None		
<b>Options</b> (include with selected model number)			

Extended product warranty		
WR3	3-year limited warranty	
WR5	5-year limited warranty	
NACE certi	ficate ⁽¹⁾	
Q15	Certificate of compliance to NACE MR0175/ISO 15156 for wetted materials	*
Q25	Certificate of compliance to NACE MR0103 for wetted materials	*
Diaphragm coating		
V	PTFE coated diaphragm for nonstick purposes only	
Typical mo	del number: 1199 W NC 1 0 N CTW 2 0 AA 0 0	

1. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.



# TFS wafer style in-line seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

#### Table 42. TFS Wafer Style In-Line Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard	
А	ANSI/ASME B16.5 (American National Standards Institute/American Society of Mechanical Engineers)	
D	EN 1092-1 (European Standard)	
Process o	connection style	
TFS	Wafer style in-line seal	
Process o	connection size	
	ANSI/ASME B16.5	EN 1092-1
G	2-in.	DN 50
7	3-in.	N/A
J	N/A	DN 80
9	4-in.	N/A
2 ⁽¹⁾	1-in.	N/A
4 ⁽²⁾	1 ¹ /2-in.	N/A
D ⁽¹⁾	N/A	DN 25
F ⁽²⁾	N/A	DN 40
К	N/A	DN 100
Pressure	rating	
0	Seal MWP based on customer supplied flange	
Diaphrag	ım and wetted, upper housing material	
	Diaphragm and wetted	Upper housing
LA	316L SST	316L SST
LB	Alloy C-276	316L SST
Housing	body length	
00	3.54-in. (90 mm)	

# **Options** (include with selected model number)

Extended product warranty	
WR3	3-year limited warranty
WR5	5-year limited warranty
Typical model number: 1199 W DC 1 0 A TFS 7 0 LA 0 0	

1. Consult factory for calibrated spans lower than 15 psi (1034 mbar).

2. Consult factory for calibrated spans lower than 5 psi (345 mbar).



# WFW flow-thru flanged seal

Specification and selection of product materials, options, or components must be made by the purchaser of the equipment. See page 136 for more information on material selection.

## Table 43. WFW Flow-Thru Flanged Seal Ordering Information

This seal is part of the Expanded offering and is subject to additional delivery lead time.

Code	Industry standard		
А	ANSI/ASME B16.5 (American National Standards Institute/American Society of Mechanical Engineers)		
Process	connection style ⁽¹⁾		
WFW	Flow-thru flanged seal		
Process	s connection size ⁽²⁾		
G	2-in.		
7	3-in.		
2	1-in.		
Flange	rating ⁽²⁾		
1	Class 150		
Diaphra	agm, upper housing material		
	Diaphragm	Upper housing ⁽²⁾	
LA	316L SST	316L SST	
LB	Alloy C-276	316L SST	
LC	Tantalum	316L SST	
Lower housing material ⁽¹⁾			
L	316L SST		
Pipe schedule ⁽²⁾			
Ν	40/405		

# **Options** (include with selected model number)

Extended product warranty	
WR3	3-year limited warranty
WR5	5-year limited warranty
Gasket material	
Y	C-4401 gasket
J	PTFE O-ring
К	Barium sulfate filled PTFE gasket
Ν	GRAFOIL gasket
R	Ethylene propylene gasket

#### Table 43. WFW Flow-Thru Flanged Seal Ordering Information

#### This seal is part of the Expanded offering and is subject to additional delivery lead time.

Bolt material	
3	304 SST bolts
NACE certificate ⁽³⁾	
Q15	Certificate of compliance to NACE MR0175/ISO 15156 for wetted materials
Q25	Certificate of compliance to NACE MR0103 for wetted materials
Cold temperature application	
В	Extra fill for cold temperature application
Typical model number: 1199 W DC 1 0 A WFW 7 1 LA L N	

1. Supplied with C-4401 Aramid fiber gasket if no other gasket option is selected.

2. Consult factory for special process connection sizes, flange pressure ratings, diaphragm/lower housing materials, and pipe schedules.

3. Materials of Construction comply with metallurgical requirements highlighted within NACE MR 0175/ISO 15156 for sour oil field production environments. Environmental limits apply to certain materials. Consult latest standard for details. Selected materials also conform to NACE MR 0103 for sour refining environments.

# **Specifications**

# Liquid level transmitter specifications

# **Performance specifications**

For zero-based spans, reference conditions, silicone oil fill, glass-filled PTFE O-rings, SST materials, coplanar flange (Rosemount 3051SMV, 3051S_C) or 1/2–14 NPT (Rosemount 3051S_T) process connections, digital trim values set to equal range points.

#### Conformance to specification (±3 $\sigma$ [Sigma])

Technology leadership, advanced manufacturing techniques, and statistical process control ensure measurement specification conformance to  $\pm 3\sigma$  or better.

#### Reference accuracy⁽¹⁾

Stated reference accuracy equations include terminal based linearity, hysteresis, and repeatability, but does not include analog output reference accuracy of  $\pm 0.005\%$  of span.

Stated reference accuracy equations include terminal based linearity, hysteresis, and repeatability, but does not include analog only reference accuracy of ±0.005% of span.

Sensor type	3051SAMG2, 3051SALG2 250 inH ₂ O (622,1 mbar)	3051SAMG3, 3051SALG3 1000 inH ₂ O (2488,4 mbar)	3051SAMT1, 3051SALT1 30 psi (2,1 bar)	3051SAM_ _T2, 3051SAL_ _T2 150 psi (10,34 bar)	3051SAM_ _G4, 3051SAL_ _G4 300 psi (20,7 bar)	3051SAM_ _T3, 3051SAL_ _T3 800 psi (41,4 bar)
Rosemount 3051SAM ⁽²⁾	0.2 inH ₂ O (0,5 mbar)	0.9 inH ₂ O (2,2 mbar)	0.6 inH ₂ O (1,4 mbar)	1.5 inH ₂ O (4,0 mbar)	6.2 inH ₂ O (15 mbar)	7.8 inH ₂ O (19 mbar)
Rosemount 3051SAL with direct mount seal types and sizes below ⁽³⁾ : • FF, FC, PF $\ge$ 2-in./DN50 • EF $\ge$ 3-in./DN80 • All RT, RE, RC, SS	2.2 inH ₂ O (5,5 mbar)	3.0 inH ₂ O (7,5 mbar)	2.3 inH ₂ O (6,0 mbar)	3.2 inH ₂ O (8,0 mbar)	6.5 inH ₂ O (16 mbar)	8.3 inH ₂ O (21 mbar)
• SC≥ 2.5-in.						
Rosemount 3051SAL with other seal types and sizes	Consult Instrument	Toolkit [™] for perform	iance.	•	·	•

## DP total accuracy for Enhanced ERS System performance⁽¹⁾

1. Includes full ambient and temperature range from -40 to 85 °C (-40 to 185 °F) requires two transmitters with identical sensor ranges. Specification are only applicable for spans down to 10:1.

2. For Rosemount 3051SAM assembled to a Rosemount 1199 Diaphragm Seal, use Rosemount 3051SAL specification for identical seal types and sizes.

3. For Rosemount 3051SAL with direct mount seals, specification applies to process temperatures from -45 to 205 °C and excludes diaphragm option code SC, 6-mil diaphragm thickness.

#### For FOUNDATION Fieldbus and wireless devices, use calibrated range in place of span.

	Ultra	Classic	
3051SAM ⁽¹⁾⁽²⁾	±0.025% of Span For spans less than 10:1, ±(0.005% URL + 0.015% span)	±0.035% of Span. For spans less than 10:1, ±(0.005% URL + 0.015% span)	
±0.055% of Span.         ±0.065% of Span.           3051SAL_C         For spans less than 10:1, ±(0.005% URL + 0.015% span)         For spans less than ±(0.005% URL + 0.015% span)		±0.065% of Span. For spans less than 10:1, ±(0.005% URL + 0.015% span)	
3051SMV assembled to 1199 (Code B11)	+0.065% span N/A For spans less than 10:1, +/-(0.005% URL + 0.015% span)		
3051L 3051C or 3051T assembled to 1199 (code S1)	±0.075% of Span. For spans less than 10:1, ±(0.005% URL + 0.025% span)		
2051L 2051C or 2051T assembled to 1199 (code S1)	±0.075% of Span. For spans less than 10:1, ±(0.005% URL + 0.025% span)		

1. Stated reference accuracy equations include terminal based linearity, hysteresis, and repeatability, but does not include analog only reference accuracy of ±0.005% of span.

2. For the Rosemount 3051SAM with 1199 assemble to code B11, use 3051SAL_C specifications.

#### DP Reference Accuracy of Rosemount 3051S ERS System

Two coplanar gage sensors (Rosemount 3051SAMG)	Ultra	Classic	
Ranges 2–4	±0.035% of DP span	±0.049% of DP span	
Range 5	±0.071% of DP span	±0.092% of DP span	
Two coplanar (Rosemount 3051SAMA)			
Ranges 1–4	±0.035% of DP span	±0.049% of DP span	
Two in-line gage sensors (Rosemount 3051SAMT) Two in-line absolute sensors (Rosemount 3051SAME)			
Ranges 1–4	±0.035% of DP span	±0.049% of DP span	
Two liquid level sensors (Rosemount 3051SAL)			
Ranges 1–5	±0.092% of DP span	±0.092% of DP span	

#### Warranty⁽¹⁾

Models ⁽¹⁾	Ultra/Enhanced	Classic
Rosemount 3051SAM	15-year limited warranty ⁽²⁾	1-year limited warranty ⁽³⁾

1. Warranty details can be found in Emerson Terms and Conditions of Sale, Document 63445, Rev G (10/06).

2. Rosemount Ultra transmitter has a limited warranty of fifteen (15) years from date of shipment. All other provisions of Emerson standard limited warranty remains the same.

3. Goods are warranted for twelve (12) months from the date of initial installation or eighteen (18) months from the date of shipment by seller, whichever period expires first.

# Dynamic performance

# **Rosemount Level Transmitters**

Rosemount 3051SAL_C, 3051L, and 2051L models - have an 4–20 mA HART (1–5 Vdc HART Low Power) update rate of 22 updates per second.

#### **ERS Systems**

Rosemount 3051SAM, 3051SAL_P, and 3051SAL_S models - have an 4–20 mA HART (1–5 Vdc HART Low Power) update rate of 11 updates per second. See page 93 for *Wireless*HART update rates.

For total response time, see Instrument Toolkit.

#### Ambient temperature effect

See Instrument Toolkit.

#### **Mounting position effects**

With liquid level remote mount seal in vertical plane, zero shift of up to  $\pm 1$  inH₂O (2,49 mbar); with remote mount seal in horizontal plane, zero shift of up to  $\pm 5$  inH₂O (12,45 mbar) plus extension length on extended units; all zero shifts can be zeroed; no span effect.

#### Vibration effect

	Less than $\pm 0.1\%$ of URL when tested per the requirements of IEC60770-1 field or pipeline with high vibration level (10–60 Hz 0.21mm
Pocomount	displacement peak amplitude/60–2000 Hz 3g).
20E1CAM	For Llouring Stude codes 11 11/ 11 - 21 and 2M
30513AIVI	FOLHOUSING SLYTE COURS 1J, TK, TL, ZJ, did ZW.
SUSTSAL	requirements of IEC60770-1 field with general
	application or pipeline with low vibration level
	(10-60  Hz 0.15  mm displacement peak)
	amplitude/60–500 Hz 2g).
	Measurement effect due to vibrations is
	negligible except at resonance frequencies.
Rosemount	When at resonance frequencies, vibration
3051L	effect is less than $\pm 0.1\%$ of URL per g when
	tested between 15 and 2000 Hz in any axis
	relative to pipe-mounted process conditions.
	Less than ±0.1% of URL when tested per the
Rosemount	requirements of IEC60770-1 field or pipeline
20511	with high vibration level (10–60 Hz 0.21 mm
	displacement peak amplitude/60–2000 Hz 3
	g).

#### Power supply effect

Less than  $\pm 0.005$  percent of calibrated span per volt.

## Electromagnetic Compatibility (EMC)

Meets all relevant requirements of EN 61326 and NAMUR NE-21. $^{(1)}$ 

Transien	Transient protection (option T1)						
Rosem 30515/ 30515/	ount AM AL	eets IEEE C62.41.2-2002, Location Category B $V$ crest (0.5 $\mu$ s-100 kHz) A crest (8 × 20 microseconds) V crest (1.2× 50 microseconds) eets IEEE C62.41, Category B $V$ crest (0.5 $\mu$ s-100 kHz) V crest (8 × 20 microseconds) V crest (1.2 × 50 microseconds)					
Rosem 3051L	ount	Weets IEEE C62.41.2-2002, Location Category B 5 kV crest (0.5 $\mu$ s-100 kHz) 3 kA crest (8 × 20 microseconds) 5 kV crest (1.2× 50 microseconds) Meets IEEE C62.41, Category B 6 kV crest (0.5 $\mu$ s-100 kHz) 3 kV crest (8 × 20 microseconds) 6 kV crest (1.2 × 50 microseconds) Meets IEEE C62.41, Location Category B 6 kV crest (0.5 $\mu$ s-100 kHz) 3 kV crest (8 × 20 microseconds) 6 kV crest (8 × 20 microseconds) 6 kV crest (8 × 20 microseconds) 6 kV crest (1.2 × 50 microseconds)					
Rosem 2051L	ount	$\begin{array}{l} \mbox{Meets IEEE C62.41, Location Category B} \\ \mbox{6 kV crest (0.5 $\mu s$-100 kHz)} \\ \mbox{3 kV crest (8 $\times$ 20 microseconds)} \\ \mbox{6 kV crest (1.2 $\times$ 50 microseconds)} \end{array}$					

^{1.} NAMUR NE-21 does not apply to wireless output code X or ERS configurations.

# **Functional specifications**

## **Range and sensor Limits**

#### Table 44. Rosemount 3051SAM__G, 3051SAL__D, 3051SAL__G Range and Sensor Limits

Range	Minimum span		Range limits			
	1114			Lower (LRL)		
			Opper (OKL)	3051SAL_G ⁽¹⁾⁽²⁾	3051SAL_D ⁽¹⁾	
2	1.3 inH ₂ O	2.5 inH ₂ O	250.0 inH ₂ O	–250.0 inH ₂ O	–250.0 inH ₂ O	
	(3,11 mbar)	(6,23 mbar)	(0,62 bar)	(–0,62 bar)	(–0,62 bar)	
3	5.0 inH ₂ O	10.0 inH ₂ O	1000.0 inH ₂ O	–393.0 inH ₂ O	–1000.0 inH ₂ O	
	(12,4 mbar)	(24,9 mbar)	(2,49 bar)	(–979 mbar)	(–2,49 bar)	
4	1.5 psi	3.0 psi	300.0 psi	–14.2 psig	–300.0 psi	
	(103,4 mbar)	(206,8 mbar)	(20,7 bar)	(–979 mbar)	–20,7 bar)	
5	10.0 psi	20.0 psi	2000.0 psi	–14.2 psig	–2000.0 psi	
	(689,5 mbar)	(1,38 bar)	(137,9 bar)	(–979 mbar)	(–137,9 bar)	

1. When specifying a Rosemount 3051SAL Ultra, use Classic minimum span. Minimum span limits may also be limited by the remote seal that is specified with the system.

2. Assumes atmospheric pressure of 14.7 psig (1 bar).

#### Table 45. Rosemount 3051SAM__A, 3051SAL__A Range and Sensor Limits⁽¹⁾

Range	Minimu	ım span	Range and sensor limits		
	Ultra	Classic	Upper (URL)	Lower (LRL)	
1	0.3 psia (20,7 mbar)	0.3 psia (20,7 mbar) 0.3 psia (20,7 mbar)		0 psia (0 bar)	
2	0.75 psia (51,7 mbar) 1.5 psia (0,103 bar)		150 psia (10,34 bar)	0 psia (0 bar)	
3	4 psia (275,8 mbar) 8 psia (0,55 bar)		800 psia (55,16 bar)	0 psia (0 bar)	
4	20 psia (1,38 bar)	40 psia (2,76 bar)	4000 psia (275,8 bar)	0 psia (0 bar)	

1. When specifying a Rosemount 3051SAL Ultra, use Classic minimum span. Minimum span limits may also be limited by the remote seal that is specified with the system.

#### Table 46. Rosemount 3051SAM__T, 3051SAM__E, 3051SAL__T, 3051SAL__E Range and Sensor Limits

Range	Minimum span		Range and sensor limits			
	Ultra	Classic	Upper (URL)	Lower (LRL) (Abs.)	Lower ⁽¹⁾ (LRL) (Gage)	
1	0.3 psi (20,7 mbar)	0.3 psi (20,7 mbar)	30 psi (2,07 bar)	0 psia (0 bar)	–14.7 psig (–1,01 bar)	
2	0.75 psi (51,7 mbar)	1.5 psi (0,103 bar)	150 psi (10,34 bar)	0 psia (0 bar)	–14.7 psig (–1,01 bar)	
3	4 psi (275,8 mbar)	8 psi (0,55 bar)	800 psi (55,16 bar)	0 psia (0 bar)	–14.7 psig (–1,01 bar)	
4	20 psi (1,38 bar)	40 psi (2,76 bar)	4000 psi (275,8 bar)	0 psia (0 bar)	–14.7 psig (–1,01 bar)	
5	1000 psi (68,9 bar)	2000 psi (137,9 bar)	10000 psi (689,5 bar)	0 psia (0 bar)	–14.7 psig (–1,01 bar)	

1. Assumes atmospheric pressure of 14.7 psig (1 bar).

		Range and sensor limits				
Range	Minimum span		Lower (LRL)			
		Upper (URL)	Rosemount 3051L Differential	Rosemount 3051L Gage ⁽¹⁾		
2	2.5 inH ₂ O (6,2 mbar)	250 inH ₂ O (0,62 bar)	–250 inH ₂ O (–0,62 bar)	–250 inH ₂ O (–0,62 bar)		
3	10 inH ₂ O (24,9 mbar)	0 inH ₂ O (24,9 mbar) 1000 inH ₂ O (2,49 bar)		-393 inH ₂ O (-979 mbar)		
4	3 psi (0,20 bar)	300 psi (20,6 bar)	–300 psi (–20,6 bar)	-14.2 psig (979 mbar)		
5	20 psi (1,38 bar)	2000 psi (137,9 bar)	N/A	N/A		

1. Assumes atmospheric pressure of 14.7 psig.

#### Table 48. 2051L Range and Sensor Limits

		Range and sensor limits				
Range	Minimum span		Lower (LRL)			
		Upper (URL)	Rosemount 2051L Differential	Rosemount 2051L Gage ⁽¹⁾		
2	2.5 inH ₂ O (6,2 mbar)	250 inH ₂ O (0,62 bar)	–250 inH ₂ O (–0,62 bar)	–250 inH ₂ O (–0,62 bar)		
3	10 inH ₂ O (24,9 mbar)	inH ₂ O (24,9 mbar) 1000 inH ₂ O (2,49 bar)		–393 inH ₂ O (–979 mbar)		
4	3 psi (0,207 bar)	300 psi (20,6 bar)	–300 psi (–20,7 bar)	–14.2 psig (–979 mbar)		

1. Assumes atmospheric pressure of 14.7 psig.

## Service

Liquid, gas, and vapor applications

## Protocols

## 4–20 mA (output code A)

#### Output

Two-wire 4–20 mA, user-selectable for linear or square root output. Digital process variable superimposed on 4–20 mA signal, available to any host that conforms to the HART protocol.

#### **Power supply**

External power supply required. Standard transmitter (4–20 mA) operates on 10.5 to 42.4 Vdc with no load. The Rosemount 3051S ERS System operates on 16 to 42.4 Vdc with no load.

#### Load limitations

Maximum loop resistance is determined by the voltage level of the external power supplied as described by:

## Figure 3. Standard HART Transmitter

Maximum Loop Resistance = 43.5 * (Power supply voltage – 10.5)



The Field Communicator requires a minimum loop resistance of  $250 \Omega$  for communication.

#### Figure 4. Rosemount 3051S ERS System

If supply voltage  $\leq$  16.74 Vdc: Maximum Loop Resistance = 277 * (Power supply voltage – 16.0)

If supply voltage > 16.74 Vdc: Maximum Loop Resistance = 43.5 * (Power supply voltage – 12.0)



The Field Communicator requires a minimum loop resistance of  $250 \Omega$  for communication.

#### FOUNDATION Fieldbus (output code F)

#### **Power supply**

External power supply required; transmitters operate on 9.0 to 32.0 Vdc transmitter terminal voltage.

#### **Current draw**

17.5 mA for all configurations (including LCD display option)

#### Indication

Optional two-line LCD display

#### FOUNDATION Fieldbus Function Block Execution Times

Diada	Execution time (milliseconds)					
DIOCK	3051SAL_C	3051L	2051L			
Resource	N/A	N/A	N/A			
Transducer	N/A	N/A	N/A			
LCD Block	N/A	N/A	N/A			
Analog Input 1, 2	20	30	35			
PID	35 ⁽¹⁾	45	45			
Input Selector	20	30	30			
Arithmetic	20	35	35			
Signal Characterizer	20	40	40			
Integrator	20	35	35			
Output Splitter	20	N/A	N/A			
Control Selector	20	N/A	N/A			

1. PID with Auto-tune.

#### FOUNDATION Fieldbus Parameters

Schedule Entries	7 (max.)
Links	20 (max.)
Virtual Communications Relationships (VCR)	12 (max.)

#### Standard function blocks

#### **Resource block**

Contains hardware, electronics, and diagnostic information.

#### Transducer block

Contains actual sensor measurement data including the sensor diagnostics and the ability to trim the pressure sensor or recall factory defaults.

#### LCD block

Configures the local display.

#### Two analog input blocks

Processes the measurements for input into other function blocks. The output value is in engineering units or custom and contains a status indicating measurement quality.

#### PID block

Contains all logic to perform PID control in the field including cascade and feedforward.

#### Backup Link Active Scheduler (LAS)

The transmitter can function as a Link Active Scheduler if the current link master device fails or is removed from the segment.

#### Advanced control function block suite (option code A01)

#### Input selector block

Selects between inputs and generates an output using specific selection strategies such as minimum, maximum, midpoint, average, or first "good."

#### **Arithmetic block**

Provides pre-defined application-based equations including flow with partial density compensation, electronic remote seals, hydrostatic tank gauging, ratio control, and others.

#### Signal characterizer block

Characterizes or approximates any function that defines an input/output relationship by configuring up to twenty X, Y coordinates. The block interpolates an output value for a given input value using the curve defined by the configured coordinates.

#### Integrator block

Compares the integrated or accumulated value from one or two variables to pre-trip and trip limits and generates discrete output signals when the limits are reached. This block is useful for calculating total flow, total mass, or volume over time.

#### FOUNDATION Fieldbus diagnostics suite (option code D01)

The FOUNDATION Fieldbus Diagnostics provide Abnormal Situation Prevention (ASP) indication. The integral statistical process monitoring (SPM) technology calculates the mean and standard deviation of the process variable 22 times per second. The Rosemount 3051S_L and 3051L use these values and highly flexible configuration options for customization to detect many user-defined or application specific abnormal situations (e.g. detecting plugged impulse lines and fluid composition change).

#### PROFIBUS PA (output code W)

#### **Profile version**

3.02

#### Power supply

External power supply required; transmitters operate on 9.0 to 32.0 Vdc transmitter terminal voltage.

#### **Current draw**

17.5 mA for all configurations (including LCD display option)

#### Output update rate

Four times per second.

#### Standard function blocks

#### Analog input (AI block)

The AI function block processes the measurements and makes them available to the host device. The output value from the AI block is in engineering units and contains a status indicating the quality of the measurement.

#### **Physical block**

The physical block defines the physical resources of the device including type of memory, hardware, electronics, and diagnostic information.

#### Transducer block

Contains actual sensor measurement data including the sensor diagnostics and the ability to trim the pressure sensor or recall factory defaults.

#### Indication

Optional two-line LCD display

#### Local operator interface

Optional external configuration buttons

#### Rosemount 3051SAL_C Wireless self-organizing networks

#### Output

IEC 62591 (WirelessHART), 2.4 GHz DSSS

#### Radio frequency power output from antenna

External Antenna (WK option): Maximum of 10 mW (10 dBm) EIRP Extended Range, External Antenna (WM option): Maximum of 18 mW (12.5 dBm) EIRP High-Gain, Remote Antenna (WN option): Maximum of 40 mW (16 dBm) EIRP

#### Local display

The optional seven-digit LCD display can display primary variable in engineering units, percent of range, sensor module temperature, and electronics temperature. Display updates at update rate up to once per minute. The display updates based on the wireless update rate.

#### Update rate

User selectable 1 second to 60 minutes.

#### Power module

Field replaceable, keyed connection eliminates the risk of incorrect installation, Intrinsically Safe Lithium-thionyl chloride Power Module with polybutadine terephthalate (PBT) enclosure. Ten-year life at one minute update rate.⁽¹⁾

1. Reference conditions are 70 °F (21 °C), and routing data for three additional network devices.

#### Note

Continuous exposure to ambient temperature limits of -40 °F or 185 °F (-40 °C or 85 °C) may reduce specified life by less than 20 percent.

#### **Overpressure limits**

Limit is 0 psia to the flange rating or sensor rating, whichever is lower.

#### Table 49. Rosemount 3051L, 2051L and Level Flange Rating Limits

Standard	Туре	CS Rating	SST Rating				
ANSI/ASME	Class 150	285 psig	275 psig				
ANSI/ASME	Class 300	740 psig	720 psig				
ANSI/ASME	1480 psig	1440 psig					
At 100 °F (38 °C), the rating decreases with increasing temperature, per ANSI/ASME B16.5.							
DIN	PN 10-40	40 bar	40 bar				
DIN	PN 10/16	16 bar	16 bar				
DIN	PN 25/40	40 bar	40 bar				
At 122 °F (50 °C) the rating decreases with increasing							

At 122 °F (50 °C), the rating decreases with increasing temperature per EN 1092-1 Annex F.

#### **Temperature limits**

#### Ambient

-40 to 185 °F (-40 to 85 °C) With LCD display⁽¹⁾: -40 to 175 °F (-40 to 80 °C) With option code P0: -20 to 185 °F (-29 to 85 °C)

1. LCD display may not be readable and LCD display updates will be slower at temperatures below -4 °F (-20 °C).

#### Storage

–50 to 185 °F (–46 to 85 °C) With LCD display: –40 to 185 °F (–40 to 85 °C) With wireless output: –40 to 185 °F (–40 to 85 °C)

#### Table 50. Rosemount 3051SAM ERS Process temperature Limits (Gage/Absolute Sensor)

Configuration	Coplanar gage/absolute sensor (Rosemount 3051SAMG, 3051SAMA)	In-line gage sensor/absolute sensor (Rosemount 3051SAMT, 3051SAME)		
Silicone Fill Fluid ⁽¹⁾	N/A	–40 to 250 °F (–40 to 121 °C) ⁽³⁾		
with Coplanar Flange ⁽¹⁾	–40 to 250 °F (–40 to 121 °C) ⁽³⁾	N/A		
with Traditional Flange ⁽²⁾	–40 to 300 °F (–40 to 149 °C) ⁽³⁾	N/A		
with Level Flange ⁽²⁾	–40 to 300 °F (–40 to 149 °C) ⁽³⁾	N/A		
with 305 Integral Manifold ⁽¹⁾	–40 to 300 °F (–40 to 149 °C) ⁽³⁾	N/A		
Inert Fill Fluid ⁽¹⁾⁽⁴⁾	–40 to 185 °F (–40 to 85 °C) ⁽⁵⁾	–22 to 250 °F (–30 to 121 °C) ⁽³⁾		

1. Process temperatures above 185 °F (85 °C) require de-rating the ambient limits by a 1.5:1 ratio. For example, for process temperature of 195 °F (91 °C), new ambient temperature limit is equal to 170 °F (77 °C). This can be determined as follows: (195 °F – 185 °F) × 1.5 = 15 °F, 185 °F – 15 °F = 170 °F.

2. Process temperatures above 185 °F (85 °C) require de-rating the ambient limits by a 1:1 ratio.

3. 220 °F (104 °C) limit in vacuum service; 130 °F (54 °C) for pressures below 0.5 psia.

4. Not available with Rosemount 3051SAM__A.

5. 160 °F (71 °C) limit in vacuum service.

#### Table 51. Fill Fluid Specifications⁽¹⁾

Seal fill fluid		Specific Viscosity	Viscosity at	Temperature limits ⁽¹⁾ ⁽²⁾				
		gravity at 77 °F (25 °C)	77 °F (25 °C) (centistokes)	No extension	2-in. (50 mm) extension	4-in. (100 mm) extension	Thermal optimizer	Capillary
D	Silicone 200	0.934	9.5	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)	–49 to 401 °F (–45 to 205 °C)
F	Silicone 200 for Vacuum Applications	0.934	9.5	For use in vacuu	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves ir Rosemount DP Level Fill Fluid Specification <u>Technical Note</u>			
J ⁽⁵⁾	Tri-Therm 300	0.795	8.6	–40 to 401 °F (–40 to 205 °C)	-40 to 464 °F (-40 to 240 °C)	–40 to 572 °F (–40 to 300 °C)	N/A	–40 to 572 °F (–40 to 300 °C)
Q ⁽⁵⁾	Tri-Therm 300 for vacuum Applications	0.795	8.6	For use in vacuu	ım applications bel Rosemount DP Lev	ow 14.7 psia (1 bar el Fill Fluid Specifica	-a), refer to vapor p ation <u>Technical No</u> t	pressure curves in te
L	Silicone 704	1.07	39	32 to 401 °F (0 to 205 °C)	32 to 464 °F (0 to 240 °C)	32 to 572 °F (0 to 300 °C)	32 to 599 °F (0 to 315 °C)	32 to 599 °F (0 to 315 °C)
с	Silicone 704 for Vacuum Applications	1.07	39	For use in vacuum applications below 14.7 psia (1 bar-a), refer to vapor pressure curves in Rosemount DP Level Fill Fluid Specification <u>Technical Note</u>				pressure curves in te
R	Silicone 705	1.09	175	68 to 401 °F (20 to 205 °C)	68 to 464 °F (20 to 240 °C)	68 to 572 °F (20 to 300 °C)	68 to 698 °F (20 to 370 °C)	68 to 698 °F (20 to 370 °C)
v	Silicone 705 for Vacuum Applications	1.09	175	For use in vacuu	im applications bel Rosemount DP Lev	ow 14.7 psia (1 bar el Fill Fluid Specifica	-a), refer to vapor p ation <u>Technical No</u> t	pressure curves in te
Y(3)	UltraTherm 805	1.20	1000	UltraTherm 80 3051SAL Scala	5 is only available w ble Level Transmitt	vith Thermal Range ter Ordering Inform limits.	Expander. SeeTabl ation" on page 27	e 3: "Rosemount for temperature
Z ⁽³⁾	UltraTherm 805 for Vacuum Applications	1.20	1000	For use in vacuu	ım applications bel Rosemount DP Lev	ow 14.7 psia (1 bar el Fill Fluid Specifica	-a), refer to vapor p ation <u>Technical No</u> t	pressure curves in te
A	Syltherm XLT	0.85	1.6	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)	–157 to 293 °F (–105 to 145 °C)
н	Inert (Halocarbon)	1.85	6.5	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)	–49 to 320 °F (–45 to 160 °C)
G ⁽⁴⁾⁽⁵⁾	Glycerin and Water	1.13	12.5	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)
N ⁽⁵⁾	Neobee M–20	0.94	9.8	5 to 401 °F (–15 to 205 °C)	5 to 437 °F (–15 to 225 °C)	5 to 437 °F (–15 to 225 °C)	5 to 437 °F (–15 to 225 °C)	5 to 437 °F (–15 to 225 °C)
P ⁽⁴⁾⁽⁵⁾	Propylene Glycol and Water	1.02	2.85	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)	5 to 203 °F (–15 to 95 °C)

1. Temperature limits are reduced in vacuum service. For more information on Fill Fluids see Rosemount DP Level Fill Fluid Specification Technical Note.

2. Due to heat transfer to the transmitter, the maximum process temperature of the transmitter will be de-rated if ambient or process temperatures exceed 185 °F (85 °C). Consult Instrument Toolkit to verify the application.

3. Only available with Thermal Range Expander.

4. Not suitable for vacuum applications.

5. This is a food grade fill fluid.







#### **Humidity limits**

0–100 percent relative humidity

#### Turn-on time

Rosemount 3051SAL_C	Performance within specifications less than 2.0 seconds after power is applied to the transmitter.
Rosemount 3051L	Performance within specifications less than 2.0 seconds (10.0 s for PROFIBUS protocol) after power is applied to the transmitter
Rosemount 2051L	Performance within specifications less than 2.0 seconds after power is applied to the transmitter.
Rosemount ERS System	Performance within specifications less than 6.0 seconds after power is applied.

#### Volumetric displacement

Less than 0.005-in.³ (0.08 cm³)

#### Damping⁽¹⁾

Software damping is in addition to sensor module response time.

Rosemount 3051SAL_C	Analog output response to a step change is user-selectable from 0 to 60 seconds for one time constant.
Rosemount 3051L	Analog output response to a step input change is user-selectable from 0 to 36 seconds for one time constant.
Rosemount 2051L	Analog output response to a step input change is user-selectable from 0 to 25.6 seconds for one time constant.
Rosemount ER S System	The PHI and PLO pressure measurements and the DP calculation may be independently dampened from 0 to 60 seconds for one time constant.

1. Does not apply to wireless option code X.

# **Physical specifications**

#### **Material selection**

Emerson provides a variety of Rosemount products with various product options and configurations including materials of construction that can be expected to perform well in a wide range of applications. The Rosemount product information presented is intended as a guide for the purchaser to make an appropriate selection for the application. It is the purchaser's sole responsibility to make a careful analysis of all process parameters (such as all chemical components, temperature, pressure, flow rate, abrasives, contaminants, etc.), when specifying product materials, options, and components for the particular application. Emerson is not in a position to evaluate or guarantee the compatibility of the process fluid or other process parameters with the product options, configuration, or materials of construction selected.

#### **Electrical connections**

 $^{1/2-14}$  NPT, PG 13.5, G1/2, and M20  $\times$  1.5 conduit. HART interface connections fixed to terminal block.

#### Non-wetted parts

Transmitter flange is CF-3M (cast version of 316L SST, material per ASTM-A743) Capillary tube is 316L SST Capillary armor is SST or PVC coated SST

	Rosemount 3051SAL	Rosemount 3051L	Rosemount 2051L
Electrical housing	Low-copper aluminum alloy or CF-8M (Cast 316 SST) NEMA [®] 4X, IP 66, IP 68 (66 ft. [20 m] for 168 hours) ⁽¹⁾	Low-copper aluminum or CF-3M (Cast version of 316L SST, material per ASTM-A743). NEMA 4X, IP 65, IP 66	Low-copper aluminum or CF-8M (Cast version of 316 SST). Enclosure Type 4X, IP 65, IP 66, IP 68
Coplanar sensor module housing	CF-3M (Cast version of 316L SST, material per ASTM-A743)	CF-3M (Cast version of 316L SST, material per ASTM-A743)	CF-3M (Cast version of 316L SST, material per ASTM-A743)
Bolts	Plated carbon steel per ASTM A449, Type 1 Austenitic 316 SST per ASTM F593 ASTM A453, Class D, Grade 660 SST ASTM A193, Grade B7M alloy steel ASTM A193, Class 2, Grade B8M SST Alloy K–500	ASTM A449, Type 1 (zinc-cobalt plated carbon steel) ASTM F593G, Condition CW1 (Austenitic 316 SST) ASTM A193, Grade B7M (zinc plated alloy steel) Alloy K–500	ASTM A449, Type 1 (zinc-cobalt plated carbon steel) ASTM F593G, Condition CW1 (Austenitic 316 SST) ASTM A193, Grade B7M (zinc plated alloy steel)
Sensor module fill fluid	Silicone or inert halocarbon (Inert is not available with Rosemount 3051S_CA). In-Line series uses Fluorinert [™] FC-43	Silicone 200 or Fluorocarbon oil (Halocarbon or Fluorinert FC-43 for Rosemount 3051T)	Silicone 200 or Fluorocarbon oil (Halocarbon or Fluorinert FC-43 for 2051T)
Process fill fluid	Syltherm XLT, Silicone 705, Silicone 704, UltraThem 805, Silicone 200,Tri-Therm 300, inert, glycerin and water, Neobee M-20, propylene glycol and water	Syltherm XLT, Silicone 705, Silicone 704, Silicone 200, Tri-Therm 300, inert, glycerin and water, Neobee M-20, propylene glycol and water	Syltherm XLT, Silicone 705, Silicone 704, Silicone 200, Tri-Therm 300, inert, glycerin and water, Neobee M-20, propylene glycol and water
Paint for aluminum housing	Polyurethane	Polyurethane	Polyurethane
Cover O-ring	Nitrile butadiene (NBR)	Nitrile butadiene (NBR)	Nitrile butadiene (NBR)
Wireless antenna	External Antenna (WK1/WM1): PBT/ PC integrated omni-directional antenna Remote Antenna (WN1): Fiberglass omni-directional antenna	N/A	N/A
Power module	Field replaceable, keyed connection eliminates the risk of incorrect installation, Intrinsically Safe Lithium-thionyl chloride Power Module with PBT enclosure	N/A	N/A

1. IP 68 not available with Wireless Output.

#### Note

If a lower housing is supplied, the following gaskets are the default gaskets for each seal unless another gasket material is selected.

# Rosemount 3051SAL Transmitter default gasket options

Seal	Gaskets
FF	ThermoTork TN-9000 gasket
EF	No gasket is supplied
FC	No gasket is supplied
RC	Klinger C-4401 gasket
RF	Klinger C-4401 gasket
RT	Klinger C-4401 gasket
PF	ThermoTork TN-9000 gasket
SS	Ethylene Propylene O-ring

# Shipping weights

Table 52. Rosemount 3051SAL Weights without SuperModule Platform, Housing, or Transmitter Options

Flange	Flush lb (kg)	2-in. Ext. Ib (kg)	4-in. Ext. Ib (kg)	6-in. Ext. lb (kg)
2-in., 150	9.5 (4,3)	N/A	N/A	N/A
3-in., 150	15.7 (7,1)	16.4 (7,4)	17.6 (8,0)	18.9 (8,6)
4-in., 150	21.2 (9,6)	20.9 (9,5)	22.1 (10,0)	23.4 (10,6)
2-in., 300	11.3 (5,1)	N/A	N/A	N/A
3-in., 300	19.6 (8,9)	20.3 (9,2)	21.5 (9,8)	22.8 (10,3)
4-in., 300	30.4 (13,8)	30.3 (13,7)	31.5 (14,3)	32.8 (14,9)
2-in., 600	12.8 (5,8)	N/A	N/A	N/A
3-in., 600	22.1 (10,0)	22.8 (10,3)	24.0 (10,9)	25.3 (11.5)
DN 50/PN 40	11.3 (5,1)	N/A	N/A	N/A
DN 80/PN 40	16.0 (7,3)	16.7 (7,6)	17.9 (8.1)	19.2 (8,7)
DN 100/PN 10/16	11.2 (5,1)	11.9 (5,4)	13.1 (5,9)	14.4 (6,5)
DN 100/PN 40	12.6 (5,7)	13.3 (6,0)	14.5 (6,6)	15.8 (7,1)

### Table 53. Rosemount 3051SAM and 3051SAL Transmitter Option Weights

Option code	Option	Add lb (kg)
1J, 1K, 1L	SST Plantweb housing	3.5 (1,6)
2J	SST Junction box housing	3.4 (1,5)
7J	SST Quick Connect	0.4 (0,2)
2A, 2B, 2C	Aluminum junction box housing	1.1 (0,5)
1A, 1B, 1C	Aluminum Plantweb I	
M5	LCD display for aluminum Plantweb housing ⁽¹⁾ LCD display for SST Plantweb housing ⁽¹⁾ Aluminum standard cover SST standard cover Aluminum display cover SST display cover Wireless extended cover LCD display ⁽²⁾ Junction box terminal block Plantweb terminal block Power module Thermal range expander	$\begin{array}{c} 0.8 \ (0,4) \\ 1.6 \ (0,7) \\ 0.4 \ (0,2) \\ 1.3 \ (0,6) \\ 0.7 \ (0,3) \\ 1.5 \ (0,7) \\ 0.7 \ (0,3) \\ 0.1 \ (0,04) \\ 0.2 \ (0,1) \\ 0.2 \ (0,1) \\ 0.5 \ (0,2) \\ 4.1 \ (1,9) \end{array}$

1. Includes LCD display and display cover.

2. Display only.

Flange	Flush lb (kg)	2-in. ext. Ib (kg)	4-in. ext. Ib (kg)	6-in. ext. Ib (kg)
2-in., Class 150	12.5 (5,7)	N/A	N/A	N/A
3-in., Class 150	17.5 (7,9)	19.5 (8,8)	20.5 (9,3)	21.5 (9,7)
4-in., Class 150	23.5 (10,7)	26.5 (12,0)	28.5 (12,9)	30.5 (13,8)
2-in., Class 300	17.5 (7,9)	N/A	N/A	N/A
3-in., Class 300	22.5 (10,2)	24.5 (11,1)	25.5 (11,6)	26.5 (12,0)
4-in., Class 300	32.5 (14,7)	35.5 (16,1)	37.5 (17,0)	39.5 (17,9)
2-in., Class 600	15.3 (6,9)	N/A	N/A	N/A
3-in., Class 600	25.2 (11,4)	27.2 (12,3)	28.2 (12,8)	29.2 (13,2)
DN 50/PN 40	13.8 (6,2)	N/A	N/A	N/A
DN 80/PN 40	19.5 (8,8)	21.5 (9,7)	22.5 (10,2)	23.5 (10,6)
DN 100/ PN 10/16	17.8 (8,1)	19.8 (9,0)	20.8 (9,5)	21.8 (9,9)
DN 100/ PN 40	23.2 (10,5)	25.2 (11,5)	26.2 (11,9)	27.2 (12,3)

#### Table 54. Rosemount 3051L Weights without Options

#### Table 55. Rosemount 3051L Transmitter Option Weights

Code	Option	Add lb (kg)
J, K, L, M	Stainless steel housing (T)	3.9 (1.8)
J, K, L, M	Stainless steel housing (C, L, H, P)	3.1 (1.4)
M5	LCD display for aluminum housing	0.5 (0.2)
M6	LCD display for SST housing	1.25 (0.6)

#### Table 56. Rosemount 2051L Weights without Options

Flange	Flush Ib (kg)	2-in. ext. lb (kg)	4-in. ext. Ib (kg)	6-in. ext. Ib (kg)
2-in., Class 150	12.5 (5,7)	N/A	N/A	N/A
3-in., Class 150	17.5 (7,9)	19.5 (8,8)	20.5 (9,3)	21.5 (9,7)
4-in., Class 150	23.5(10,7)	26.5 (12,0)	28.5 (12,9)	30.5 (13,8)
2-in., Class 300	17.5 (7,9)	N/A	N/A	N/A
3-in., Class 300	22.5 (10,2)	24.5 (11,1)	25.5 (11,6)	26.5 (12,0)
4-in., Class 300	32.5 (14,7)	35.5 (16,1)	37.5 (17,0)	39.5 (17,9)
DN 50/PN 40	13.8 (6,2)	N/A	N/A	N/A
DN 80/PN 40	19.5 (8,8)	21.5 (9,7)	22.5 (10,2)	23.5 (10,6)
DN 100/ PN 10/16	17.8 (8,1)	19.8 (9,0)	20.8 (9,5)	21.8 (9,9)
DN 100/ PN 40	23.2 (10,5)	25.2 (11,5)	26.2 (11,9)	27.2 (12,3)

#### Table 57. Rosemount 2051L Transmitter Option Weights

Code	Option	Add lb (kg)
J, K, L, M	Stainless steel housing	3.9 (1,8)
M5	LCD display for aluminum housing	0.5 (0,2)

# **Rosemount 1199 Seal specifications**

#### **Functional specifications**

#### Hygienic seal approvals

#### 3-A

The following seals are 3-A approved and labeled:

SCW (Tri-clover style Tri-Clamp seal)

STW (Thin wall tank spud seal)

EES Flanged Tank spud extended seal

VCS (In-line tri-clover style Tri-Clamp seal)

SVS (Tuchenhagen VARIVENT compatible seal

SHP (Cherry-Burrell "I" line style seal

SLS (Dairy process connection - female thread)

#### EHEDG (Type EL Class I)

The following seals are EHEDG Type EL Class I approved and labeled:

SCW (Tri-clover style Tri-Clamp seal)

VCS (In-line tri-clover style Tri-Clamp seal)

SVS (Tuchenhagen VARIVENT compatible seal

SLS (Dairy process connection - female thread)

Ensure gasket selected for installation is approved to meet both application and EHEDG certification requirements.

#### **Hygienic Fill Fluids**

The hygienic fill fluids glycerin and water and Propylene Glycol and water meet United States Pharmacopeia(USP) and Food Chemical Codex (FCC) requirements and is Generally Recognized as Safe (GRAS) in accordance with the FDA Code of Federal Regulations Title 21. The hygienic fill fluid Neobee M-20 is approved under 21CFR 172.856 as a direct food additive and under 21 CFR 174.5 as an indirect food additive. Tri-Therm 300 is registered by NSF as meeting FDA 21 CFR regulatory requirements and is acceptable for use where there is possibility of incidental food contact (HT 1).

#### **Hygienic O-rings:**

The EPDM, Fluorocarbon (FMK), and Nitrilebutadiene (NBR) O-rings for the SSW Tank Spud Seal meet 3-A Hygienic Standard Number 18 Class 1 requirements. The EPDM O-ring also meets USP Class VI approval requirements.

#### Transmissible Spongiform Encephalopathy (TSE) Declaration

Emerson certifies no process wetted components used in hygienic seal products contain substances of animal origin. Materials used in the production or processing of wetted components for hygienic seals meet the requirements stated in EMA/410/01 Rev. 3 and ISO 22442-1:2015. Wetted components in hygienic seals are considered free of TSE.

#### Surface finish certification (Q16 option)

When ordering the Q16 option in the pressure transmitter model number, the surface finish of the seal diaphragm is certified per BPE 2002 requirements. This surface finish certification is available for Tri-Clamp, Tri-Clamp Inline, Tank Spud, and Thin Wall Tank Spud seal types.

#### NACE Standard (Q15 or Q25 option)

NACE (National Association of Corrosion Engineers) standard MR0175/ISO 15156 defines metallic material requirements for resistance to sulfide stress cracking when applied on petroleum production, drilling, gathering and flow line equipment, and field processing facilities to be used in H2S bearing hydrocarbon service. MR0103 provides material requirements exclusive to sour petroleum refining environments. Compliance guidelines are intended to include "wetted" materials as recommended by both NACE standards. The option code T in several of the general purpose seal types limits the wetted material offering. Metallurgical requirements for alloys used are virtually identical for the two standards, but application conditions enforced are different and can limit material acceptance. Contact an Emerson representative to aid in selecting the proper materials to meet the NACE standard.

#### Material traceability (Q8 Option)

Material traceability is provided for the seal, upper housing, and if applicable, lower housing/flushing connection or diaphragm extension, upon selecting the option code Q8 in the pressure transmitter model number. Material traceability for the transmitter/seal system is provided per the DIN EN10204 3.1 standard, and is only available for general purpose seal types.

# Performance specifications

Instrument Toolkit calculates the remote seal system performance and validates model number configuration.

# Remote seal system performance calculation report (QZ Option)

When the QZ option code is specified within the pressure transmitter model structure, Emerson will generate a remote seal system calculation report for the given application. This report quantifies all aspects of remote seal system performance including seal temperature effects, head temperature effects, seal response time, and transmitter total probable error.

# **Physical specifications**

#### Material selection

Emerson provides a variety of Rosemount products with various product options and configurations including materials of construction that can be expected to perform well in a wide range of applications. The Rosemount product information presented is intended as a guide for the purchaser to make an appropriate selection for the application. It is the purchaser's sole responsibility to make a careful analysis of all process parameters (such as all chemical components, temperature, pressure, flow rate, abrasives, contaminants, etc.), when specifying product materials, options, and components for the particular application. Emerson is not in a position to evaluate or guarantee the compatibility of the process fluid or other process parameters with the product options, configuration, or materials of construction selected.

#### Note

If a lower housing is supplied, then the following gaskets are the default gaskets for each seal unless another gasket option is selected.

#### Wetted materials

Seal	Gaskets	
FFW	Thermo-Tork TN-9000 gasket	
EFW	No gasket is s3upplied	
FCW	No gasket is supplied	
FUW	No gasket is supplied	
FVW	No gasket is supplied	
RCW	Klinger C-4401 gasket	
RFW	Klinger C-4401 gasket	
RTW	Klinger C-4401 gasket	
PFW	Thermo-Tork TN-9000 gasket	
PCW	No gasket is supplied	
SSW	Ethylene Propylene O-ring	
STW	Ethylene Propylene O-ring	
UCW	Teflon O-ring	
UCP	Barium-sulfate Filled PTFE O-ring	
WSP	Klinger C-4401 gasket	
WBW	Klinger C-4401 gasket	
WFW	Klinger C-4401 gasket	
WTW	Klinger C-4401 gasket	
WWW	Klinger C-4401 gasket	

#### Tagging

The Rosemount 1199 Remote Seal model number is marked on the transmitter nameplate (neck or top label). The pressure transmitter will be tagged in accordance with customer requirements. The standard stainless steel tag is wired to the transmitter. Tag is 0.02-in. (0.051 cm) thick with 0.125-in. (0.318 cm) high letters. A permanently attached tag is available upon request.

#### Calibration

Transmitters are factory calibrated to customer's specified range. If calibration is not specified, then the transmitters are calibrated at maximum range. Calibration is performed at ambient temperature and pressure.

# **Product certifications**

# Rosemount 3051S/3051SFx/3051S ERS

#### Rev 1.15

# **European Directive Information**

A copy of the EU Declaration of Conformity can be found at the end of the Quick Start Guide. The most recent revision of the EU Declaration of Conformity can be found at <u>Emerson.com/Rosemount.</u>

# **Ordinary Location Certification**

As standard, the transmitter has been examined and tested to determine that the design meets the basic electrical, mechanical, and fire protection requirements by FM Approvals, a nationally recognized test laboratory (NRTL) as accredited by the Federal Occupational Safety and Health Administration (OSHA).

# **Installing Equipment in North America**

The US National Electrical Code[®] (NEC) and the Canadian Electrical Code (CEC) permit the use of Division marked equipment in Zones and Zone marked equipment in Divisions. The markings must be suitable for the area Classification, gas, and temperature Class. This information is clearly defined in the respective codes.

# USA

- E5 FM Explosionproof (XP) and Dust-Ignitionproof (DIP) Certificate: 3008216
  - Standards: FM Class 3600 2011, FM Class 3615 2006, FM Class 3616-2011, 3810 – 2005, ANSI/NEMA 250 – 2003
  - Markings: XP CL I, DIV 1, GP B, C, D; DIP CL II, DIV 1, GP E, F, G; CL III;T5(-50 °C  $\leq$  T_a  $\leq$  +85 °C); Factory Sealed; Type 4X
- **I5** FM Intrinsic Safety (IS) and Nonincendive (NI) Certificate: 3012350
  - Standards: FM Class 3600 2011, FM Class 3610 2010, FM Class 3611 - 2004, FM Class 3810 - 2005, NEMA 250 - 2003
  - Markings: IS CL I, DIV 1, GP A, B, C, D; CL II, DIV 1, GP E, F, G; Class III; Class 1, Zone 0 AEx ia IIC T4; NI CL 1, DIV 2, GP A, B, C, D; T4(-50 °C  $\leq$  T_a  $\leq$  +70 °C) [HART]; T4(-50 °C  $\leq$  T_a  $\leq$  +60 °C) [Fieldbus]; when connected per Rosemount drawing 03151-1006; Type 4X

#### Special Condition for Safe Use (X):

1. The Model 3051S/3051S-ERS Pressure Transmitter contains aluminum and is considered to constitute a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact and friction.

#### Note

Transmitters marked with NI CL 1, DIV 2 can be installed in Division 2 locations using general Division 2 wiring methods or Nonincendive Field Wiring (NIFW). See Drawing 03151-1006.

IE US FISCO

Certificate: FM16US0089X Standards: FM Class 3600 - 2011, FM Class 3610 - 2010, FM Class 3611 - 2004, FM Class 3810 - 2005, NEMA 250 - 2003 Markinger IS CL + DIV1 - CDA - B, C, Di

Markings: IS CL I, DIV 1, GP A, B, C, D; T4(-50 °C  $\leq$  T_a  $\leq$  +70 °C); when connected per Rosemount drawing 03151-1006; Type 4X

#### Special Condition for Safe Use (X):

1. The Model 3051S/3051S-ERS Pressure Transmitter contains aluminum and is considered to constitute a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact and friction.

## Canada

- **E6** CSA Explosionproof, Dust-Ignitionproof, and Division 2 Certificate: 143113
  - Standards: CAN/CSA C22.2 No. 0-10, CSA Std C22.2 No. 25-1966, CSA Std C22.2 No. 30-M1986, CAN/CSA C22.2 No. 94-M91, CSA Std C22.2 No. 142-M1987, CSA Std C22.2 No. 213-M1987, ANSI/ISA 12.27.01-2003, CSA Std C22.2 No. 60529:05
  - Markings: Explosionproof Class I, Division 1, Groups B, C, D; Dust-Ignitionproof Class II, Division 1, Groups E, F, G; Class III; suitable for Class I, Zone 1, Group IIB+H2, T5; suitable for Class I, Division 2, Groups A, B, C, D; suitable for Class I, Zone 2, Group IIC, T5; when connected per Rosemount drawing 03151-1013; Type 4X

- **I6** CSA Intrinsically Safe Certificate: 1143113
  - Standards: CAN/CSA C22.2 No. 0-10, CSA Std C22.2 No. 30-M1986, CAN/CSA C22.2 No. 94-M91, CSA Std C22.2 No. 142-M1987, CSA Std C22.2 No. 157-92, ANSI/ISA 12.27.01-2003, CSA Std C22.2 No. 60529:05
  - Markings: Intrinsically Safe Class I, Division 1; suitable for Class 1, Zone 0, IIC, T3C; when connected per Rosemount drawing 03151-1016; Type 4X
- IF CSA FISCO

Certificate: 1143113

- Standards: CAN/CSA C22.2 No. 0-10, CSA Std C22.2 No. 30-M1986, CAN/CSA C22.2 No. 94-M91, CSA Std C22.2 No. 142-M1987, CSA Std C22.2 No. 157-92, ANSI/ISA 12.27.01-2003, CSA Std C22.2 No. 60529:05
- Markings: Intrinsically Safe Class I, Division 1; Groups A, B, C, D; suitable for Class 1, Zone 0, IIC, T3C; when connected per Rosemount drawing 03151-1016 [3051S] 03151-1313 [ERS]; Type 4X

# Europe

- - T6(-60 °C  $\leq$  T_a  $\leq$  +70 °C), T5/T4(-60 °C  $\leq$  T_a  $\leq$  +80 °C)

Temperature class	Process temperature
T6	–60 °C to +70 °C
T5	–60 °C to +80 °C
T4	–60 °C to +120 °C

## Special Conditions for Safe Use (X):

- 1. This device contains a thin wall diaphragm less than 1 mm thickness that forms a boundary between EPL Ga (process connection) and EPL Gb (all other parts of the equipment). The model code and datasheet are to be consulted for details of the diaphragm material. Installation, maintenance and use shall take into account the environmental conditions to which the diaphragm will be subjected. The manufacturer's instructions for installation and maintenance shall be followed in detail to assure safety during its expected lifetime.
- 2. Flameproof joints are not intended for repair.
- 3. Non-standard paint options may cause risk from electrostatic discharge. Avoid installations that could cause electrostatic build-up on painted surfaces, and only clean the painted surfaces with a damp cloth. If paint is ordered through a special option code, contact the manufacturer for more information.
- 4. Appropriate cable, glands and plugs need to be suitable for a temperature of 5 °C greater than maximum specified temperature for location where installed.

 $\begin{array}{ll} \mbox{ITEX Intrinsic Safety} \\ \mbox{Certificate: BAS01ATEX1303X} \\ \mbox{Standards: EN 60079-0: 2012+A11:2013,} \\ \mbox{EN 60079-11: 2012} \\ \mbox{Markings: } \textcircled{ \mbox{ } \mbox{II 1 G Ex ia IIC T4 Ga, T4(-60 °C <math display="inline">\leq T_a \leq +70 °C) } \end{array}$ 

Model	Ui	li	Pi	C _i	Li
SuperModule	30 V	300 mA	1.0 W	30 nF	0
3051SA; 3051SFA; 3051SALC	30 V	300 mA	1.0 W	12 nF	0
3051SF; 3051SFF	30 V	300 mA	1.3 W	0	0
3051SAM7, M8, or M9; 3051SFAM7, M8, or M9; 3051SALC M7, M8, or M9	30 V	300 mA	1.0 W	12 nF	60 µH
3051SAL or 3051SAM	30 V	300 mA	1.0 W	12 nF	33 μΗ
3051SALM7, M8, or M9 3051SAMM7, M8, or M9	30 V	300 mA	1.0 W	12 nF	93 µH
RTD Option for 3051SF	5 V	500 mA	0.63 W	N/A	N/A

## Special Conditions for Safe Use (X):

- 1. The Model 3051S Transmitters fitted with transient protection are not capable of withstanding the 500 V test as defined in Clause 6.3.13 of EN 60079-11:2012. This must be taken into account during installation.
- 2. The terminal pins of the Model 3051S SuperModule must be provided with a degree of protection of at least IP20 in accordance with IEC/EN 60529.
- 3. The Model 3051S enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in a zone 0 area.

## IA ATEX FISCO

Certificate: BAS01ATEX1303X Standards: EN 60079-0: 2012+A11:2013, EN 60079-11: 2012

Markings: (a) II 1 G Ex ia IIC T4 Ga, T4( $-60 \degree C \le Ta \le +70 \degree C$ )

Parameter	FISCO
Voltage U _i	17.5 V
Current l _i	380 mA
Power P _i	5.32 W
Capacitance C _i	0
Inductance L _i	0

## Special Conditions for Safe Use (X):

- 1. The Model 3051S Transmitters fitted with transient protection are not capable of withstanding the 500 V test as defined in Clause 6.3.13 of EN 60079-11:2012. This must be taken into account during installation.
- 2. The terminal pins of the Model 3051S SuperModule must be provided with a degree of protection of at least IP20 in accordance with IEC/EN 60529.

- 3. The Model 3051S enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in a zone 0 area.
- ND ATEX Dust

Certificate: BAS01ATEX1374X Standards: EN 60079-0: 2012+A11:2013, EN 60079-31: 2009 Markings: 🐵 II 1 D Ex ta IIIC T105 °C T₅₀₀ 95 °C Da,  $(-20 °C \le T_a \le +85 °C), V_{max} = 42.4 V$ 

#### Special Conditions for Safe Use (X):

- 1. Cable entries must be used which maintain the ingress protection of the enclosure to at least IP66.
- 2. Unused cable entries must be filled with suitable blanking plugs which maintain the ingress protection of the enclosure to at least IP66.
- 3. Cable entries and blanking plugs must be suitable for the ambient temperature range of the apparatus and capable of withstanding a 7J impact test.
- 4. The SuperModule(s) must be securely screwed in place to maintain the ingress protection of the enclosure(s).
- N1 ATEX Type n

Certificate: BAS01ATEX3304X Standards: EN 60079-0: 2012+A11:2013, EN 60079-15: 2010 Markings: 🕲 II 3 G Ex nA IIC T5 Gc, (-40 °C  $\leq$  Ta  $\leq$  +85 °C), V_{max} = 45 V

## Special Condition for Safe Use (X):

 The equipment is not capable of withstanding the 500 V insulation test required by clause 6.5 of EN 60079-15:2010. This must be taken into account when installing the equipment.

#### Note

RTD Assembly is not included with the Rosemount 3051SFx Type n Approval.

## International

**E7** IECEx Flameproof and Dust Certificate: IECEx KEM 08.0010X (Flameproof) Standards: IEC 60079-0:2011, IEC 60079-1:2014, IEC 60079-26:2014 Markings: Ex d IIC T6...T4 Ga/Gb, T6(-60 °C  $\leq$  T_a  $\leq$  +70 °C),

arkings: Ex d IIC 16...14 Ga/GD, 16(-60 °C  $\le$   $I_a \le$  +70 T5/T4(-60 °C  $\le$   $T_a \le$  +80 °C)

Temperature class	Process temperature
T6	–60 °C to +70 °C
T5	–60 °C to +80 °C
T4	–60 °C to +120 °C

#### Special Conditions for Safe Use (X):

- 1. This device contains a thin wall diaphragm less than 1 mm thickness that forms a boundary between EPL Ga (process connection) and EPL Gb (all other parts of the equipment). The model code and datasheet are to be consulted for details of the diaphragm material. Installation, maintenance and use shall take into account the environmental conditions to which the diaphragm will be subjected. The manufacturer's instructions for installation and maintenance shall be followed in detail to assure safety during its expected lifetime.
- 2. Flameproof joints are not intended for repair.
- 3. Non-standard paint options may cause risk from electrostatic discharge. Avoid installations that could cause electrostatic build-up on painted surfaces, and only clean the painted surfaces with a damp cloth. If paint is ordered through a special option code, contact the manufacturer for more information.
- 4. Appropriate cable, glands and plugs need to be suitable for a temperature of 5 °C greater than maximum specified temperature for location where installed.

Certificate: IECEx BAS 09.0014X (Dust) Standards: IEC 60079-0:2011, IEC 60079-31:2008 Markings: Ex ta IIIC T105 °C T₅₀₀95 °C Da,  $(-20 °C \le T_a \le +85 °C), V_{max} = 42.4 V$ 

#### Special Conditions for Safe Use (X):

- 1. Cable entries must be used which maintain the ingress protection of the enclosure to at least IP66.
- 2. Unused cable entries must be filled with suitable blanking plugs which maintain the ingress protection of the enclosure to at least IP66.
- 3. Cable entries and blanking plugs must be suitable for the ambient temperature range of the apparatus and capable of withstanding a 7J impact test.
- 4. The 3051S- SuperModule must be securely screwed in place to maintain the ingress protection of the enclosure.
$\begin{array}{ll} \mbox{IZCEx Intrinsic Safety} \\ \mbox{Certificate: IECEx BAS 04.0017X} \\ \mbox{Standards: IEC 60079-0: 2011, IEC 60079-11: 2011} \\ \mbox{Markings: Ex ia IIC T4 Ga, T4(-60 °C <math>\leq T_a \leq +70 °C) \end{array}$ 

Model	Ui	li	Pi	Ci	Li
SuperModule	30 V	300 mA	1.0 W	30 nF	0
3051SA; 3051SFA; 3051SALC	30 V	300 mA	1.0 W	12 nF	0
3051SF; 3051SFF	30 V	300 mA	1.3 W	0	0
3051SAM7, M8, or M9; 3051SFAM7, M8, or M9; 3051SALC M7, M8, or M9	30 V	300 mA	1.0 W	12 nF	60 µH
3051SAL or 3051SAM	30 V	300 mA	1.0 W	12 nF	33 μΗ
3051SALM7, M8, or M9 3051SAMM7, M8, or M9	30 V	300 mA	1.0 W	12 nF	93 μΗ
RTD Option for 3051SF	5 V	500 mA	0.63 W	N/A	N/A

## Special Conditions for Safe Use (X):

- 1. The Model 3051S Transmitters fitted with transient protection are not capable of withstanding the 500 V test as defined in Clause 6.3.13 of IEC 60079-11:2011. This must be taken into account during installation.
- 2. The terminal pins of the Model 3051S SuperModule must be provided with a degree of protection of at least IP20 in accordance with IEC/EN 60529.
- 3. The Model 3051S enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in a zone 0 area.
- I7IECEx Intrinsic Safety Group I Mining (I7 with<br/>special A0259)<br/>Certificate: IECEx TSA 14.0019X<br/>Standards: IEC 60079-0: 2011, IEC 60079-11: 2011<br/>Markings: Ex ia I Ma ( $-60 \degree C \le T_a \le +70 \degree C$ )

Model	Ui	li	Pi	C _i	Li
SuperModule	30 V	300 mA	1.0 W	30 nF	0
3051SA; 3051SFA; 3051SALC	30 V	300 mA	1.0 W	12 nF	0
3051SF; 3051SFF	30 V	300 mA	1.3 W	0	0
30515AM7, M8, or M9; 3051SFAM7, M8, or M9; 3051SALCM7, M8, or M9	30 V	300 mA	1.0 W	12 nF	60 µH
3051SAL or 3051SAM	30 V	300 mA	1.0 W	12 nF	33 μΗ
3051SALM7, M8, or M9 3051SAMM7, M8, or M9	30 V	300 mA	1.0 W	12 nF	93 μH
RTD Option for 3051SF	5 V	500 mA	0.63 W	N/A	N/A

#### Special Conditions for Safe Use (X):

- If the apparatus is fitted with an optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test required by clause 6.6.13 of IEC60079-11. This must be taken into account when installing the apparatus.
- 2. It is a condition of safe use that the following parameters shall be taken into account during installation.
- 3. It is a condition of manufacture that only the apparatus fitted with housings, junction boxes, covers and sensor module housings made out of stainless steel are used in Group I applications.

## IG IECEx FISCO

Certificate: IECEx BAS 04.0017X Standards: IEC 60079-0: 2011, IEC 60079-11: 2011 Markings: Ex ia IIC T4 Ga, T4( $-60 \degree C \le T_a \le +70 \degree C$ )

	FISCO
Voltage U _i	17.5 V
Current I _i	380 mA
Power P _i	5.32 W
Capacitance C _i	0
Inductance L _i	0

## Special Conditions for Safe Use (X):

- 1. The Model 3051S Transmitters fitted with transient protection are not capable of withstanding the 500 V test as defined in Clause 6.3.13 of EN 60079-11:2012. This must be taken into account during installation.
- 2. The terminal pins of the Model 3051S SuperModule must be provided with a degree of protection of at least IP20 in accordance with IEC/EN 60529.
- 3. The Model 3051S enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in a zone 0 area.

IECEx Intrinsic Safety - Group I - Mining (IG with Special A0259)

Certificate: IECEx TSA 04.0019X Standards: IEC 60079-0: 2011, IEC 60079-11: 2011 Markings: FISCO FIELD DEVICE Ex ia I Ma,  $(-60 \degree C \le T_a \le +70 \degree C)$ 

	FISCO
Voltage U _i	17.5 V
Current I _i	380 mA
Power P _i	5.32 W
Capacitance C _i	0
Inductance L _i	0

- If the apparatus is fitted with optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test required by Clause 6.3.13 of IEC60079-11. This must be taken into account when installing the apparatus.
- 2. It is a condition of safe use that the above input parameters shall be taken into account during installation.
- 3. It is a condition of manufacture that only the apparatus fitted with housing, covers and sensor module housing made out of stainless steel are used in Group I applications.
- **N7** IECEx Type n Certificate: IECEx BAS 04.0018X Standards: IEC 60079-0: 2011, IEC 60079-15: 2010 Markings: Ex nA IIC T5 Gc,  $(-40 \ ^{\circ}C \le T_a \le +85 \ ^{\circ}C)$

## Special Condition for Safe Use (X):

 The equipment is not capable of withstanding the 500 V insulation test required by clause 6.5 of IEC 60079-15:2010. This must be taken into account when installing the equipment.

## Brazil

E2 INMETRO Flameproof Certificate: UL-BR15.0393X Standards: ABNT NBR IEC 60079-0:2008 + Corrigendum 1:2011, ABNT NBR IEC 60079-1:2009 + Corrigendum 1:2011, ABNT NBR IEC 60079-26:2008 + Corrigendum 1: 2008 Markings: Ex d IIC T^{*} Ga/Gb, T6(-60 °C ≤ T_a ≤ +70 °C), T5/T4(-60 °C ≤ T_a ≤ +80 °C), IP66

## Special Conditions for Safe Use (X):

- 1. The device contains a thin wall diaphragm. Installation, maintenance and use shall take into account the environmental conditions to which the diaphragm will be subjected. The manufacturer's instructions for installation and maintenance shall be followed in detail to assure safety during its expected lifetime.
- 2. For information on the dimensions of the flameproofs joints, the manufacturer shall be contacted.

I2/IB INMETRO Intrinsic Safety/FISCO<br/>Certificate: UL-BR 15.0392X<br/>Standards: ABNT NBR IEC 60079-0:2008 + Corrigendum<br/>1:2011, ABNT NBR IEC 60079-11:2009<br/>Markings: Ex ia IIC T4 Ga, T4(-60 °C  $\leq$  Ta  $\leq$  +70 °C),<br/>IP66

#### Special Condition for Safe Use (X):

- The surface resistivity of the antenna is greater than 1 GΩ. To avoid electrostatic charge build-up, it must not be rubbed or cleaned with solvents or a dry cloth.
- 2. 2The Model 701PBKKF Power Module may be replaced in a hazardous area. The Power Module has a surface resistivity greater than 1 G $\Omega$  and must be properly installed in the wireless device enclosure. Care must be taken during transportation to and from the point of installation to prevent electrostatic charge build-up.
- 3. The 3051S enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in areas that requires EPL Ga.

Rosemount model	Ui	li	Pi	C _i	Lį
SuperModule	30 V	300 mA	1.0 W	30 nF	0
3051SA; 3051SFA; 3051SALC	30 V	300 mA	1.0 W	12 nF	0
3051SF; 3051SFF	30 V	300 mA	1.3 W	0	0
3051SFIB; 3051SFFIB	17.5V	380 mA	5.32 W	0	0
30515AM7, M8, or M9; 3051SFAM7, M8, or M9; 3051SALCM7, M8, or M9	30 V	300 mA	1.0 W	11.4 nF	60 µH
3051SAL or 3051SAM	30 V	300 mA	1.0 W	11.4 nF	33 μΗ
3051SALM7, M8, or M9 3051SAMM7, M8, or M9	30 V	300 mA	1.0 W	11.4 nF	93 µH
RTD Option for 3051SF	5 V	500 mA	0.63 W	N/A	N/A

## China

E3 China Flameproof and Dust Ignition-proof Certificate: 3051S: GY|16.1249X 3051SFx: GY[16.1466X 3051S-ERS: GJY15.1406X Standards: 3051S: GB3836.1-2010, GB3836.2-2010, GB3836.20-2010, GB12476.1-2013, GB12476.5-2013 3051SFx: GB3836.1-2010, GB3836.2-2010, GB3836.20-2010, GB12476.1-2013, GB 12476.5-2013 3051S-ERS: GB3836.1-2010, GB3836.2-2010, GB3836.20-2010 Markings: 3051S: Ex d IIC T6...T4; Ex tD A20 T105 °C T₅₀₀ 95 °C; IP66 3051SFx: Ex d IIC T5/T6 Ga/Gb; DIP A20 TA 105 °C; IP66 3051S-ERS: Ex d IIC T4 ~ T6 Ga/Gb

- 1. Only the pressure transmitters, consisting of Rosemount 3051SC, 3051ST, 3051SL and 300S Series, are certified.
- 2. Flameproof joints are not intended for repair.
- 3. The ambient temperature range for the 3051S in a dust environment is  $-20~^\circ\text{C} \le T_a \le 85~^\circ\text{C}$
- 4. The relation between temperature class and maximum temperature of process medium is as follows:

Temperature class	Ambient temperature	Process temperature
T6	–60 °C ≤ Ta ≤ +70 °C	–60 °C ≤ Ta ≤ +70 °C
T5	–60 °C ≤ Ta ≤ +80 °C	–60 °C ≤ Ta ≤ +80 °C
T4	-60 °C ≤ Ta ≤ +80 °C	–60 °C ≤ Ta ≤ +120 °C

- 5. The earth connection facility in the enclosure should be connected reliably.
- 6. During installation, use and maintenance of transmitter, observe the warning "Don't open the cover when the circuit is alive."
- 7. During installation, there should be no mixture harm to flameproof housing.
- 8. Cable entry, certified by NEPSI with type of protection Ex d IIC in accordance with GB3836.1-2000 and GB3836.2-2000, should be applied when installation in hazardous location. 5 full threads should be in engagement when the cable entry is assembled onto the transmitter. When pressure transmitter is used in the presence of combustible dust, the ingress of protection of the cable entry should be IP66.
- 9. The diameter of cable should observe the instruction manual of cable entry. The compressing nut should be fastened. The aging of seal ring should be changed in time.
- 10. Maintenance should be done in non-hazardous location.
- 11. End users are not permitted to change any components inside.
- 12. When installation, use and maintenance of transmitter, observe following standards:

GB3836.13-1997 "Electrical apparatus for explosive gas atmospheres Part 13: Repair and overhaul for apparatus used in explosive gas atmospheres"

GB3836.15-2000 "Electrical apparatus for explosive gas atmospheres Part 15: Electrical installations in hazardous area (other than mines)"

GB50257-1996 "Code for construction and acceptance of electric device for explosion atmospheres and fire hazard electrical equipment installation engineering" GB15577-1995 "Safe regulation for explosive dust

atmospheres"

GB12476.2-2006 "Electrical apparatus for use in the presence of combustible dust – Part 1-2: Electrical apparatus protected by enclosures and surface temperature limitation – Selection, installation and maintenance"

- 13 China Intrinsic Safety
- Certificate: 30515: GYJ16.1250X[Mfg USA, China, Singapore] 3051SFx: GYJ16.1465X [Mfg USA, China, Singapore] 3051S-ERS: GYJ16.1248X [Mfg USA, China, Singapore] Standards: 3051S: GB3836.1-2010, GB3836.4-2010, GB3836.20-2010 3051SFx: GB3836.1/4-2010, GB3836.20-2010, GB12476.1-2013, GB12476.5-2013

3051S-ERS: GB3836.1-2010, GB3836.4-2010, GB3836.20-2010

3051S-ERS: GB3836.1-2010, GB3836.2-2010, GB3836.2-2010, GB3836.20-2010

Markings: 3051S, 3051SFx: Ex ia IIC T4 Ga 3051S-ERS: Ex ia IIC T4

## Special Conditions for Safe Use (X):

- 1. Symbol "X" is used to denote specific conditions of use: For output code A and F: This apparatus is not capable of withstanding the 500 V r.m.s. insulation test required by Clause 6.4.12 of GB3836.4-2000.
- 2. The ambient temperature range is:

Output code	Ambient temperature
A	$-50 \degree C \le T_a \le +70 \degree C$
F	$-50 \degree C \le T_a \le +60 \degree C$

#### 3. Intrinsically safe parameters:

Output code	Housing code	Display code	Maximum input voltage: U _i (V)	Maximum input current: I _i (mA)	Maximum input power: P _i (W)	Maximum internal parameters : C _i (nF)	Maximum internal parameters : L _i (uH)
A	=00	N/A	30	300	1	38	0
A	≠00	N/A	30	300	1	11.4	2.4
А	≠00	M7/M8 /M9	30	300	1	0	58.2
F	≠00	N/A	30	300	1.3	0	0
F FISCO	≠00	N/A	17.5	500	5.5	0	0

- 4. The product should be used with Ex-certified associated apparatus to establish explosion protection system that can be used in explosive gas atmospheres. Wiring and terminals should comply with the instruction manual of the product and associated apparatus.
- 5. The cable between this product and associated apparatus should be shielded cables (the cables must have insulated shield). The shield has to be grounded reliably in non-hazardous area.
- 6. The product complies to the requirements for FISCO field devices specified in IEC60079-27:2008. For the connection of an intrinsically safe circuit in accordance FISCO model, FISCO parameters of this product are as above.
- 7. End users are not permitted to change any components inside, but to settle the problem in conjunction with manufacturer to avoid damage to the product.

8. When installation, use and maintenance of this product, observe the following standards:

GB3836.13-1997 "Electrical apparatus for explosive gas atmospheres Part 13: Repair and overhaul for apparatus used in explosive gas atmospheres"

GB3836.15-2000 "Electrical apparatus for explosive gas atmospheres Part 15: Electrical installations in hazardous area (other than mines)"

GB3836.16-2006 "Electrical apparatus for explosive gas atmospheres Part 16: Inspection and maintenance of electrical installation (other than mines)" GB50257-1996 "Code for construction and acceptance of electric device for explosion atmospheres and fire hazard electrical equipment installation engineering"

N3 China Type n

Certificate: 3051S: GYJ15.1106X [Mfg China] 3051SF: GYJ15.1107X [Mfg China] Markings: Ex nA IIC T5 Gc

## Special Condition for Safe Use (X):

1. When transient protection board is chosen (Option Code T1), this apparatus is not capable of withstanding the 500V r.m.s insulation test, this must be taken into account when installing the component.

## EAC - Belarus, Kazakhstan, Russia

- EM Technical Regulation Customs Union (EAC) Flameproof Certificate: RU C-US.AA87.B.00378 Markings: Ga/Gb Ex d IIC T6...T4 X Ex tb IIIC T105 °C T₅₀₀ 95 °C Db X Ex ta IIIC T105 °C T₅₀₀ 95 °C Da X
- IM Technical Regulation Customs Union (EAC) Intrinsic Safety Certificate: RU C-US.AA87.B.00094 Markings: 0Ex ia IIC T4 Ga X

## Japan

- **E4** Japan Flameproof
  - Certificate: TC15682, TC15683, TC15684, TC15685, TC15686, TC15687, TC15688, TC15689, TC15690, TC17099, TC17100, TC17101, TC17102, TC18876 3051ERS: TC20215, TC20216, TC20217, TC20218, TC20219, TC20220, TC20221 Markings: Ex d IIC T6

## **Republic of Korea**

EP Republic of Korea Flameproof Certificate: 12-KB4BO-0180X [Mfg USA], 11-KB4BO-0068X [Mfg Singapore] Markings: Ex d IIC T6...T4  IP Republic of Korea Intrinsic Safety Certificate: 12-KB4BO-0202X [HART – Mfg USA], 12-KB4BO-0204X [Fieldbus – Mfg USA], 12-KB4BO-0203X [HART – Mfg Singapore], 13-KB4BO-0296X [Fieldbus – Mfg Singapore]
 Markings: Ex ia IIC T4

## Combinations

- **K1** Combination of E1, I1, N1, and ND
- **K2** Combination of E2 and I2
- **K5** Combination of E5 and I5
- **K6** Combination of E6 and I6
- **K7** Combination of E7, I7, and N7
- **KA** Combination of E1, I1, E6, and I6
- **KB** Combination of E5, I5, E6, and I6
- **KC** Combination of E1, I1, E5, and I5
- **KD** Combination of E1, I1, E5, I5, E6, and I6
- **KG** Combination of IA, IE, IF, and IG
- **KM** Combination of EM and IM
- **KP** Combination of EP and IP

## **Additional Certifications**

**SBS** American Bureau of Shipping (ABS) Type Approval Certificate: 00-HS145383-6-PDA

Intended Use: Measure gauge or absolute pressure of liquid, gas or vapor applications on ABS Classed vessels, marine, and offshore installations.

SBV Bureau Veritas (BV) Type Approval Certificate: 31910 BV Requirements: Bureau Veritas Rules for the Classification of Steel Ships

Application: Class Notations: AUT-UMS, AUT-CCS, AUT-PORT and AUT-IMS

SDN Det Norske Veritas (DNV) Type Approval Certificate: A-14186 Intended Use: Det Norske Veritas' Rules for Classification of Ships, High Speed and Light Craft, and Det Norske Veritas' Offshore Standards

Application:

Location Classes			
Туре	30515		
Temperature	D		
Humidity	В		
Vibration	A		
EMC	А		
Enclosure	D/IP66/IP68		

- SLL Lloyds Register (LR) Type Approval Certificate: 11/60002 Application: Environmental categories ENV1, ENV2, ENV3, and ENV5
- D3 Custody Transfer Measurement Canada Accuracy Approval [3051S Only] Certificate: AG-0501, AV-2380C

# Rosemount 3051S and 3051SMV Wireless

Rev 2.3

## **European Directive Information**

A copy of the EC Declaration of Conformity can be found at the end of the Quick Start Guide. The most recent revision of the EC Declaration of Conformity can be found at <u>Emerson.com/Rosemount.</u>

## **Telecommunication compliance**

All wireless devices require certification to ensure that they adhere to regulations regarding the use of the RF spectrum. Nearly every country requires this type of product certification. Emerson is working with governmental agencies around the world to supply fully compliant products and remove the risk of violating country directives or laws governing wireless device usage.

# FCC and IC

This device complies with Part 15 of the FCC Rules. Operation is subject to the following conditions: This device may not cause harmful interference. This device must accept any interference received, including interference that may cause undesired operation. This device must be installed to ensure a minimum antenna separation distance of 20 cm from all persons.

# **Ordinary Location Certification**

As standard, the transmitter has been examined and tested to determine that the design meets the basic electrical, mechanical, and fire protection requirements by a nationally recognized test laboratory (NRTL) as accredited by the Federal Occupational Safety and Health Administration (OSHA).

# **Installing Equipment in North America**

The US National Electrical Code (NEC) and the Canadian Electrical Code (CEC) permit the use of Division marked equipment in Zones and Zone marked equipment in Divisions. The markings must be suitable for the area Classification, gas, and temperature Class. This information is clearly defined in the respective codes.

# USA

IS USA Intrinsically Safe (IS), Nonincendive (NI), and Dust-Ignitionproof (DIP) Certificate: 3027705 Standards: FM Class 3600 – 2011, FM Class 3610 – 2010, FM Class 3611 – 2004, FM Class 3810 – 2005, NEMA 250 –2003  $\begin{array}{ll} \text{Markings:} & \text{IS CL I, DIV 1, GP A, B, C, D; CL II, DIV 1, GP E, F, } \\ & \text{G; CL III T4; CL 1, Zone 0 AEx ia IIC T4; NI CL 1, } \\ & \text{DIV 2, GP A, B, C, D T4; DIP CL II, DIV 1, GP E, F, } \\ & \text{G; CL III, T5; T4(-50 °C <math>\leq \text{T}_a \leq +70 °C)/ } \\ & \text{T5(-50 °C } \leq \text{T}_a \leq +85 °C); \text{ when connected per } \\ & \text{Rosemount drawing 03151-1000; Type 4X} \end{array}$ 

## Special Conditions for Safe Use (X):

- 1. The Model 3051S and SMV Wireless Transmitters shall only be used with the 701PBKKF Rosemount SmartPower Battery Pack or alternately the Perpetuum Intelligent Power Module Vibration Harvester.
- 2. The transmitter may contain more than 10% aluminum and is considered a potential risk of ignition by impact or friction.
- The surface resistivity of the antenna is greater than 1GΩ. To avoid electrostatic charge build-up, it must not be rubbed or cleaned with solvents or a dry cloth.

## Canada

- **I6** CSA Intrinsically Safe Certificate: CSA 1143113
  - Standards: CAN/CSA C22.2 No. 0-10, CSA Std C22.2 No. 30-M1986, CAN/CSA C22.2 No. 94-M91, CSA Std C22.2 No. 142-M1987, CSA Std C22.2 No. 157-92, ANSI/ISA 12.27.01-2003, CSA Std C22.2 No. 60529:05
  - Markings: Intrinsically Safe Class I, Division 1; suitable for Class 1, Zone 0, IIC, T3C; when connected per Rosemount drawing 03151-1010; Type 4X

# Europe

 $\begin{array}{ll} \mbox{II NTEX Intrinsic Safety} \\ \mbox{Certificate: Baseefa13ATEX0127X} \\ \mbox{Standards: EN 60079-0: 2012, EN 60079-11: 2012} \\ \mbox{Markings: } & \textcircled{II 1 G Ex ia IIC T4 Ga,} \\ \mbox{T4(-60 °C <math>\leq T_a \leq +70 °C)} \end{array}$ 

## Special Conditions for Safe Use (X):

- 1. The Model 3051S Wireless and Model 3051SMV Wireless enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in a zone 0 area.
- 2. The surface resistivity of the antenna is greater than  $1G\Omega$ . To avoid electrostatic charge build-up, it must not be rubbed or cleaned with solvents or dry cloth.

## International

#### Special Conditions for Safe Use (X):

- 1. The Model 3051S Wireless and Model 3051SMV Wireless enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in a zone 0 area.
- The surface resistivity of the antenna is greater than 1GΩ. To avoid electrostatic charge build-up, it must not be rubbed or cleaned with solvents or dry cloth.

## Brazil

I2 INMETRO Intrinsic Safety Certificate: UL-BR 14.0760X Standards: ABNT NBR IEC60079-0:2008, + Errata 1:2011, ABNT NBRIEC60079-11:2009, Markings: Ex ia IIC T4 Ga,T4(-60 °C  $\leq$  T_a  $\leq$  +70 °C)

#### Special Condition for Safe Use (X):

1. See certificate.

## China

 I3 China Intrinsic Safety Certificate: 3051S Wireless: GYJ161250X 3051SFx GYJ16.1465X [Flowmeters] Standards: GB3836.1-2010, GB3836.4-2010, GB3836.20-2010
 Markings: Ex ia IIC T4 Ga, T4 –60 ~ 70 °C

#### Special Condition for Safe Use (X):

1. See appropriate certificate.

#### Note

Not currently available on the Rosemount 3051S MultiVariable[™] Wireless Transmitter.

## Japan

 IIIS Intrinsically Safe Certificate: TC18649,TC18650, TC18657 Markings: Ex ia IIC T4 (-20 ~ 60 °C)

#### Note

Not currently available on the 3051S MultiVariable Wireless Transmitter.

## EAC – Belarus, Kazakhstan, Russia

 $\begin{array}{ll} \mbox{IM} & \mbox{EAC Intrinsic Safety} \\ & \mbox{Certificate: TC RU C-US.AA87.B.00378} \\ & \mbox{Markings: 0Ex ia IIC T4 Ga X (-60 \ ^{\circ}\mbox{C} \le T_a \le +70 \ ^{\circ}\mbox{C})} \end{array}$ 

#### Special Condition for Safe Use (X):

1. See certificate for special conditions.

## **Republic of Korea**

IP Korea Intrinsic Safety Certificate: 12-KB4BO-0202X, 12-KB4BO-0203X Markings: Ex ia IIC T4, (-60 °C ≤ T_a ≤ +70 °C)

#### Special Condition for Safe Use (X):

1. See certificate for special conditions.

#### Note

Not currently available on the Rosemount 3051S MultiVariable Wireless Transmitter.

## Combinations

KQ Combination of 11, 15, and 16

# Rosemount 3051

#### Rev 1.11

## **European Directive Information**

A copy of the EU Declaration of Conformity can be found at the end of the Quick Start Guide. The most recent revision of the EU Declaration of Conformity can be found at <u>Emerson.com/Rosemount</u>.

## **Ordinary Location Certification**

As standard, the transmitter has been examined and tested to determine that the design meets the basic electrical, mechanical, and fire protection requirements by a nationally recognized test laboratory (NRTL) as accredited by the Federal Occupational Safety and Health Administration (OSHA).

## **North America**

- E5 USA Explosionproof (XP) and Dust-Ignitionproof (DIP) Range 1-5
  - Certificate: FM16US0121 Standards: FM Class 3600 - 2011, FM Class 3615 - 2006,
  - FM Class 3810 2005, ANSI/NEMA 250 2003 Markings: XP CL I, DIV 1, GP B, C, D; DIP CL II, DIV 1, GP E, F, G; CL III; T5(−50 °C ≤  $T_a$  ≤ +85 °C); Factory Sealed; Type 4X

Range 6

- Certificate: 1053834
- Standards: ANSI/ISA 12.27.01-2003, CSA Std. C22.2 No. 30 -M1986, CSA Std. C22.2 No.142-M1987, CSA Std. C22.2 No. 213 - M1987
- Markings: XP Class I, Division 1, Groups B, C and D, T5,  $(-50 \degree C \le T_a \le +85 \degree C)$  Suitable for Class I, Zone 1, Group IIB+H2, T5; DIP Class II and Class III, Division 1, Groups E, F and G, T5,  $(-50 \degree C \le T_a \le +85 \degree C)$ ; Type 4X; Factory Sealed; Single Seal (See drawing 03031-1053)
- **I5** FM Intrinsic Safety (IS) and Nonincendive (NI)
  - Range 1–5
  - Certificate: FM16US0120X
  - Standards: FM Class 3600 2011, FM Class 3610 2010, FM Class 3611 - 2004, FM Class 3810 - 2005, ANSI/NEMA 250 - 2008

 $\label{eq:markings: IS CL I, DIV 1, GP A, B, C, D; CL II, DIV 1, GP E, F, G; Class III; DIV 1 when connected per Rosemount drawing 03031-1019; NI CL 1, DIV 2, GP A, B, C, D; T4(-50 °C <math>\leq T_a \leq +70 °C$ ) [HART], T5(-50 °C  $\leq T_a \leq +40 °C$ ) [HART]; T4(-50 °C  $\leq T_a \leq +60 °C$ ) [Fieldbus/PROFIBUS];

- Type 4X
- ijpe in

#### Special Conditions for Safe Use (X):

- 1. The Rosemount 3051 Transmitter housing contains aluminum and is considered a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact and friction.
- 2. The Rosemount 3051 Transmitter with the transient terminal block (option code T1) will not pass the 500 Vrms dielectric strength test and this must be taken into account during installation.

#### Range 6

Certificate: 1053834

- Standards: ANSI/ISA 12.27.01-2003, CSA Std. C22.2 No.142-M1987, CSA Std. C22.2. No.157-92
- Markings: IS Class I, II, III, Division 1 Groups A, B, C, D, E, F, and G when connected in accordance with Rosemount drawing 03031-1024, Suitable for Class I, Zone 0 Group IIC; Class I, Division 2, Groups A, B, C and D; NIFW; Suitable for Class I Zone 2, Group IIC; HART: T4 ( $-60 \degree C \le T_a \le 70 \degree C$ ); T5 ( $-60 \degree C \le T_a \le 40 \degree C$ ) Fieldbus/PROFIBUS: T4 ( $-60 \degree C \le T_a \le 60 \degree C$ ) Type 4X; Factory Sealed; Single Seal (See drawing 03031-1053)

## IE USA FISCO

Range 1-5	
Certificate:	FM16US0120X
Standards:	FM Class 3600 - 2011, FM Class 3610 - 2010,
	FM Class 3611 - 2004, FM Class 3810 - 2005
Markings:	IS CL I, DIV 1, GP A, B, C, D when connected
	per Rosemount drawing 03031-1019
	$(-50 \text{ °C} \le \text{T}_{a} \le +60 \text{ °C})$ ; Type 4X

#### Special Conditions for Safe Use (X):

- 1. The Rosemount 3051 Transmitter housing contains aluminum and is considered a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact and friction.
- 2. The Rosemount 3051 Transmitter with the transient terminal block (option code T1) will not pass the 500 Vrms dielectric strength test and this must be taken into account during installation.

Range 6

Certificate: 1053834

- Standards: ANSI/ISA 12.27.01-2003, CSA Std. C22.2 No.142-M1987, CSA Std. C22.2. No.157-92
- $\begin{array}{ll} \text{Markings:} & \text{IS Class I, Division 1 Groups A, B, C, D, T4} \\ (-60 \ ^\circ\text{C} \leq \text{T}_a \leq +60 \ ^\circ\text{C}) \text{ when connected in} \\ & \text{accordance with Rosemount drawing} \\ & 03031-1024, \text{Suitable for Class I, Zone 0} \\ & \text{Group IIC; Type 4X; Factory Sealed; Single} \\ & \text{Seal (See drawing 03031-1053)} \end{array}$
- **C6** Canada Explosionproof, Dust-Ignitionproof, Intrinsic Safety and Nonincendive Certificate: 1053834

- Standards: ANSI/ISA 12.27.01-2003, CSA Std. C22.2 No. 30 -M1986, CSA Std. C22.2 No.142-M1987, CSA Std. C22.2. No.157-92, CSA Std. C22.2 No. 213 - M1987
- Markings: Explosionproof for Class I, Division 1, Groups B, C and D; Suitable for Class I, Zone 1, Group IIB+H2, T5 ( $-50 \degree C \le T_a \le 85 \degree C$ ); Dust-Ignitionproof Class II, III, Division 1, Groups E, F, G, T5 ( $-50 \degree C \le T_a \le 85 \degree C$ ); Class III Division 1; Intrinsically Safe Class I, Division 1 Groups A, B, C, D when connected in accordance with Rosemount drawing 03031-1024, Temperature Code T4; Suitable for Class I, Zone 0; Class I Division 2 Groups A, B, C and D, T5 ( $-50 \degree C \le T_a \le 85 \degree C$ ); Suitable for Class I Zone 2, Group IIC; Type 4X; Factory Sealed; Single Seal (See drawing 03031-1053)
- **E6** Canada Explosionproof, Dust-Ignitionproof and Division 2 Certificate: 1053834
  - Standards: ANSI/ISA 12.27.01-2003, CSA Std. C22.2 No. 30 -M1986, CSA Std. C22.2 No.142-M1987, CSA Std. C22.2 No. 213 - M1987

Markings: Explosionproof Class I, Division 1, Groups B, C and D; Suitable for Class I, Zone 1, Group IIB+H2, T5( $-50^{\circ}C \le T_a \le 85^{\circ}C$ ); Dust-Ignitionproof for Class II and Class III, Division 1, Groups E, F and G; T5 ( $-50^{\circ}C \le T_a \le 85^{\circ}C$ ); Class I, Division 2, Groups A, B, C and D; T5 ( $-50^{\circ}C \le T_a \le 85^{\circ}C$ ); Suitable for Class I Zone 2, Group IIC; Type 4X; Factory Sealed; Single Seal (See drawing 03031-1053)

## Europe

**E8** ATEX Flameproof and Dust

Certificate:	KEMA00ATEX2013X; Baseefa11ATEX0275X
Standards:	EN60079-0:2012 + A11:2013,
	EN60079-1:2014, EN60079-26:2015,
	EN60079-31:2009
Markings:	ⓑ Ⅱ ¹/₂ G Ex db IIC T6T4 Ga/Gb, T6
-	$(-60 \text{ °C} \le \text{T}_a \le +70 \text{ °C}),$
	$T4/T5(-60^{\circ}C \le T_a \le +80^{\circ}C);$
	Ex II 1 D Ex ta IIIC T95 °C T ₅₀₀ 105 °C Da
	$(-20 ^{\circ}\text{C} \le \text{T}_a \le +85 ^{\circ}\text{C})$

#### Table 58. Process Temperature

Temperature class	Process temperature
T6	–60 to +65 °C
T5	–60 to +80 °C
T4	–60 to +120 °C

#### Special Conditions for Safe Use (X):

- 1. This device contains a thin wall diaphragm. Installation, maintenance and use shall take into account the environmental conditions to which the diaphragm will be subjected. The manufacturer's instructions for installation and maintenance shall be followed in detail to assure safety during its expected lifetime.
- 2. Flameproof joints are not intended for repair.
- 3. Non-standard paint options may cause risk from electrostatic discharge. Avoid installations that could cause electrostatic build-up on painted surfaces, and only clean the painted surfaces with a damp cloth. If paint is ordered through a special option code, contact the manufacturer for more information.
- 4. Some variants of the equipment have reduced markings on the nameplate. Refer to the Certificate for full equipment marking.

#### Table 59. Input Parameters

Parameter HART Fieldbus/PROFIE		Fieldbus/PROFIBUS
Voltage U _i	30 V	30 V
Current I _i	200 mA	300 mA
Power P _i	0.9 W	1.3 W
Capacitance C _i	0.012 μF	0 μF
Inductance L _i	0 mH	0 mH

#### Special Conditions for Safe Use (X):

- 1. The apparatus is not capable of withstanding the 500 V insulation test required by clause 6.3.12 of EN60079-11:2012. This must be taken into account when installing the apparatus.
- 2. The enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however care should be taken to protect it from impact or abrasion if located in Zone 0.
- 3. Some variants of the equipment have reduced markings on the nameplate. Refer to the Certificate for full equipment marking.

IA ATEX FISCO

Certificate: BAS97ATEX1089X Standards: EN60079-0:2012, EN60079-11:2009 Markings: Ex II 1 G Ex ia IIC T4 Ga  $(-60 \ ^{\circ}C \le T_a \le +60 \ ^{\circ}C)$ 

## Table 60. Input Parameters

Parameters	FISCO
Voltage U _i	17.5 V
Current l _i	380 mA
Power P _i	5.32 W
Capacitance C _i	<5 nF
Inductance L _i	<10 µH

## Special Conditions for Safe Use (X):

- 1. The apparatus is not capable of withstanding the 500 V insulation test required by clause 6.3.12 of EN60079-11:2012. This must be taken into account when installing the apparatus.
- 2. The enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however care should be taken to protect it from impact or abrasion if located in Zone 0.
- **N1** ATEX Type n and Dust

Certificate:	BAS00ATEX3105X; Baseefa11ATEX0275X
Standards:	EN60079-0:2012, EN60079-15:2010,
	EN60079-31:2009
Markings:	Ex II 3 G Ex nA IIC T5 Gc
-	$(-40 \text{ °C} \le T_a \le +70 \text{ °C})$ ; Ex II 1 D Ex ta IIIC
	T95 °C T ₅₀₀ 105 °C Da ( $-20$ °C $\le$ T _a $\le$ +85 °C)

## Special Conditions for Safe Use (X):

- 1. This apparatus is not capable of withstanding the 500 V insulation test that is required by clause 6.8.1 of EN60079-15. This must be taken into account when installing the apparatus.
- 2. Some variants of the equipment have reduced markings on the nameplate. Refer to the Certificate for full equipment marking.

## International

**E7** IECEx Flameproof and Dust

Certificate:	IECEx KEM 09.0034X; IECEx BAS 10.0034X
Standards:	IEC60079-0:2011, IEC60079-1:2014-06,
	IEC60079-26:2014-10,IEC60079-31:2008
Markings:	Ex db IIC T6T4 Ga/Gb,
-	$T_{6}(-60 \text{ °C} \le T_{a} \le +70 \text{ °C}),$
	T4/T5(-60 °C $\leq$ T _a $\leq$ +80 °C);
	Ex ta IIIC T95 °C T ₅₀₀ 105 °C Da
	(-20 °C ≤ T ₃ ≤ +85 °C)

#### Table 61. Process temperature

Temperature class	Process temperature
Т6	–60 °C to +70 °C
T5	–60 °C to +80 °C
T4	–60 °C to +80 °C

## Special Conditions for Safe Use (X):

- 1. This device contains a thin wall diaphragm. Installation, maintenance and use shall take into account the environmental conditions to which the diaphragm will be subjected. The manufacturer's instructions for installation and maintenance shall be followed in detail to assure safety during its expected lifetime.
- 2. Flameproof joints are not intended for repair.
- 3. Non-standard paint options may cause risk from electrostatic discharge. Avoid installations that could cause electrostatic build-up on painted surfaces, and only clean the painted surfaces with a damp cloth. If paint is ordered through a special option code, contact the manufacturer for more information.
- 4. Some variants of the equipment have reduced markings on the nameplate. Refer to the Certificate for full equipment marking.
- 17 IECEx Intrinsic Safety

Certificate:	IECEx BAS 09.0076X
Standards:	IEC60079-0:2011, IEC60079-11:2011
Markings:	HART: Ex ia IIC T5/T4 Ga,
	T5(-60 °C $\le$ T _a $\le$ +40 °C),
	$T4(-60 \degree C \le T_a \le +70 \degree C)$
	Fieldbus/PROFIBUS: Ex ia IIC
	$T4(-60 \degree C \le T_a \le +60 \degree C)$

#### Table 62. Input Parameters

Parameter	HART	Fieldbus/PROFIBUS	
Voltage U _i 30 V		30 V	
Current l _i	200 mA	A 300 mA	
Power P _i 0.9 W		1.3 W	
Capacitance C _i	0.012 μF	0 μF	
Inductance L _i	0 mH	0 mH	

#### Special Conditions for Safe Use (X):

- If the apparatus is fitted with an optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test required by clause 6.3.12 of IEC60079-11. This must be taken into account when installing the apparatus.
- 2. The enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in Zone 0.

 $\begin{array}{ll} \mbox{IECEx Mining (Special A0259)} \\ \mbox{Certificate:} & \mbox{IECEx TSA 14.0001X} \\ \mbox{Standards:} & \mbox{IEC60079-0:2011, IEC60079-11:2011} \\ \mbox{Markings:} & \mbox{Ex ia I Ma (} -60 \ ^{\circ}\mbox{C} \leq \mbox{T}_a \leq +70 \ ^{\circ}\mbox{C}) \\ \end{array}$ 

#### Table 63. Input Parameters

Parameter	HART	Fieldbus/ PROFIBUS	FISCO
Voltage U _i	30 V	30 V	17.5 V
Current I _i	200 mA	300 mA	380 mA
Power P _i	0.9 W	1.3 W	5.32 W
Capacitance C _i	0.012 μF	0 μF	<5 nF
Inductance L _i	0 mH	0 mH	<10 μH

#### Special Conditions for Safe Use (X):

- 1. If the apparatus is fitted with an optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test required by IEC60079-11. This must be taken into account when installing the apparatus.
- 2. It is a condition of safe use that the above input parameters shall be taken into account during installation.
- 3. It is a condition of manufacture that only the apparatus fitted with housing, covers and sensor module housing made out of stainless steel are used in Group I applications.
- **N7** IECEx Type n Certificate: IECEx BAS 09.0077X Standards: IEC60079-0:2011, IEC60079-15:2010 Markings: Ex nA IIC T5 Gc ( $-40 \text{ °C} \le T_a \le +70 \text{ °C}$ )

#### Special Condition for Safe Use (X):

1. The apparatus is not capable of withstanding the 500 V insulation test required by IEC60079-15. This must be taken into account when installing the apparatus.

#### Brazil

- **E2** INMETRO Flameproof
  - Certificate: UL-BR 13.0643X
    - Standards: ABNT NBR IEC60079-0:2008 + Errata 1:2011, ABNT NBR IEC60079-1:2009 + Errata 1:2011, ABNT NBR IEC60079-26:2008 + Errata 1:2008 Markings: Ex db IIC T6...T4 Ga/Gb,

T6(-60 °C  $\leq$  T_a  $\leq$  +70 °C), T4/T5(-60 °C  $\leq$  T_a  $\leq$  +80 °C)

#### Special Conditions for Safe Use (X):

- 1. This device contains a thin wall diaphragm less than 1 mm thickness that forms a boundary between zone 0 (process connection) and zone 1 (all other parts of the equipment). The model code and datasheet are to be consulted for details of the diaphragm material. Installation, maintenance and use shall take into account the environmental conditions to which the diaphragm will be subjected. The manufacturer's instructions for installation and maintenance shall be followed in detail to assure safety during its expected lifetime.
- 2. Flameproof joints are not intended for repair.
- 3. Non-standard paint options may cause risk from electrostatic discharge. Avoid installations that could cause electrostatic build-up on painted surfaces, and only clean the painted surfaces with a damp cloth. If paint is ordered through a special option code, contact the manufacturer for more information.
- I2 INMETRO Intrinsic Safety Certificate: UL-BR 13.0584X Standards: ABNT NBR IEC60079-0:2008 + Errata 1:2011, ABNT NBR IEC60079-11:2009
  - Markings: HART: Ex ia IIC T5/T4 Ga, T5(-60 °C  $\leq$  T_a  $\leq$  +40°C), T4(-60 °C  $\leq$  T_a  $\leq$  +70 °C) Fieldbus/PROFIBUS: Ex ia IIC T4 Ga (-60 °C  $\leq$  T_a  $\leq$  +60 °C)

#### Table 64. Input Parameters

Parameter	HART	Fieldbus/PROFIBUS	
Voltage U _i 30 V         30 V		30 V	
Current l _i	200 mA	300 mA	
<b>Power P_i</b> 0.9 W 1.3 W		1.3 W	
Capacitance C _i	0.012 μF	0 μF	
Inductance L _i	0 mH	0 mH	

#### Special Conditions for Safe Use (X):

IB

- 1. If the equipment is fitted with an optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test required by ABNT NBR IRC 60079-11. This must be taken into account when installing the equipment.
- 2. The enclosure may be made of aluminum alloy and given protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if equipment requires EPL Ga.

INMETRO FISCO Certificate: UL-BR 13.0584X Standards: ABNT NBR IEC60079-0:2008 + Errata 1:2011, ABNT NBR IEC60079-11:2009 Markings: Ex ia IIC T4 Ga (-60 °C  $\leq T_a \leq +60$  °C)

# **Rosemount DP Level**

#### Table 65. Input Parameters

Parameters	FISCO
Voltage U _i	17.5 V
Current l _i	380 mA
Power P _i	5.32 W
Capacitance C _i	<5 nF
Inductance L _i	<10 µH

#### Special Conditions for Safe Use (X):

- 1. If the equipment is fitted with an optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test required by ABNT NBR IEC 60079-11. This must be taken into account when installing the equipment.
- 2. The enclosure may be made of aluminum alloy and given protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if equipment requires EPL Ga.

## China

#### Special Conditions for Safe Use (X):

1. The relation between ambient temperature arrange and temperature class is as follows:

Ta	Temperature class
−50 °C~ +80 °C	T5
−50 °C~ +65 °C	T6

When used in a combustible dust environment, the maximum ambient temperature is 80 °C.

- 2. The earth connection facility in the enclosure should be connected reliably.
- 3. Cable entry certified by notified body with type of protection Ex d IIC in accordance with GB3836.1-2000 and GB3836.2-2000, should be applied when installed in a hazardous location. When used in combustible dust environment, cable entry in accordance with IP66 or higher level should be applied.
- 4. Obey the warning "Keep tight when the circuit is alive."
- 5. End users are not permitted to change any internal components.

- During installation, use and maintenance of this product, observe the following standards: GB3836.13-1997, GB3836.15-2000, GB3836.16-2006, GB50257-1996, GB12476.2-2006, GB15577-2007
- I3 China Intrinsic Safety

Certificate:	GYJ13.1362X; GYJ15.1367X [Flowmeters]
Standards:	GB3836.1-2010, GB3836.4-2010,
	GB3836.20-2010, GB12476.1-2000
Markings:	Ex ia IIC Ga T4/T5

#### Special Conditions for Safe Use (X):

- 1. Symbol "X" is used to denote specific conditions of use:
  - a. If the apparatus is fitted with an optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test for one minute. This must be taken into account when installing the apparatus.
  - b. The enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in Zone 0.
- 2. The relation between T code and ambient temperature range is:

Model	T code	Temperature range
HART	T5	$-60 \degree C \le T_a \le +40 \degree C$
HART	T4	$-60 ^{\circ}\text{C} \le T_a \le +70 ^{\circ}\text{C}$
Fieldbus/PROFIBUS/ FISCO	T4	$-60 \degree C \le T_a \le +60 \degree C$

3.	Intrinsical	Ily Safe parameters:	:

Parameter	HART	Fieldbus/ PROFIBUS	FISCO
Voltage U _i	30 V	30 V	17.5 V
Current l _i	200 mA	300 mA	380 mA
Power P _i	0.9 W	1.3 W	5.32 W
Capacitance C _i	0.012 μF	0 μF	<5 nF
Inductance L _i	0 mH	0 mH	<10 μH

#### Note

FISCO parameters apply to both Group IIC and IIB.

[For Flowmeters] When Rosemount 644 Temperature Transmitter is used, the Rosemount 644 Transmitter should be used with Ex-certified associated apparatus to establish explosion protection system that can be used in explosive gas atmospheres. Wiring and terminals should comply with the instruction manual of both Rosemount 644 Transmitter and associated apparatus. The cables between Rosemount 644 Transmitter and associated apparatus should be shielded cables (the cables must have insulated shield). The shielded cable has to be grounded reliably in a non-hazardous area.

- 4. Transmitters comply with the requirements for FISCO field devices specified in IEC60079-27:2008. For the connection of an intrinsically safe circuit in accordance with FISCO Model, FISCO parameters are listed in Table 65 on page 156.
- 5. The product should be used with Ex-certified associated apparatus to establish explosion protection system that can be used in explosive gas atmospheres. Wiring and terminals should comply with the instruction manual of the product and associated apparatus.
- 6. The cables between this product and associated apparatus should be shielded cables (the cables must have insulated shield). The shielded cable has to be grounded reliably in a non-hazardous area.
- 7. End users are not permitted to change any intern components but to settle the problem in conjunction with the manufacturer to avoid damage to the product.
- During installation, use and maintenance of this product, observe the following standards: GB3836.13-1997, GB3836.15-2000, GB3836.16-2006, GB50257-1996, GB12476.2-2006, GB15577-2007
- N3 China Type n Certificate: GYJ15.1105X Standards: GB3836.1-2010, GB3836.8-2003 Markings: Ex nA nL IIC T5 Gc (-40 °C ≤ T_a ≤ +70 °C)

#### Special Condition for Safe Use (X):

 Symbol "X" is used to denote specific conditions of use: The apparatus is not capable of withstanding the 500 V test to earth for one minute. The must be taken into consideration during installation.

## Japan

E4 Japan Flameproof Certificate: TC20577, TC20578, TC20583, TC20584 [HART]; TC20579, TC20580, TC20581, TC20582 [Fieldbus] Markings: Ex d IIC T5

## **Republic of Korea**

- **EP** Republic of Korea Flameproof Certificate: 11-KB4BO-0188X [Mfg Singapore] Markings: Ex d IIC T6...T4
- IP Republic of Korea Intrinsic Safety Certificate: 13-KB4BO-0203X [HART - Mfg USA], 13-KB4BO-0204X [Fieldbus - Mfg USA], 10-KB4BO-0138X [HART - Mfg Singapore], 13-KB4BO-0206X [Fieldbus - Mfg Singapore]
  - Markings: Ex ia IIC T5/T4 (HART) Ex ia IIC T4 (Fieldbus)

## **Technical Regulations Customs Union (EAC)**

- **EM** EAC Flameproof
  - Markings: Ga/Gb Ex db IIC T4...T6 X, T4/T5(-60 °C  $\leq$  T_a  $\leq$  +80 °C), T6(-60 °C  $\leq$  T_a  $\leq$  +70 °C)

## Special Condition for Safe Use (X):

- 1. See certificate for special conditions.
- IM EAC Intrinsically Safe
  - Markings: HART: 0Ex ia IIC T4/T5 Ga X, T4(-60 °C  $\leq$  T_a  $\leq$  +70 °C), T5(-60 °C  $\leq$  T_a  $\leq$  +40 °C) Fieldbus/PROFIBUS: 0Ex ia IIC T4 Ga X (-60 °C  $\leq$  T_a  $\leq$  +60 °C)

## Special Condition for Safe Use (X):

1. See certificate for special conditions.

## Combinations

- K2 Combination of E2 and I2
- **K5** Combination of E5 and I5
- K6 Combination of C6, E8, and I1
- **K7** Combination of E7, I7, and N7
- **K8** Combination of E8, I1, and N1
- **KB** Combination of E5, I5, and C6
- **KD** Combination of E8, I1, E5, I5, and C6
- **KM** Combination of EM and IM
- **KP** Combination of EP and IP

Markings:

## **Conduit plugs and adapters**

<b>IECEx Flame</b>	proof and Increased Safety
Certificate:	IECEx FMG 13.0032X
Standards:	IEC60079-0:2011, IEC60079-1:2007,
	IEC60079-7:2006-2007
Markings:	Ex de IIC Gb
ATEX Flame	proof and Increased Safety
Certificate:	FM13ATEX0076X
Standards:	EN60079-0:2012, EN60079-1:2007,
	IEC60079-7:2007

Ex II 2 G Ex de IIC Gb

Table 66.	Conduit	Plug	Thread	Sizes
-----------	---------	------	--------	-------

Thread	Identification mark
M20 × 1.5	M20
¹ /2 –14 NPT	1/2 NPT

Table 67. Thread Adapter Thread Sizes

Male Thread	Identification mark
M20 × 1.5 – 6H	M20
¹ /2–14 NPT	¹ /2 – 14 NPT
³ /4 – 14 NPT	³ /4–14 NPT
Female Thread	Identification mark
<b>Female Thread</b> M20 × 1.5 – 6H	Identification mark M20
<b>Female Thread</b> M20 × 1.5 – 6H ¹ /2–14 NPT	Identification mark M20 1/2-14 NPT

## Special Conditions for Safe Use (X):

- 1. When the thread adapter or blanking plug is used with an enclosure in type of protection increased safety "e" the entry thread shall be suitably sealed in order to maintain the ingress protection rating (IP) of the enclosure.
- 2. The blanking plug shall not be used with an adapter.
- 3. Blanking Plug and Threaded Adapter shall be either NPT or Metric thread forms. G¹/₂ thread forms are only acceptable for existing (legacy) equipment installations.

## **Additional Certifications**

SBS	American Burea Certificate: Intended Use:	au of Shipping (ABS) Type Approval 09-HS446883A-5-PDA Marine & Offshore Applications - Measurement of either gauge or absolute pressure for liquid, gas and vapor.
SBV	Bureau Veritas ( Certificate:	(BV) Type Approval
	Requirements:	Bureau Veritas Rules for the
		Classification of Steel Ships
	Application:	Class notations: AUT-UMS, AUT-CCS,
		AUT-PORT and AUT-IMS; Pressure
		transmitter type 3051 cannot be
		installed on diesel engines

SDNDet Norske Veritas (DNV) Type Approval<br/>Certificate:TAA000004FIntended Use:DNV GL Rules for Classification - Ships<br/>and offshore units

## Application:

Location Classes		
Temperature	D	
Humidity	В	
Vibration	А	
EMC	В	
Enclosure	D	

- SLLLloyds Register (LR) Type Approval<br/>Certificate:Application:11/60002<br/>Environmental categories ENV1, ENV2,<br/>ENV3, and ENV5
- C5 Custody Transfer Measurement Canada Accuracy Approval Certificate: AG-0226; AG-0454; AG-0477

# Rosemount 2051

#### Rev 1.6

## **European Directive Information**

A copy of the EU Declaration of Conformity can be found at the end of the Quick Start Guide. The most recent revision of the EU Declaration of Conformity can be found at <u>Emerson.com/Rosemount.</u>

## **Ordinary Location Certification**

As standard, the transmitter has been examined and tested to determine that the design meets the basic electrical, mechanical, and fire protection requirements by a nationally recognized test laboratory (NRTL) as accredited by the Federal Occupational Safety and Health Administration (OSHA).

## **North America**

- **E5** USA Explosionproof (XP) and Dust-Ignitionproof (DIP) Certificate: FM16US0232
  - Standards: FM Class 3600 2011, FM Class 3615 2006, FM Class 3616 – 2011, FM Class 3810 – 2005, ANSI/NEMA 250 –2008. ANSI/IEC 60529 2004
  - Markings: XP CL I, DIV 1, GP B, C, D; DIP CL II, DIV 1, GP E, F, G; CL III; T5( $-50 \degree C \le T_a \le +85 \degree C$ ); Factory Sealed; Type 4X
- IS USA Intrinsic Safety (IS) and Nonincendive (NI) Certificate: FM16US0231X
  - Standards: FM Class 3600 2011, FM Class 3610 2010, FM Class 3611 – 2004, FM Class 3810 – 2005, ANSI/NEMA 250 –2008
  - Markings: IS CL I, DIV 1, GP A, B, C, D; CL II, DIV 1, GP E, F, G; Class III; DIV 1 when connected per Rosemount drawing 02051-1009; Class I, Zone 0; AEx ia IIC T4; NI CL 1, DIV 2, GP A, B, C, D; T4(-50 °C  $\leq$  T_a  $\leq$ +70 °C); Type 4X

#### Specific Condition of Use:

1. The Model 2051 transmitter housing contains aluminum and is considered a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact and friction.

IE USA FISCO

Certificate: FM16US0231X

- Standards: FM Class 3600 2011, FM Class 3610 2010, FM Class 3611 – 2004, FM Class 3810 – 2005
- Markings: IS CL I, DIV 1, GP A, B, C, D when connected per Rosemount drawing 02051-1009  $(-50 \degree C \le T_a \le +60 \degree C)$ ; Type 4X

- 1. The Model 2051 transmitter housing contains aluminum and is considered a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact and friction.
- **E6** Canada Explosion-Proof, Dust Ignition Proof Certificate: 2041384

Standards: CAN/CSA C22.2 No. 0-10, CSA Std C22.2 No. 25-1966, CSA Std C22.2 No. 30-M1986, CAN/CSA-C22.2 No. 94-M91, CSA Std C22.2 No.142-M1987, CAN/CSA-C22.2 No.157-92, CSA Std C22.2 No. 213-M1987, CAN/CSA-E60079-0:07, CAN/CSA-E60079-1:07, CAN/CSA-E60079-11-02, CAN/CSA-C22.2 No. 60529:05, ANSI/ISA-12.27.01–2003

- Markings: Explosion-Proof for Class I, Divisions 1, Groups B, C, and D. Dust-Ignition Proof for Class II and Class III, Division 1, Groups E, F, and G. Suitable for Class I, Division 2; Groups A, B, C, and D for indoor and outdoor hazardous locations. Class I Zone 1 Ex d IIC T5. Enclosure type 4X, factory sealed. Single Seal
- I6 Canada Intrinsic Safety Certificate: 2041384
  - Standards: CSA Std. C22.2 No. 142 M1987, CSA Std.C22.2 No. 213 - M1987, CSA Std. C22.2 No.157 - 92, CSA Std. C22.2 No. 213 - M1987, ANSI/ISA 12.27.01 – 2003, CAN/CSA-E60079-0:07, CAN/CSA-E60079-11:02
  - Markings: Intrinsically safe for Class I, Division 1, Groups A,B, C, and D when connected in accordance with Rosemount drawings 02051-1008. Temperature code T3C. Ex ia IIC T3C. Single Seal. Enclosure Type 4X

## Europe

E1 ATEX Flameproof

Certificate: KEMA 08ATEX0090X

Standards: EN 60079-0:2012 + A11:2013,

EN 60079-1:2014, EN 60079-26:2015 Markings: D II 1/2 G Ex db IIC Ga/Gb T6(-60 °C  $\leq$  T_a  $\leq$  +70 °C),

T4/T5 ( $-60^{\circ}C \le T_a \le +80^{\circ}C$ )

Temperature class	Process temperature	Ambient temperature
T6	–60 °C to +70 °C	–60 °C to +70 °C
T5	–60 °C to +80 °C	–60 °C to +80 °C
T4	–60 °C to +120 °C	–60 °C to +80 °C

- 1. Appropriate cable, glands and plugs need to be suitable for a temperature of 5 °C greater than maximum specified temperature for location where installed.
- 2. Non- standard paint options may cause risk from electrostatic discharge. Avoid installations that could cause electrostatic build-up on painted surfaces, and only clean the painted surfaces with a damp cloth. If paint is ordered through a special option code, contact the manufacturer for more information.
- 3. The device contains a thin wall diaphragm less than 1 mm thickness that forms a boundary between zone 0 (process connection) and zone 1 (all other parts of the equipment). The model code and datasheet are to be consulted for details of the diaphragm material. Installation, maintenance and use shall take into account the environmental conditions to which the diaphragm shall be subjected. The manufacturer's instructions for installation and maintenance shall be followed in detail to assure safety during its expected lifetime.
- 4. Flameproof joints are not intended for repair.
- ATEX Intrinsic Safety Certificate: Baseefa08ATEX0129X Standards: EN60079-0:2012, EN60079-11:2012 Markings: O II 1 G Ex ia IIC T4 Ga (-60 °C  $\leq$  T_a  $\leq$  +70 °C)

#### Table 68. Input Parameters

11

Parameters	HART	Fieldbus/PROFIBUS
Voltage U _i	30 V	30 V
Current l _i	200 mA	300 mA
Power P _i	1.0 W	1.3 W
Capacitance C _i	0.012 μF	0 μF
Inductance L _i	0 mH	0 mH

#### Special Conditions for Safe Use (X):

- 1. If the equipment is fitted with an optional 90 V transient suppressor, it is incapable of withstanding the 500 V isolation from earth test and this must be taken into account during installation.
- 2. The enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however care should be taken to protect it from impact and abrasion when located in Zone 0.
- $\begin{array}{ll} \textbf{IA} & \text{ATEX FISCO} \\ & \text{Certificate: Baseefa08ATEX0129X} \\ & \text{Standards: EN60079-0:2012, EN60079-11:2012} \\ & \text{Markings: } \textcircled{} II 1 G Ex ia IIC T4 Ga (-60 \ ^{\circ}C \leq T_a \leq +60 \ ^{\circ}C) \\ \end{array}$

#### Table 69. Input Parameters

Parameters	FISCO
Voltage U _i	17.5 V
Current l _i	380 mA

#### Table 69. Input Parameters

Power P _i	5.32 W
Capacitance C _i	0 μF
Inductance L _i	0 mH

#### Special Conditions for Safe Use (X):

- 1. If the equipment is fitted with an optional 90V transient suppressor, it is incapable of withstanding the 500V isolation from earth test and this must be taken into account during installation.
- 2. The enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however care should be taken to protect it from impact and abrasion when located in Zone 0.

N1 ATEX Type n

Certification: Baseefa08ATEX0130X Standards: EN60079-0:2012, EN60079-15:2010 Markings: II 3G Ex nA IIC T4 Gc (-40 °C  $\leq$  T_a  $\leq$  +70 °C)

## Special Condition for Safe Use (X):

1. If the equipment is fitted with an optional 90 V transient suppressor, it is incapable of withstanding the 500 V electrical strength test as defined in clause 6.5.1 of by EN 60079-15:2010. This must be taken into account during installation.

#### ND ATEX Dust

## Special Conditions for Safe Use (X):

1. If the equipment is fitted with an optional 90 V transient suppressor, it is incapable of withstanding the 500 V isolation from earth test and this must be taken into account during installation.

## International

**E7** IECEx Flameproof Certificate: IECExKEM08.0024X Standards: IEC 60079-0:2011, IEC 60079-1:2014-06, IEC 60079-26:2014-10 Markings: Ex d IIC T6/T5 IP66, T6(-50 °C  $\leq T_a \leq +65$  °C), T5(-50 °C  $\leq T_a \leq +80$  °C)

#### Table 70. Process temperature

Temperature class	Process temperature	Ambient temperature
Т6	–60 °C to +70 °C	–60 °C to +70 °C
T5	–60 °C to +80 °C	–60 °C to +80 °C
T4	–60 °C to +120 °C	–60 °C to +80 °C

- 1. The device contains a thin wall diaphragm less than 1 mm thickness that forms a boundary between zone 0 (process connection) and zone 1 (all other parts of the equipment). The model code and datasheet are to be consulted for details of the diaphragm material. Installation, maintenance and use shall take into account the environmental conditions to which the diaphragm shall be subjected. The manufacturer's instructions for installation and maintenance shall be followed in detail to assure safety during its expected lifetime.
- 2. Appropriate cable, glands and plugs need to be suitable for a temperature of 5°C greater than maximum specified temperature for location where installed.
- 3. Flameproof joints are not intended for repair.
- 4. Non-standard paint options may cause risk from electrostatic discharge. Avoid installations that could cause electrostatic build-up on painted surfaces, and only clean the painted surfaces with a damp cloth. If paint is ordered through a special option code, contact the manufacturer for more information.
- **17** IECEx Intrinsic Safety Certificate: IECExBAS08.0045X Standards: IEC60079-0:2011, IEC60079-11:2011 Markings: Ex ia IIC T4 Ga ( $-60 \degree C \le T_a \le +70 \degree C$ )

Parameters	HART	Fieldbus/PROFIBUS
Voltage U _i	30 V	30 V
Current l _i	200 mA	300 mA
Power P _i	1.0 W	1.3 W
Capacitance C _i	0.012 μF	0 μF
Inductance L _i	0 mH	0 mH

#### Table 71. Input Parameters

#### Special Conditions for Safe Use (X):

- 1. If the equipment is fitted with an optional 90 V transient suppressor, it is incapable of withstanding the 500 V isolation from earth test and this must be taken into account during installation.
- 2. The enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however care should be taken to protect it from impact and abrasion when located in Zone 0.

IG IECEx FISCO

Certificate: IECExBAS08.0045X Standards: IEC60079-0:2011, IEC60079-11:2011 Markings: Ex ia IIC T4 Ga ( $-60 \degree C \le T_a \le +60 \degree C$ )

#### **Table 72. Input Parameters**

Parameters	FISCO	
Voltage U _i	17.5 V	
Current l _i	380 mA	
Power P _i	5.32 W	
Capacitance C _i	0 μF	
Inductance L _i	0 mH	

#### Special Conditions for Safe Use (X):

- 1. If the equipment is fitted with an optional 90 V transient suppressor, it is incapable of withstanding the 500 V isolation from earth test and this must be taken into account during installation.
- 2. The enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however care should be taken to protect it from impact and abrasion when located in Zone 0.
- N7 IECEx Type n

Certificate: IECExBAS08.0046X Standards: IEC60079-0:2011, IEC60079-15:2010 Markings: Ex nA IIC T4 Gc ( $-40 \degree C \le T_a \le +70 \degree C$ )

## Special Condition for Safe Use (X):

1. If fitted with a 90 V transient suppressor, the equipment is not capable of withstanding the 500 V electrical strength test as defined in clause 6.5.1 of IEC60079-15:2010. This must be taken into account during installation.

## Brazil

- The device contains a thin wall diaphragm less than 1 mm thickness that forms a boundary between zone 0 (process connection) and zone 1 (all other parts of the equipment). The model code and datasheet are to be consulted for details of the diaphragm material. Installation, maintenance and use shall take into account the environmental conditions to which the diaphragm will be subjected. The manufacturer's instructions for maintenance shall be followed in detail to assure safety during its expected lifetime.
- 2. Flameproof joints are not intended for repair.
- 3. Non-standard paint options may cause risk from electrostatic discharge. Avoid installations that could cause electrostatic build-up on painted surfaces, and only clean the painted surfaces with a damp cloth. If paint is ordered through a special option code, contact the manufacturer for more information.
- I2 INMETRO Intrinsic Safety Certificate: UL-BR 14.0759X Standards: ABNT NBR IEC60079-0:2008, +Errata 1:2011 ABNT NBR IEC60079-11:2009 Markings: Ex ia IIC T4 Ga (−60 °C ≤  $T_a$  ≤ +70 °C)

#### Table 73. Input Parameters

Parameters	HART	Fieldbus/PROFIBUS
Voltage U _i	30 V	30 V
Current l _i	200 mA	300 mA
Power P _i	1 W	1.3 W
Capacitance C _i	0.012 μF	0 μF
Inductance L _i	0 mH	0 mH

#### Special Conditions for Safe Use (X):

- If the equipment is fitted with an optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test required by ABNT NBR IRC 60079-11:2008. This must be taken into account when installing the equipment.
- 2. The enclosure may be made of aluminium alloy and given a protective polyurethane paint finish; however care should be taken to protect it from impact and abrasion when located in atmospheres that require ELP Ga.

```
 \begin{array}{ll} \textbf{IB} & \text{INMETRO FISCO} \\ & \text{Certificate: UL-BR 14.0759X} \\ & \text{Standards: ABNT NBR IEC 60079-0:2008 + Errata 1:2011;} \\ & \text{ABNT NBR IEC 60079-11:2009} \\ & \text{Markings: Ex ia IIC T4 Ga} (-60\ ^\circ\text{C} \leq \text{T}_{\text{a}} \leq +60\ ^\circ\text{C}) \\ \end{array}
```

#### Table 74. Input Parameters

	FISCO
Voltage U _i	17.5 V
Current l _i	380 mA
Power P _i	5.32 W
Capacitance C _i	0 μF
Inductance L _i	0 mH

#### Special Conditions for Safe Use (X):

- 1. If the equipment is fitted with an optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test required by ABNT NBR IRC 60079-11:2008. This must be taken into account when installing the equipment.
- 2. The enclosure may be made of aluminium alloy and given a protective polyurethane paint finish; however care should be taken to protect it from impact and abrasion when located in atmospheres that require ELP Ga.

## China

E3 China Flameproof Certificate: GYJ13.1386X Standards: GB3836.1-2010, GB3836.2-2010 Markings: Pressure Transmitter: Ex d IIC Gb, T6(-50 °C  $\leq$  Ta  $\leq$  +65 °C), T5(-50 °C  $\leq$  Ta  $\leq$  +80 °C)

#### Special Conditions for Safe Use (X):

- 1. Symbol "X" is used to denote specific conditions of use:
  - a. The Ex d blanking elements, cable glands, and wiring shall be suitable for a temperature of 90 °C.
  - b. This device contains a thin wall diaphragm. Installation, maintenance and use shall take into account the environment conditions to which the diaphragm will be subjected.
- 2. The relation between T code and ambient temperature range is:

T _a	Temperature class
–50 °C ≤ Ta ≤ +80 °C	Т5
–50 °C ≤ Ta ≤ +65 °C	Т6

- 3. The earth connection facility in the enclosure should be connected reliably.
- 4. During installation, use and maintenance of the product, observe the warning "Don't open the cover when the circuit is alive."
- 5. During installation, there should be no mixture harmful to flameproof housing.
- 6. Cable entry and conduit, certified by NEPSI with type of protection Ex d IIC and appropriate thread form, should be applied when installed in a hazardous location. Blanking elements should be used on the redundant cable entries.

- 7. End users are not permitted to change any internal components, but to settle the problem in conjunction with the manufacturer to avoid damage to the product.
- 8. Maintenance should be done in a non-hazardous location.
- 9. During installation, use and maintenance of this product, observe the following standards: GB3836.13-2013, GB3836.15-2000, GB3836.16-2006, GB50257-2014
- I3 China Intrinsic Safety Certificate: GYJ12.1295X Standards: GB3836.1-2010, GB3836.4-2010, GB3836.20-2010 Markings: Ex ia IIC Ga, T6(-60 °C ≤ Ta ≤ +70 °C)

- 1. Symbol "X" is used to denote specific conditions of use:
  - a. If the apparatus is fitted with an optional 90 V transient suppressor, it is not capable of withstanding the 500 V insulation test for one minute. This must be taken into account when installing the apparatus.
  - b. The enclosure may be made of aluminum alloy and given a protective polyurethane paint finish; however, care should be taken to protect it from impact or abrasion if located in Zone 0.
- 2. The relation between T code and ambient temperature range is:

Model	T Code	Temperature range
HART, Fieldbus, PROFIBUS, and Low Power	T4	$-60 ^{\circ}\text{C} \le \text{T}_a \le +70 ^{\circ}\text{C}$

3. Intrinsically safe parameters:

	HART	Fieldbus/ PROFIBUS	FISCO
Voltage U _i	30 V	30 V	17.5 V
Current l _i	200 mA	300 mA	380 mA
Power P _i	1 W	1.3 W	5.32 W
Capacitance C _i	0.012 μF	0 μF	0 nF
Inductance L _i	0 mH	0 mH	0 μF

#### Note

FISCO parameters comply with the requirements for FISCO field devices in GB3836.19-2010.

[For Flowmeters] When 644 temperature transmitter is used, the 644 temperature transmitter should be used with Ex-certified associated apparatus to establish explosion protection system that can be used in explosive gas atmospheres. Wiring and terminals should comply with the instruction manual of both 644 temperature transmitter and associated apparatus. The cables between 644 temperatures transmitter and associated apparatus should be shielded cables (the cables must have insulated shield). The shielded cable has to be grounded reliably in a non-hazardous area.

- 4. The product should be used with Ex-certified associated apparatus to establish explosion protection system that can be used in explosive gas atmospheres. Wiring and terminals should comply with the instruction manual of the product and associated apparatus.
- 5. The cables between this product and associated apparatus should be shielded cables (the cables must have insulated shield). The shielded cable has to be grounded reliably in a non-hazardous area.
- End users are not permitted to change any internal components, and needs to settle the problem in conjunction with the manufacturer to avoid damage to the product.
- During installation, use and maintenance of this product, observe the following standards: GB3836.13-2013, GB3836.15-2000, GB3836.16-2006, GB3836.18-2010, GB50257-2014.

## Japan

E4 Japan Flameproof

Certificate: TC20598, TC20599, TC20602, TC20603 [HART]; TC20600, TC20601, TC20604, TC20605 [Fieldbus]

Markings: Ex d IIC T5

## **Technical Regulations Customs Union (EAC)**

**EM** EAC Flameproof

Certificate: RU C-US.GB05.B.01199 Markings: Ga/Gb Ex d IIC X, T5(-50 °C  $\leq$  T_a  $\leq$  +80 °C), T6(-50 °C  $\leq$  T_a  $\leq$  +65 °C)

## Special Condition for Safe Use (X):

- 1. See certificate for special conditions.
- IM EAC Intrinsically Safe

Certificate: RU C-US.GB05.B.01199 Markings: 0Ex ia IIC T4 Ga X (-60 °C  $\leq$  T_a  $\leq$  +70 °C)

#### Special Condition for Safe Use (X):

1. See certificate for special conditions.

## Combinations

- K1 Combination of E1, I1, N1, and ND
- K2 Combination of E2 and I2
- **K5** Combination of E5 and I5
- K6 Combination of E6 and I6
- **K7** Combination of E7, I7, N7 and IECEx Dust

IECEx Dust Certificate: IECExBAS08.0058X Standards: IEC60079-0:2011, IEC60079-31:2008 Markings: Ex ta IIIC T95 °C T₅₀₀105 °C Da (-20 °C  $\leq$  Ta  $\leq$  +85 °C)

- 1. If the equipment is fitted with an optional 90 V transient suppressor, it is incapable of withstanding a 500 V isolation from earth test and this must be taken into account during installation.
- KA Combination of E1, I1, and K6
- KB Combination of K5 and K6
- KC Combination of E1, I1, and K5
- **KD** Combination of K1, K5, and K6
- KM Combination of EM and IM

## **Additional Certifications**

- **SBS** American Bureau of Shipping (ABS) Type Approval Certificate: 09-HS446883B-3-PDA
  - Intended Use: Marine and Offshore Applications Measurement of either Gauge or Absolute Pressure for Liquid, Gas, and Vapor.
  - ABS Rules: 2013 Steel Vessels Rules 1-1-4/7.7, 1-1-Appendix 3, 4-8-3/1.7, 4-8-3/13.1
- SBV Bureau Veritas (BV) Type Approval

Certificate: 23157/B0 BV

- BV Rules: Bureau Veritas Rules for the Classification of Steel Ships
- Application: Class notations: AUT-UMS, AUT-CCS, AUT-PORT and AUT-IMS; Pressure transmitter type 2051 cannot be installed on diesel engines.

**SDN** Det Norske Veritas (DNV) Type Approval

Certificate: TAA000004F

Intended Use: DNV GL Rules for Classification -Ships and offshore units

### Application:

Location classes		
Туре	2051	
Temperature	D	
Humidity	В	
Vibration	A	
EMC	В	
Enclosure	D	

SLL Lloyds Register (LR) Type Approval

Certificate: 11/60002

Application: Environmental categories ENV1, ENV2, ENV3 and ENV5

# **Rosemount 3051 Wireless**

Rev 1.4

## **European Directive Information**

A copy of the EU Declaration of Conformity can be found at the end of the Quick Start Guide. The most recent revision of the EU Declaration of Conformity can be found at <u>Emerson.com/Rosemount</u>.

## **Telecommunication compliance**

All wireless devices require certification to ensure that they adhere to regulations regarding the use of the RF spectrum. Nearly every country requires this type of product certification. Emerson is working with governmental agencies around the world to supply fully compliant products and remove the risk of violating country directives or laws governing wireless device usage.

## FCC and IC

This device complies with Part 15 of the FCC Rules. Operation is subject to the following conditions: This device may not cause harmful interference. This device must accept any interference received, including interference that may cause undesired operation. This device must be installed to ensure a minimum antenna separation distance of 20 cm from all persons.

# **Ordinary Location Certification**

As standard, the transmitter has been examined and tested to determine that the design meets the basic electrical, mechanical, and fire protection requirements by a nationally recognized test laboratory (NRTL) as accredited by the Federal Occupational Safety and Health Administration (OSHA).

## **Installing in North America**

The US National Electrical Code (NEC) and the Canadian Electrical Code (CEC) permit the use of Division marked equipment in Zones and Zone marked equipment in Divisions. The markings must be suitable for the area classification, gas, and temperature class. This information is clearly defined in the respective codes.

## USA

IS U.S.A. Intrinsically Safe (IS) Range 1–5 Certificate: FM 3046325 Standards: FM Class 3600 - 2011, FM Class 3610 - 2010, FM Class 3810 - 2005, ANSI/ISA 60079-0 -2009, ANSI/ISA 60079-11 - 2009, NEMA 250 -2003, ANSI/IEC 60529 Markings: IS CL I, DIV 1, GP A, B, C, D T4; CL 1, Zone 0 AEx ia IIC T4; T4(-40 °C  $\leq$  T_a  $\leq$  +70 °C) when installed per Rosemount drawing 03031-1062; Type 4X/IP66/IP68

## Special Conditions for Safe Use (X):

- 1. The Rosemount 3051 Wireless Pressure Transmitter shall only be used with the 701PGNKF Rosemount SmartPower Battery Pack.
- 2. The inline pressure sensor may contain more than 10% aluminum and is considered a potential risk of ignition by impact or friction. Care must be taken into account during installation and used to prevent impact and friction.
- 3. The surface resistivity of the transmitter housing is greater than one gigaohm. To avoid electrostatic charge build-up, it must not be rubbed or cleaned with solvents or a dry cloth.

#### Range 6

Certificate: CSA 2526009

Standards:	FM Class 3600 - 2011, FM Class 3610 - 2010,
	FM Class 3810 - 2005, ANSI/ISA 60079-0 -
	2009, ANSI/ISA 60079-11 - 2009, UL 61010-1
	(3rd edition), UL50E (1st Edition)
Markings:	IS CL I, DIV 1, GP A, B, C, D T4; CL 1, Zone 0 AE

Markings: IS CL I, DIV I, GP A, B, C, D I4; CL I, Zone 0 AEx ia IIC T4; T4(-40  $^{\circ}C \le T_a \le +70 ^{\circ}C$ ) when installed per Rosemount drawing 03031-1063; Type 4X/IP66/IP68

## Canada

**I6** Canada Intrinsically Safe

Certificate: CSA 2526009 Standards: CAN/CSA C22.2 No. 0-M91, CAN/CSA C22.2 No.94-M91, CSA Std C22.2 No. 142-M1987, CSA Std C22.2 No. 157-92, CSA Std C22.2 No. 60529:05

Markings: Intrinsically Safe for Class I, Division 1, Groups A, B, C, D, T4 when installed per Rosemount drawing 03031-1063; Type 4X/IP66/IP68

## Europe

 $\begin{array}{ll} \mbox{ATEX Intrinsic Safety} \\ \mbox{Certificate: Baseefa12ATEX0228X} \\ \mbox{Standards: EN 60079-0: 2012, EN 60079-11: 2012} \\ \mbox{Markings: Ex II 1 G Ex ia IIC T4 Ga, T4(-40 °C \leq T_a \leq +70 °C)} \\ \mbox{IP66/IP68} \end{array}$ 

- 1. The plastic enclosure may constitute a potential electrostatic ignition risk and must not be rubbed or cleaned with a dry cloth.
- 2. The Model 701PGNKF Power Module may be replaced in a hazardous area. The power module has a surface resistivity greater than 1 G $\Omega$  and must be properly installed in the wireless device enclosure. Care must be taken during transportation to and from the point of installation to prevent electrostatic charge build-up.

## International

 $\begin{array}{ll} \mbox{I7} & \mbox{IECEx Intrinsic Safety} \\ & \mbox{Certificate: IECEx BAS 12.0124X} \\ & \mbox{Standards: IEC 60079-0: 2011, IEC 60079-11: 2011} \\ & \mbox{Markings: Ex ia IIC T4 Ga, T4(-40 °C <math display="inline">\leq$  T_a  $\leq$  +70 °C)} \\ & \mbox{IP66/IP68} \\ \end{array}

#### Special Conditions for Safe Use (X):

- 1. The plastic enclosure may constitute a potential electrostatic ignition risk and must not be rubbed or cleaned with a dry cloth.
- 2. The Model 701PGNKF Power Module may be replaced in a hazardous area. The power module has a surface resistivity greater than 1 G $\Omega$  and must be properly installed in the wireless device enclosure. Care must be taken during transportation to and from the point of installation to prevent electrostatic charge build-up.

## Brazil

I2 INMETRO Intrinsic Safety Certificate: UL-BR 13.0534X Standards: ABNT NBR IEC 60079-0:2008 + Errata 1:2011, ABNT NBR IEC 60079-11:2009 Markings: Ex ia IIC T4 IP66 Ga, T4(-40 °C  $\leq T_a \leq +70$  °C)

## Special Condition for Safe Use (X):

1. See certificate for special conditions.

## China

 I3 China Intrinsic Safety Certificate: GYJ13.1362X, GYJ15.1367X [Flowmeters] Standards: GB3836.1-2010, GB3836.4-2010, GB3836.20-2010 Markings: Ex ia IIC T4 Ga, T4(-40 ~ +70 °C)

## Special Condition for Safe Use (X):

1. See certificate for special conditions.

## Japan

```
I4 TIIS Intrinsic Safety
Certificate: TC22022X (Rosemount 3051C/L), TC22023X
(Rosemount 3051T), TC22024X (Rosemount 3051CFx)
Markings: Ex ia IIC T4 Ga, T4(-20 \le T_a \le +60 °C)
```

## Special Condition for Safe Use (X):

1. See certificate for special conditions.

## EAC - Belarus, Kazakhstan, Russia

IMTechnical Regulation Customs Union (EAC) Intrinsic Safety<br/>Certificate: TU RU C-US.AA87.B.00534<br/>Markings: 0Ex ia IIC T4 Ga X;  $(-40 \degree C \le T_a \le +70 \degree C)$ 

## Special Condition for Safe Use (X):

1. See certificate for special conditions.

## Korea

 $\begin{array}{ll} \textbf{IP} & \text{Korea Intrinsic Safety} \\ & \text{Certificate: 13-KB4BO-0295X} \\ & \text{Markings: Ex ia IIC T4 (-40 \ ^{\circ}\text{C} \leq \text{T}_{a} \leq +70 \ ^{\circ}\text{C}) \end{array} \end{array}$ 

#### Special Condition for Safe Use (X):

1. See certificate for special conditions.

# **Rosemount 2051 Wireless**

Rev 1.3

## **European Directive Information**

A copy of the EC Declaration of Conformity can be found at the end of the Quick Start Guide. The most recent revision of the EC Declaration of Conformity can be found at Emerson.com/Rosemount.

## **Telecommunication compliance**

All wireless devices require certification to ensure that they adhere to regulations regarding the use of the RF spectrum. Nearly every country requires this type of product certification. Emerson is working with governmental agencies around the world to supply fully compliant products and remove the risk of violating country directives or laws governing wireless device usage.

## FCC and IC

This device complies with Part 15 of the FCC Rules. Operation is subject to the following conditions: This device may not cause harmful interference. This device must accept any interference received, including interference that may cause undesired operation. This device must be installed to ensure a minimum antenna separation distance of 20 cm from all persons.

## **Ordinary Location Certification**

As standard, the transmitter has been examined and tested to determine that the design meets the basic electrical, mechanical, and fire protection requirements by a nationally recognized test laboratory (NRTL) as accredited by the Federal Occupational Safety and Health Administration (OSHA).

## **Installing in North America**

The US National Electrical Code (NEC) and the Canadian Electrical Code (CEC) permit the use of Division marked equipment in Zones and Zone marked equipment in Divisions. The markings must be suitable for the area Classification, gas, and temperature Class. This information is clearly defined in the respective codes.

## USA

- **I5** U.S.A. Intrinsically Safe (IS)
  - Certificate: FM 3046325

Standards: FM Class 3600 - 2011, FM Class 3610 - 2010, FM Class 3810 - 2005, ANSI/ISA 60079-0 -2009, ANSI/ISA 60079-11 - 2009, NEMA 250 - 2003,

ANSI/IEC 60529 Markings: IS CL I, DIV 1, GP A, B, C, D T4; CL 1, Zone 0 AEx ia IIC T4; T4(-40 °C  $\leq$  T_a  $\leq$  +70 °C) when installed per Rosemount drawing 03031-1062;

Type 4X/IP66/IP68

#### Special Conditions for Safe Use (X):

- 1. The Model 2051 Wireless Pressure Transmitter shall only be used with the 701PGNKF Rosemount SmartPower Battery Pack.
- 2. The inline pressure sensor may contain more than 10% aluminum and is considered a potential risk of ignition by impact or friction. Care must be taken into account during installation and used to prevent impact and friction.
- 3. The surface resistivity of the transmitter housing is greater than one gigaohm. To avoid electrostatic charge build-up, it must not be rubbed or cleaned with solvents or a dry cloth.

## Canada

- I6 Canada Intrinsically Safe Certificate: CSA 2526009
  - Standards: CAN/CSA C22.2 No. 0-M91, CAN/CSA C22.2 No. 94-M91, CSA Std C22.2 No. 142-M1987, CSA Std C22.2 No. 157-92, CSA Std C22.2 No. 60529:05
  - Markings: Intrinsically Safe for Class I, Division 1, Groups A, B, C, D, T4 when installed per Rosemount drawing 03031-1063; Type 4X/IP66/IP68

## Europe

#### Special Conditions for Safe Use (X):

- 1. The plastic enclosure may constitute a potential electrostatic ignition risk and must not be rubbed or cleaned with a dry cloth.
- 2. The Model 701PGNKF Power Module may be replaced in a hazardous area. The power module has a surface resistivity greater than  $1G\Omega$  and must be properly installed in the wireless device enclosure. Care must be taken during transportation to and from the point of installation to prevent electrostatic charge build-up.

## International

- 1. The plastic enclosure may constitute a potential electrostatic ignition risk and must not be rubbed or cleaned with a dry cloth.
- 2. The Model 701PGNKF Power Module may be replaced in a hazardous area. The power module has a surface resistivity greater than  $1G\Omega$  and must be properly installed in the wireless device enclosure. Care must be taken during transportation to and from the point of installation to prevent electrostatic charge build-up.

## Brazil

I2 INMETRO Intrinsic Safety Certificate: UL-BR 13.0534X Standards: ABNT NBR IEC 60079-0:2008 + Errata 1:2011, ABNT NBR IEC 60079-11:2009 Markings: Ex ia IIC T4 IP66 Ga, T4(-40 °C  $\leq T_a \leq +70$  °C)

## Special Conditions for Safe Use (X):

1. See certificate for special conditions.

# China

 I3 China Intrinsic Safety Certificate: GYJ17.1225X GYJ15.1365X [Flowmeters] Standards: GB3836.1-2010, GB3836.4-2010, GB3836.20-2010 Markings: Ex ia IIC Ga T4, −40 ~ +70 °C

## Special Conditions for Safe Use (X):

1. See certificate for special conditions.

## Japan

 I4 TIIS Intrinsic Safety Certificate: TC22022X (2051C/L) TC22023X (2051T) TC22024X (2051CFx) Markings: Ex ia IIC T4 Ga, T4(-20 ~ +60 °C)

## Special Condition for Safe Use (X):

1. See certificate for special conditions.

## EAC - Belarus, Kazakhstan, Russia

IM Technical Regulation Customs Union (EAC) Intrinsic Safety Certificate: RU C-US. Fb05.B.00390 Markings: 0Ex ia IIC T4 Ga X;

## Special Condition for Safe Use (X):

1. See certificate for special conditions.

## Korea

**IP** Korea Intrinsic Safety Certificate: 13-KB4BO-0220X Markings: Ex ia IIC T4 ( $-40 \degree C \le T_a \le +70 \degree C$ )

## Special Condition for Safe Use (X):

1. See certificate for special conditions.

# **Dimensional drawings**

## Figure 8. Rosemount 3051S ERS Measurement Transmitter - Coplanar Style







## Figure 10. Rosemount 3051S Scalable Level Transmitter with FF⁽¹⁾⁽²⁾- Coplanar Style

Figure 11. Rosemount 3051S Scalable Level Transmitter with FF⁽¹⁾⁽²⁾- In-Line Style



- 1. FF (FFW) seal dimensions and pressure ratings can be found on page 178.
- 2. Lower housing (flushing ring) is available with FFW style flange.



## Figure 12. Rosemount 3051S Scalable Level Transmitter with Thermal Range Expander – Coplanar Style







## Figure 14. Rosemount 3051S Scalable Level Transmitter with RF⁽¹⁾- Coplanar Style

Dimensions are in inches (millimeters).



Figure 15. Rosemount 3051S Scalable Level Transmitter with RF⁽¹⁾- In-Line Style

^{1.} RF (RFW) seal dimensions and pressure ratings can be found on page 188.



## Figure 16. Rosemount 3051S Scalable Level Transmitter with SS⁽¹⁾- Coplanar Style

## Figure 17. Rosemount 3051S Scalable Level Transmitter with SS⁽¹⁾ - In-Line Style



Dimensions are in inches (millimeters).

^{1.} SS (SSW) seal dimensions and pressure ratings can be found on page 205.



# Figure 18. Rosemount 3051S Scalable Level Transmitter with SC⁽¹⁾- Coplanar Style



## Figure 19. Rosemount 3051S Scalable Level Transmitter with SC⁽¹⁾ - In-Line Style

^{1.} SC (SCW) seal dimensions and pressure ratings can be found on page 204.

## Figure 20. Rosemount 3051L Level Transmitter with FF or EF Seal⁽¹⁾



A. 2-, 4-, or 6-in. extension (only available with 3- and 4-in. flange configurations)

B. Flange adapters (optional, differential configuration only)

Dimensions are in inches (millimeters).

#### Table 75. Transmitter Direct Mount Extension

Flange rating	Transmitter flange extension	Extension dimension ("A")
ANSI/ASME B16.5 Class 600	2-in.	7.65-in. (194,3 mm)
All others	0-in.	5.65-in. (143,5 mm)

#### Figure 21. Rosemount 2051L Level Transmitter with FF or EF Seal⁽¹⁾



A. 2-. 4-, or 6-in. extension (only available with 3- and 4-in. flange configurations)

B. Flange adapters (optional, differential configuration only)

FF (FFW) and EF (EFW) seal and flange diameter dimensions can be viewed on page 178 and page 195.

Dimensions are in inches (millimeters).



# Figure 23. Rosemount 1199 Remote Seal System Assembly Shown with Rosemount 3051S Scalable Transmitter



B. Capillary connects to Rosemount 1199 Remote seals

1. Tuned System Assemblies require specification of capillary length and addition Rosemount 1199 Remote Seal.

2. Tuned System Assemblies are available on all Level Transmitters.

Dimensions are in inches (millimeters).

## Figure 24. Thermal Optimizer (D5) with FFW



Figure 25. FFW Flush Flanged Seal - Two-Piece Design (Shown with Flushing Ring)



	Pipe size	Class	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Bolt circle "C" in. (mm)	Number of bolts	Bolt hole diameter "D" in. (mm)	Standard diaphragm diameter "F" in. (mm)	Raised face outer diameter "G" in. (mm)
	2-in.	150	6.00 (152)	0.69 (18)	4.75 (121)	4	0.75 (19)	2.30 (58)	3.62 (92)
ANSI/ ASME		300	6.50 (165)	0.81 (21)	5.00 (127)	8	0.75 (19)	2.30 (58)	3.62 (92)
		600	6.50 (165)	1.00 (25)	5.00 (127)	8	0.75 (19)	2.30 (58)	3.62 (92)
		900	8.50 (216)	1.00 (25)	6.50 (165)	8	1.50 (38)	2.30 (58)	3.62 (92)
		1500	8.50 (216)	1.00 (25)	6.50 (165)	8	1.50 (38)	2.30 (58)	3.62 (92)
		2500	9.25 (235)	1.13 (29)	6.75 (172)	8	2.00 (51)	2.30 (58)	3.62 (92)
	3-in.	150	7.50 (191)	0.88 (22)	6.00 (152)	4	0.75 (19)	3.50 (89)	5.00 (127)
		300	8.25 (210)	1.06 (27)	6.62 (168)	8	0.88 (22)	3.50 (89)	5.00 (127)
		600	8.25 (210)	1.25 (32)	6.62 (168)	8	0.88 (22)	3.50 (89)	5.00 (127)
		900	9.50 (241)	1.50 (38)	7.50 (191)	8	1.00 (25)	3.50 (89)	5.00 (127)
		1500	10.50 (267)	1.88 (48)	8.00 (203)	8	1.25 (32)	3.50 (89)	5.00 (127)
		2500	12.00 (305)	2.62 (67)	9.00 (229)	8	1.38 (35)	3.50 (89)	5.00 (127)
		150	9.00 (229)	0.88 (22)	7.50 (191)	8	0.75 (19)	3.50 (89)	6.20 (157)
		300	10.0 (254)	1.19 (30)	7.88 (200)	8	0.88 (22)	3.50 (89)	6.20 (157)
	4 in	600	10.75 (273)	1.50 (38)	8.50 (216)	8	1.00 (25)	3.50 (89)	6.20 (157)
	4-in.	900	11.50 (292)	1.75 (45)	9.25 (235)	8	1.25 (32)	3.50 (89)	6.20 (157)
		1500	12.25 (311)	2.12 (54)	9.50 (241)	8	1.38 (35)	3.50 (89)	6.20 (157)
		2500	14.00 (356)	3.00 (76)	10.75(274)	8	1.63 (41)	3.50 (89)	6.20 (157)
		PN 40	6.50 (165)	0.67 (17)	4.92 (125)	4	0.71 (18)	2.30 (58)	4.00 (102)
	DN 50	PN 63	7.09 (180)	0.91 (23)	5.31 (135)	4	0.87 (22)	2.30 (58)	4.00 (102)
		PN 100	7.68 (195)	0.99 (25)	5.71 (145)	4	1.02 (26)	2.30 (58)	4.00 (102)
		PN 160	7.68 (195)	1.06 (27)	5.71 (145)	4	1.02 (26)	2.30 (58)	4.00 (102)
		PN 40	7.87 (200)	0.83 (21)	6.30 (160)	8	0.71 (18)	3.50 (89)	5.43 (138)
EN1092-1	DN 80	PN 63	8.46 (215)	0.99 (25)	6.69 (170)	8	0.88 (22)	3.50 (89)	5.43 (138)
		PN 100	9.06 (230)	1.15 (29)	7.09 (180)	8	1.02 (26)	3.50 (89)	5.43 (138)
		PN 160	9.06 (230)	1.30 (33)	7.09 (180)	8	1.02 (26)	3.50 (89)	5.43 (138)
	DN 100	PN 10/16	8.66 (220)	0.67 (17)	7.09 (180)	8	0.71 (18)	3.50 (89)	6.20 (157)
		PN 40	9.25 (235)	0.94 (24)	7.48 (190)	8	0.87 (22)	3.50 (89)	6.20 (157)
		PN 63	9.84 (250)	0.83 (21)	7.87 (200)	8	1.02 (26)	3.50 (89)	6.20 (157)
		PN 100	10.43 (265)	1.30 (27)	8.27 (210)	8	1.18 (30)	3.50 (89)	6.20 (157)
		PN 160	10.43 (265)	1.46 (37)	8.27 (210)	8	1.18 (30)	3.50 (89)	6.20 (157)
SIĮ	50A	10K	6.10 (155)	0.63 (16)	4.72 (120)	4	0.75 (19)	2.30 (58)	3.62 (92)
		20K	6.10 (155)	0.71 (18)	4.72 (120)	8	0.75 (19)	2.30 (58)	3.62 (92)
		40K	6.50 (165)	1.02 (26)	5.12 (130)	8	0.75 (19)	2.30 (58)	4.00 (102)
	80A	10K	7.28 (185)	0.71 (18)	5.91 (150)	8	0.75 (19)	3.50 (89)	5.00 (127)
		20K	7.87 (200)	0.87 (22)	6.30 (160)	8	0.91 (23)	3.50 (89)	5.00 (127)
		40K	8.27 (210)	1.26 (32)	6.69 (170)	8	0.91 (23)	3.50 (89)	5.43 (138)
	100A	10K	8.27 (210)	0.71 (18)	6.89 (175)	8	0.75 (19)	3.50 (89)	6.20 (157)
		20K	8.86 (225)	0.95 (24)	7.28 (185)	8	0.91 (23)	3.50 (89)	6.20 (157)
		40K	9.84 (250)	1.42 (36)	8.07 (205)	8	0.98 (25)	3,50 (89)	6.20 (157)

# Table 76. Dimensions for FFW Flush Flanged Raised Face Seals-Two Piece (Upper Housing and Flange) Design

	Pipe size	Class	Inner diameter "K" in. (mm)	Beveled edge "L" in. (mm)	Thickness with ¹ /4-NPT F.C. "M" in. (mm)	Thickness with 1/2-NPT F.C. "M" in. (mm)	Minimum gasket I.D. "N" in. (mm)	Weight lb (kg)
ISI/ASME	2-in	150	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	2.50 (64)	7.40 (3,33)
		300	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	2.50 (64)	8.99 (4,05)
		600	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	2.50 (64)	10.44 (4,70)
	2-111.	900	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	2.50 (64)	24.62 (11,08)
		1500	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	2.50 (64)	24.62 (11,08)
		2500	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	2.50 (64)	36.71 (16,52)
	2 in	150	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	13.79 (6,21)
		300	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	17.84 (8,03)
		600	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	20.31 (9,14)
	J-III.	900	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	33.21 (14,94)
AN		1500	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	46.76 (21,04)
		2500	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	81.34 (36,60)
		150	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	19.56 (8,80)
		300	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	29.56 (13,30)
	4 in	600	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	40.73 (18,33)
	4-111.	900	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	53.16 (23,92)
		1500	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	71.72 (32,27)
		2500	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	125.72 (56,57)
	DN 50	PN 40	2.40 (61)	N/A	0.97 (25)	1.30 (33)	2.50 (64)	9.02 (4,06)
		PN 63	2.40 (61)	N/A	0.97 (25)	1.30 (33)	2.50 (64)	12.58 (5,66)
		PN 100	2.40 (61)	N/A	0.97 (25)	1.30 (33)	2.50 (64)	15.23 (6,85)
		PN 160	2.40 (61)	N/A	0.97 (25)	1.30 (33)	2.50 (64)	16.12 (7,25)
		PN 40	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	15.03 (6,76)
EN1092-1	DN 80	PN 63	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	18.87 (8,49)
		PN 100	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	23.34 (10,50)
		PN 160	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	25.83 (11,62)
_		PN 10/16	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	16.08 (7,24)
	DN 100	PN 40	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	20.31 (9,14)
		PN 63	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	26.74 (12,03)
		PN 100	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	34.26 (15,42)
		PN 160	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	37.44 (16,85)
SI	50A	10K	2.12 (54)	N/A	0.97 (25)	1.30 (33)	2.5 (64)	6.93 (3,15)
		20K	2.12 (54)	N/A	0.97 (25)	1.30 (33)	2.5 (64)	7.11 (3,20)
		40K	2.40 (61)	N/A	0.97 (25)	1.30 (33)	2.5 (64)	10.41 (4,68)
	80A	10K	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	10.52 (4,73)
		20K	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	13.61 (6,12)
		40K	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	20.08 (9,04)
		10K	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	14.03 (6,31)
	100A	20K	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	19.16 (8,62)
		40K	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.70 (94)	32.12 (14,45)

# Table 77. Dimensions for FFW Flush Flanged Raised Face Seals-Two Piece (Upper Housing and Flange) Design


## Figure 26. FFW Flush Flanged Seal - One-Piece Design (Shown with Flushing Ring)

	Pipe size	Class	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Bolt circle "C" in. (mm)	Number of bolts	Bolt hole diameter "D" in. (mm)	Standard diaphragm diameter "F" in. (mm)	Raised face diameter "G" in. (mm)	Raised face height "J" in. (mm)	Minimum gasket I.D. "N" in. (mm)	Weight lb (kg)
		150	6.00 (152)	0.69 (18)	4.75 (121)	4	0.75 (19)	2.30 (58)	3.62 (92)	0.06 (1,50)	2.5 (64)	7.40 (3,33)
		300	6.50 (165)	0.81 (21)	5.00 (127)	8	0.75 (19)	2.30 (58)	3.62 (92)	0.06 (1,50)	2.5 (64)	8.99 (4,05)
	2-in.	600	6.50 (165)	1.00 (25)	5.00 (127)	8	0.75 (19)	2.30 (58)	3.62 (92)	0.25 (6,40)	2.5 (64)	10.44 (4,70)
		900/1500	8.50 (216)	1.50 (38)	6.50 (165)	8	1.00 (25)	2.30 (58)	3.62 (92)	0.25 (6,40)	2.5 (64)	24.62 (11,08)
		2500	9.25 (235)	2.00 (51)	6.75 (172)	8	1.13 (29)	2.30 (58)	3.62 (92)	0.25 (6,40)	2.5 (64)	36.71 (16,52)
		150	7.50 (191)	0.88 (22)	6.00 (152)	4	1.13 (25)	3.50 (89)	5.00 (127)	0.06 (1,50)	3.70 (94)	13.79 (6,21)
SI/ASME		300	8.25 (210)	1.06 (27)	6.62 (168)	8	0.88 (22)	3.50 (89)	5.00 (127)	0.06 (1,50)	3.70 (94)	17.84 (8,03)
	ċ	600	8.25 (210)	1.25 (32)	6.62 (168)	8	0.88 (22)	3.50 (89)	5.00 (127)	0.25 (6,40)	3.70 (94)	20.31 (9,14)
	3-ii	900	9.50 (241)	1.50 (38)	7.50 (229)	8	1.00 (25)	3.50 (89)	5.00 (127)	0.25 (6,40)	3.70 (94)	33.21 (14,94)
AN		1500	10.50 (267)	1.88 (48)	8.00 (203)	8	1.25 (32)	3.50 (89)	5.00 (127)	0.25 (6,40)	3.70 (94)	46.76 (21,04)
		2500	12.00 (305)	2.62 (67)	9.00 (229)	8	1.38 (35)	3.50 (89)	5.00 (127)	0.25 (6,40)	3.70 (94)	81.34 (36,60)
		150	9.00 (229)	0.88 (22)	7.50 (191)	8	0.75 (19)	3.50 (89)	6.20 (157)	0.06 (1,50)	3.70 (94)	19.56 (8,80)
		300	10.00 (254)	1.19 (30)	7.88 (200)	8	0.88 (22)	3.50 (89)	6.20 (157)	0.06 (1,50)	3.70 (94)	29.56 (8,80)
	Ŀ.	600	10.75 (273)	1.50 (38)	8.50 (216)	8	1.00 (25)	3.50 (89)	6.20 (157)	0.25 (6.40)	3.70 (94)	40.73 (18,33)
	4	900	11.50 (292)	1.75 (45)	9.25 (235)	8	1.25 (32)	3.50 (89)	6.20 (157)	0.25 (6.40)	3.70 (94)	53.16 (23,92)
		1500	12.25 (311)	2.12 (54)	9.50 (241)	8	1.38 (35)	3.50 (89)	6.20 (157)	0.25 (6.40)	3.70 (94)	71.72 (32,27)
		2500	14.00 (356)	3.00 (76)	10.75 (274)	8	1.63 (41)	3.50 (89)	6.20 (157)	0.25 (6.40)	3.70 (94)	125.72 (56,57)
		PN 40	6.50 (165)	0.67 (17)	4.92 (125)	4	0,71 (18)	2.30 (58)	4.00 (102)	0.12 (3,00)	2.50 (64)	9.02 (4,06)
92-1	150	PN 63	7.08 (180)	0.91 (23)	5.31 (135)	4	0.87 (22)	2.30 (58)	4.00 (102)	0.12 (3,00)	2.50 (64)	12,58 (5,66)
EN 1(	D	PN 100	7.68 (195)	0.99 (25)	5.71 (145)	4	1.02 (26)	2.30 (58)	4.00 (102)	0.12 (3,00)	2.50 (64)	15.23 (6,85)
EN		PN160	7.68 (195)	1.06 (27)	5.71 (145)	4	1.02 (26)	2.30 (58)	4.00 (102)	0.12 (3,00)	2.50 (64)	16.12 (7,25)

## Table 78. Dimensions for FFW Flush Flanged Seals- One Piece (Upper Housing and Flange) Design (Option Code E)

	Pipe size	Class	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Bolt circle "C" in. (mm)	Number of bolts	Bolt hole diameter "D" in. (mm)	Standard diaphragm diameter "F" in. (mm)	Raised face diameter "G" in. (mm)	Raised face height "J" in. (mm)	Minimum gasket I.D. "N" in. (mm)	Weight Ib (kg)
		PN 40	7.87 (200)	0.83 (21)	6.30 (160)	8	0.71 (18)	3.50 (89)	5.43 (138)	0.12 (3,0)	3.70 (94)	15.03 (6,76)
	180	PN 63	8.46 (215)	0.99 (25)	6.69 (170)	8	0.88 (22)	3.50 (89)	5.43 (138)	0.12 (3,0)	3.70 (94)	18.87 (8,49)
		PN 100	9.06 (230)	1.15 (29)	7.09 (180)	8	1.02 (26)	3.50 (89)	5.43 (138)	0.12 (3,0)	3.70 (94)	23.34 (10,50)
<u>e-1</u>		PN160	9.06 (230)	1.30 (33)	7.09 (180)	8	1.02 (26)	3.50 (89)	5.43 (138)	0.12 (3,0)	3.70 (94)	25.83 (11,62)
1092		PN 10/16	8.66 (220)	0.67 (17)	7.09 (180)	8	0.71 (18)	3.50 (89)	6.20 (157)	0.12 (3,0)	3.70 (94)	16.08 (7,24)
EN		PN 40	9.25 (235)	0.83 (21)	7.48 (190)	8	0.87 (22)	3.50 (89)	6.20 (157)	0.12 (3,0)	3.70 (94)	20.31 (9,14)
	DN100	PN 63	9.84 (250)	1.07 (27)	7.87 (200)	8	1.02 (26)	3.50 (89)	6.20 (157)	0.12 (3,0)	3.70 (94)	26.74 (1203)
		PN 100	10.43 (265)	1.30 (33)	8.27 (210)	8	1.18 (30)	3.50 (89)	6.20 (157)	0.12 (3,0)	3.70 (94)	34.26 (15,42)
		PN 160	10.43 (265)	1.46 (37)	8.27 (210)	8	1.18 (30)	3.50 (89)	6.20 (157)	0.12 (3,0)	3.70 (94)	37.44 (16,85)
		10K	6.1 (155)	0.63 (16)	4.72 (120)	4	0.75 (19)	2.30 (58)	3.62 (92)	0.08 (2,0)	2.50 (64)	6.93 (3,15)
	50A	20K	6.1 (155)	0.71 (18)	4.72 (120)	8	0.75 (19)	2.30 (58)	3.62 (92)	0.08 (2,0)	2.50 (64)	7.11 (3,20)
		40K	6.5 (165)	1.02 (26)	5.12 (130)	8	0.75 (19)	2.30 (58)	4.00 (102)	0.08 (2,0)	2.50 (64)	10.41 (4,68)
		10K	7.28 (185)	0.71 (18)	5.91 (150)	8	0.75 (19)	3.50 (89)	5.00 (127)	0.08 (2,0)	3.70 (94)	10.52 (4,73)
JIS	80A	20K	7.87 (200)	0.87 (22)	6.3 (160)	8	0.91 (23)	3.50 (89)	5.00 (127)	0.08 (2,0)	3.70 (94)	13.61 (6,12)
		40K	8.27 (210)	1.26 (32)	6.69 (170)	8	0.91 (23)	3.50 (89)	5.43 (138)	0.08 (2,0)	3.70 (94)	20.08 (9,04)
		10K	8.27 (210)	0.71 (18)	6.89 (175)	8	0.75 (19)	3.50 (89)	6.20 (157)	0.08 (2,0)	3.70 (94)	14.03 (6,31)
	100A	20K	8.86 (225)	0.95 (24)	7.28 (185)	8	0.91 (23)	3.50 (89)	6.20 (157)	0.08 (2,0)	3.70 (94)	19.16 (8,62)
		40K	9.84 (250)	1.42 (36)	8.07 (205)	8	0.98 (25)	3.50 (89)	6.20 (157)	0.08 (2,0)	3.70 (94)	32.12 (14,45)

## Table 78. Dimensions for FFW Flush Flanged Seals- One Piece (Upper Housing and Flange) Design (Option Code E)

## Figure 27. FFW Flush Flanged Seal - Flushing Connection Ring (Lower Housing)



## Table 79. Dimensions for FFW Flushing Connection Ring (Lower Housing)

	Pipe size	Class	Raised face diameter "G" in. (mm)	Inner diameter "K" in. (mm)	Beveled edge "L" in. (mm)	Thickness with 1/4 NPT F.C. "M" in. (mm)	Thickness with 1/2 NPT F.C. "M" in. (mm)	Weight lb (kg)
		150	3.62 (92)	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	7.41 (3,33)
		300	3.62 (92)	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	8.99 (4,05)
	2-in.	600	3.62 (92)	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	10.44 (4,70)
		900/1500	3.62 (92)	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	24.62 (11,08)
		2500	3.62 (92)	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	36.71 (16,52)
		150	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	13.79 (6,21)
		300	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	17.84 (8,03)
ЧE	2 in	600	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	20.31 (9,14)
ASI	5-111.	900	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	33.21 (14,94)
ISI/		1500	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	46.76 (21,04)
A		2500	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	81.34 (36,60)
		150	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	19.56 (8,80)
		300	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	29.56 (13,30)
		600	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	40.73 (18,33)
	4-in.	900	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	53.16 (23,92)
		1500	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	71.72 (32,27)
		2500	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	125.72 (56,57)
		PN 40	4.00 (102)	2.40 (61)	N/A	0.97 (25)	1.30 (33)	9.02 (4,06)
		PN 63	4.00 (102)	2.40 (61)	N/A	0.97 (25)	1.30 (33)	12.58 (5,66)
		PN 100	4.00 (102)	2.40 (61)	N/A	0.97 (25)	1.30 (33)	15.23 (6.85)
		PN 160	4.00 (102)	2.40 (61)	N/A	0.97 (25)	1.30 (33)	16.12 (7,25)
		PN 40	5.43 (138)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	15.03 (6,76)
2-1		PN 63	5.43 (138)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	18.87 (8,49)
60		PN 100	5.43 (138)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	23.34 (10.50)
EN		PN 160	5.43 (138)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	25.83 (11,62)
_		PN 10/16	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	16.08 (7,24)
		PN 40	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	20.31 (9,14)
	DN 100	PN 63	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	26.74 (12,03)
		PN 100	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	34.26 (15,42)
		PN 160	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	37.44 (16,85)

	Pipe size	Class	Raised face diameter "G" in. (mm)	Inner diameter "K" in. (mm)	Beveled edge "L" in. (mm)	Thickness with 1/4NPT F.C. "M" in. (mm)	Thickness with 1/2NPT F.C. "M" in. (mm)	Weight lb (kg)
		10K	3.62 (92)	2.12 (54)	N/A	0.97 (25)	1.30 (33)	6.93 (3,15)
	50A	20K	3.62 (92)	2.12 (54)	N/A	0.97 (25)	1.30 (33)	7.11 (3,20)
		40K	4.00 (102)	2.40 (61)	N/A	0.97 (25)	1.30 (33)	10.41 (4,68)
		10K	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	10.52 (4,73)
JIS	80A	20K	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	13.61 (6,12)
		40K	5.43 (138)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	20.08 (9,04)
		10K	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	14.03 (6,31)
	100A	20K	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	19.16 (8,62)
		40K	6.20 (157)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	32.12 (14,45)

## Table 79. Dimensions for FFW Flushing Connection Ring (Lower Housing)

## Figure 28. RFW Flanged Seal Standard Design



Dimensions are in inches (millimeters).

## Table 80. RFW Flanged Seal Standard Design Dimensions⁽¹⁾

	Pipe size		Flange	Flange	Overall height	"C" in. (mm)	Bolt circle	Bolt hole	Lower	
	Pipe size	Class	diameter "A" in. (mm)	thickness "B" in. (mm)	No or ¹ /4-in. NPT flush connection	¹ /2-in. NPT flush connection	diameter "D" in. (mm)	diameter "E" in. (mm)	housing diameter "F" in. (mm)	Weight lb (kg)
	¹ /2-in.	2500	5.25 (133)	1.19 (30)	2.45 (62)	2.79 (71)	3.25 (83)	0.75 (19)	2.62 (67)	8.49 (3,82)
		300/600	4.62 (117)	0.62 (16)	2.45 (62)	2.79 (71)	3.25 (83)	0.88 (22)	2.62 (67)	4.99 (2,25)
ASME	³ /4-in.	900/1500	5.12 (130)	1.00 (25)	2.45 (62)	2.79 (71)	3.50 (89)	0.88 (22)	2.62 (67)	7.25 (3,26)
		2500	5.50 (140)	1.25 (32)	2.45 (62)	2.79 (71)	3.75 (95)	0.88 (22)	2.62 (67)	9.52 (4,28)
		150	4.25 (108)	0.50 (13)	2.45 (62)	2.79 (71)	3.25 (83)	0.75 (19)	2.62 (67)	4.19 (1,89)
		300	4.88 (124)	0.62 (16)	2.45 (62)	2.79 (71)	3.12 (79)	0.63 (16)	2.62 (67)	5.30 (2,39)
	1-in.	600	4.88 (124)	0.69 (18)	2.45 (62)	2.79 (71)	3.50 (89)	0.75 (19)	2.62 (67)	5.58 (2,51)
AS		900/1500	5.88 (150)	1.12 (29)	2.45 (62)	2.79 (71)	4.00 (102)	1.00 (25)	2.62 (67)	9.68 (4,36)
ISI/		2500	6.25 (159)	1.38 (35)	2.45 (62)	2.79 (71)	4.25 (108)	1.00 (25)	2.87 (73)	13.68 (6,16)
AN		150	5.00 (127)	0.62 (16)	2.45 (62)	2.79 (71)	3.50 (89)	0.63 (22)	2.62 (67)	5.63 (2,53)
4	1 ¹ /2-in.	300	6.12 (155)	0.75 (19)	2.45 (62)	2.79 (71)	3.88 (99)	0.75 (19)	2.88 (73)	8.20 (3.69)
		600	6.12 (155)	0.88 (22)	2.45 (62)	2.79 (71)	4.50 (114)	0.88 (22)	2.88 (73)	9.09 (4,09)
		900	7.00 (178)	1.25 (32)	2.45 (62)	2.79 (71)	4.50 (114)	0.88 (22)	2.88 (73)	14.48 (6,52)
		1500	7.00 (178)	1.25 (32)	2.45 (62)	2.79 (71)	4.88 (124)	1.13 (29)	2.88 (73)	14.48 (6,62)
		2500	8.00 (203)	1.75 (45)	2.45 (62)	2.79 (71)	5.75 (146)	1.25 (32)	2.88 (73)	25.34 (11,40)
	DN 25	PN 40	4.53 (115)	0.71 (18)	2.45 (62)	2.79 (71)	3.35 (85)	0.55 (14)	2.68 (68)	5.09 (2,29)
EN 1092	DN 40	PN 40	5.91 (150)	0.71 (18)	2.45 (62)	2.79 (71)	4.33 (110)	0.71 (18)	3.47 (88)	8.04 (3,62)
	20A	40K	4.72 (120)	0.79 (20)	2.45 (62)	2.79 (71)	3.35 (85)	0.75 (19)	2.62 (67)	5.59 (2,52)
		10K	4.92 (125)	0.55 (14)	2.45 (62)	2.79 (71)	3.54 (90)	0.75 (19)	2.62 (67)	5.00 (2,25)
	25A	20K	4.92 (125)	0.63 (16)	2.45 (62)	2.79 (71)	3.54 (90)	0.75 (19)	2.62 (67)	5.31 (2,39)
JIS		40K	5.12 (130)	0.87 (22)	2.45 (62)	2.79 (71)	3.74 (95)	0.75 (19)	2.76 (70)	6.86 (3,09)
		10K	5.51 (140)	0.63 (16)	2.45 (62)	2.79 (71)	4.13 (105)	0.75 (19)	3.19 (81)	6.20 (2,79)
	40A	20K	5.51 (140)	0.71 (18)	2.45 (62)	2.79 (71)	4.13 (105)	0.75 (19)	3.19 (81)	7.36 (3,31)
		40K	6.30 (160)	0.94 (24)	2.45 (62)	2.79 (71)	4.72 (120)	0.91 (23)	3.54 (90)	11.06 (4,98)

1. Lower housing is loose on standard design, consult factory for retained lower housing options.

## Figure 29. RFW Flanged Seal Stud Bolt Design



B. Diaphragm

C. Lower housing or flushing connection

Dimensions are in inches (millimeters).

			Overall height "A" in. (mm)		Stud circle	Stud (size length)	Lower housing	Raised face	Weight Ib
	Pipe size	Class	No or ¹ /4-in. NPT flush connection	¹ /2-in. NPT flush connection	diameter "B" in. (mm)	"C" in. (mm)	diameter "D" in. (mm)	diameter "E" in. (mm)	(kg)
ИE	1/2-in	150	2.52 (64)	2.82 (72)	2.38 (61)	¹ /2–13NC, 2.5-in.	3.74 (95)	1.38 (35)	6.28 (2,83)
ASI	/2-111.	300/600	2.77 (70)	2.87 (73)	2.62 (67)	¹ /2–13NC, 2.5-in.	3.75 (95)	1.38 (35)	6.53 (2,94)
ANSI/	³ /4-in.	150	2.52 (64)	2.82 (72)	2.75 (70)	¹ /2–13NC, 2.5-in.	3.88 (99)	1.69 (43)	6.46 (2,91)
-		PN 40	2.52 (64)	2.82 (72)	2.56 (65)	M12 $ imes$ 1.75, 60 mm	3.74 (95)	1.77 (45)	6.27 (2,82)
92		PN 100/160	2.52 (64)	2.82 (72)	2.95 (75)	M12 × 1.75, 60 mm	4.13 (105)	1.77 (45)	6.92 (3,11)
EN 10	DN 20	PN 40	2.52 (64)	2.82 (72)	2.95 (75)	M12 $ imes$ 1.75, 60 mm	4.13 (105)	2.28 (58)	6.90 (3,11)
	104	10/20K	2.52 (64)	2.82 (72)	2.56 (65)	M12 $ imes$ 1.75, 60 mm	3.74 (95)	1.81 (46)	6.30 (2,84)
	107	40K	2.52 (64)	2.82 (72)	2.95 (75)	M16 $ imes$ 2.00, 70 mm	4.33 (110)	2.05 (52)	7.70 (3,47)
S		10K	2.52 (64)	2.82 (72)	2.76 (70)	M12 $ imes$ 1.75, 60 mm	3.74 (95)	2.01 (51)	6.39 (2,88)
JIS	15A	20K	2.52 (64)	2.82 (72)	2.76 (70)	M12 $ imes$ 2.00, 60 mm	3.74 (95)	2.01 (51)	6.39 (2,88)
		40K	2.52 (64)	2.82 (72)	3.15 (80)	M16 $ imes$ 2.00, 70 mm	4.53 (115)	2.17 (55)	8.26 (3,72)
	20A	10/20K	2.52 (64)	2.82 (72)	2.95 (75)	M12 $ imes$ 1.75, 60 mm	3.94 (100)	2.21 (56)	6.68 (3,01)

#### Table 81. RF/RFW Flanged Seal Standard Design Dimensions⁽¹⁾

Lower housing is loose on standard design, consult factory for retained lower housing options. 1.

## Figure 30. EFW Extended Flanged Seal - Extended Flanged Assembly





D. Connection to transmitter

E. Extension length

A. Process flange

- B. Extension
- C. Diaphragm

Dimensions are in inches (millimeters).

#### Table 82. EFW Extended Flanged Seal Dimensions

	Pipe size	Class	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Bolt circle "C" in. (mm)	Number of bolts	Bolt hole diameter "D" in. (mm)	Raised face diameter "F" in. (mm)
		150	5.00 (127)	0.62 (16)	0.63 (16)	4	3.88 (99)	2.88 (73)
		300	6.12 (156)	0.75 (19)	0.88 (22)	4	4.50 (114)	2.88 (73)
	1 ¹ /2-in.	600	6.12 (156)	0.88 (22)	0.88 (22)	4	4.50 (114)	2.88 (73)
		900/1500	7.00 (178)	1.25 (32)	1.13 (28)	4	4.88 (124)	2.88 (73)
		2500	8.00 (203)	1.75 (45)	1.25 (32)	4	5.75 (146)	2.88 (73)
		150	6.00 (152)	0.69 (18)	0.75 (19)	4	4.75 (121)	3.62 (92)
		300	6.50 (165)	0.82 (21)	0.75(19)	8	5.00 (127)	3.62 (92)
ASME	2-in.	600	6.50 (165)	1.00 (25)	0.75 (19)	8	5.00 (127)	3.62 (92)
	-	900/1500	8.50 (216)	1.50 (38)	1.00 (25)	8	6.50 (165)	3.62 (92)
		2500	9.25 (235)	2.00 (51)	1.13 (29)	8	6.75 (172)	3.62(92)
		150	7.50 (191)	0.88 (22)	0.75 (19)	4	6.00 (152)	5.00 (127)
SI		300	8.25 (210)	1.06 (27)	0.88 (22)	8	6.62 (168)	5.00 (127)
Ž	2 in	600	8.25 (210)	1.25 (32)	0.88 (22)	8	6.62 (168)	5.00 (127)
	5-111.	900	9.50 (241)	1.50 (38)	1.00 (25)	8	7.50 (191)	5.00 (127)
		1500	10.50 (267)	1.88 (48)	1.25(32)	8	8.00 (203)	5.00 (127)
		2500	12.00 (305)	2.62 (67)	1.38 (35)	8	9.00 (229)	5.00 (127)
		150	9.00 (229)	0.88 (22)	0.75 (19)	8	7.50 (191)	6.20 (158)
		300	10.00 (254)	1.19 (30)	0.88 (22)	8	7.88 (200)	6.20 (158)
	4 in	600	10.75 (273)	1.50 (38)	1.00 (25)	8	8.50 (216)	6.20 (158)
	4-111.	900	11.50 (292)	1.75 (45)	1.25 (32)	8	9.25 (235)	6.20 (158)
		1500	12.25 (311)	2.12 (54)	1.38 (35)	8	9.50 (241)	6.20 (158)
		2500	14.00 (356)	3.00 (76)	1.63 (41)	8	10.75 (274)	6.20 (158)

	Pipe size	Class	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Bolt circle "C" in. (mm)	Number of bolts	Bolt hole diameter "D" in. (mm)	Raised face diameter "F" in. (mm)
		PN 40	6.50 (165)	0.67 (17)	0.71 (18)	4	4.92 (125)	4.02 (102)
		PN 63	7.08 (180)	0.91 (23)	0.87 (22)	4	5.31 (135)	4.02 (102)
		PN 100	7.68 (195)	0.98 (25)	1.02 (26)	4	5.71 (145)	4.02 (102)
		PN 160	7.68 (195)	1.06 (27)	1.02 (26)	4	5.71 (145)	4.02 (102)
_		PN 40	7.87 (200)	0.83 (21)	0.71 (18)	8	6.30 (160)	5.43 (138)
5		PN 63	8.46 (215)	0.98 (25)	0.88 (22)	8	6.69 (170)	5.43 (138)
EN 109	DN 80	PN 100	9.06 (230)	1.14 (29)	1.02 (26)	8	7.09 (180)	5.43 (138)
		PN 160	9.06 (230)	1.30 (33)	1.02 (26)	8	7.09 (180)	5.43 (138)
		PN 10/16	8.66 (220)	0.67 (17)	0.71 (18)	8	7.09 (180)	6.20 (158)
	DN 100	PN 40	9.25 (235)	0.83 (21)	0.87 (22)	8	7.48 (190)	6.20 (158)
		PN 63	9.84 (250)	1.06 (27)	1.02 (26)	8	7.87 (200)	6.20 (158)
		PN 100	10.43 (265)	1.30 (33)	1.18 (30)	8	8.27 (210)	6.20 (158)
		PN 160	10.43 (265)	1.46 (37)	1.18 (30)	8	8.27 (210)	6.20 (158)
		10K	6.10 (155)	0.63 (16)	0.75 (19)	4	4.72 (120)	3.62 (92)
	50A	20K	6.10 (155)	0.71 (18)	0.75 (19)	8	4.72 (120)	3.62 (92)
		40K	6.50 (165)	1.02 (26)	0.75 (19)	8	5.12 (130)	4.00 (102)
		10K	7.28 (185)	0.71 (18)	0.75 (19)	8	5.91 (150)	5.00 (127)
JIS	80A	20K	7.87 (200)	0.87 (22)	0.91 (23)	8	6.30 (160)	5.00 (127)
=		40K	8.27 (210)	1.26 (32)	0.91 (23)	8	6.69 (170)	5.43 (138)
		10K	8.27 (210)	0.71 (18)	0.75 (19)	8	6.89 (175)	6.20 (158)
	100A	20K	8.86 (225)	0.94 (24)	0.91 (23)	8	7.28 (185)	6.20 (158)
		40K	9.84 (250)	1.42 (36)	0.98 (25)	8	8.07 (205)	6.20 (158)

## Table 82. EFW Extended Flanged Seal Dimensions

#### Table 83. EFW Extended Flanged Seal Dimensions

Pro	Process connection size											
ANSI B16.5	EN 1092-1	JIS B2238	in. (mm)									
3-in.	DN 80	80A	2.58 (66)									
4-in.	DN 100	100A	3.50 (89)									
1 ¹ /2-in.	DN 40	40A	1.45 (37)									
2-in.	DN 50	50A	1.90 (48)									
3-in. Headbox	DN 80 Headbox	N/A	2.88 (73)									
4-in. Headbox	DN100 Headbox	N/A	3.78 (96)									

## Table 84. EFW Extended Flanged Seal Weights Pounds (Kilograms)

	Pipe size			Extension length									
		Class	1-in. (25 mm)	2-in. (51 mm)	3-in. (76 mm)	4-in. (102 mm)	5-in. (127 mm)	6-in. (152 mm)	7-in. (178 mm)	8-in. (203 mm)	9-in. (229 mm)		
		150	5.53 (2,49)	5.99 (2,70)	6.46 (2,91)	6.92 (3,11)	7.38 (3,32)	7.85 (3,53)	8.31 (3,74)	8.78 (3,95)	7.47 (3,36)		
si/ASME	1 ¹ /2-in.	300	8.11 (3,65)	8.57 (3,86)	9.04 (4,07)	9.50 (4,28)	9.96 (4,48)	10.43 (4,69)	10.89 (4,90)	11.36 (5,11)	10.05 (4,52)		
		600	9.00 (4,05)	9.46 (4,56)	9.93 (4,47)	10.39 (4,68)	10.86 (4,89)	11.32 (5,09)	11.78 (5,30)	12.25 (5,51)	10.94 (4,92)		
AN		900/1500	15.19 (6,86)	15.66 (7,05)	16.12 (7,25)	16.59 (7,47)	17.05 (7,67)	17.51 (7,88)	17.98 (8,09)	18.44 (8,30)	18.70 (8,42)		
		2500	25.38 (11,42)	25.84 (11,63)	26.31 (11,84)	26.77 (12,05)	27.23 (12,25)	27.70 (12,47)	28.16 (12,67)	28.63 (12,88)	28.89 (13,00)		

				Extension length								
	Pip	oe size	Class	1-in.	2-in.	3-in.	4-in.	5-in.	6-in.	7-in.	8-in.	9-in.
				(25 mm)	(51 mm)	(76 mm)	(102 mm)	(127 mm)	(152 mm)	(178 mm)	(203 mm)	(229 mm)
			150	8.22	8.80	9.41	10.00	10.60	11.19	11.79	12.38	11.16
				(3,70)	(3,96)	(4,23)	(4,50)	(4,//)	(5,04)	(5,31)	(5,57)	(5,02)
			300	9.81	(4.68)	(4.95)	(5.22)	(5.49)	(5.76)	(6.02)	(6.29)	(5.74)
		2-in.	600	11.26 (5,07)	11.84 (5,33)	12.44 (5,60)	13.05 (5,87)	13.64 (6,14)	14.23 (6,40)	14.83 (6,67)	15.42 (6,94)	14,20 (6.39)
			900/1500	25.50 (11,48)	26.31 (11,84)	27.12 (12,20)	27.92 (12,56)	28.73 (12,93)	29.54 (13,29)	30.34 (13,65)	31.15 (14,02)	31.32 (14,09)
			2500	36.58 (16,46)	37.38 (16,82)	38.19 (17,19)	39.00 (17,55)	39.80 (17,91)	40.61 (18,27)	41.42 (18,64)	42.22 (19,00)	42.40 (19,08)
			150	15.89	17.64	19.48	21.27	23.08	24.88	26.69	28.50	22.47
			150	(7,15)	(7,94)	(8,77)	(9,57)	(10,39)	(11,20)	(12,01)	(12,83)	(10,11)
			300	19.94	21.69	23.53	25.32	27.13	28.93	30.74	32.54	26.52
				(0,97)	(9,70)	26.02	27.81	29.62	31.42	33 23	35.03	29.01
	2 :		600	(10,09)	(10,88)	(11,71)	(12,51)	(13,33)	(14,14)	(14,95)	(15,76)	(13,05)
		3-IN.	900	33.26	35.10	36.90	38.71	40.51	42.32	44.12	45.93	48.80
			500	(14,97)	(15,80)	(16,61)	(17,42)	(18,23)	(19,04)	(19,85)	(20,67)	(21,96)
			1500	47.88	49.71 (22.37)	51.52 (23.18)	53.33	(24.81)	(25.62)	58.74	60.55	63.42 (28.54)
				83.46	85 30	87 10	88.91	90.71	92 52	94 33	96.13	99.00
ME			2500	(37,56)	(38,39)	(39,20)	(40,01)	(40,82)	(41,63)	(42,45)	(43,26)	(44,55)
AS			150	15.76	17.40	19.07	20.90	22.40	24.07	25.74	27.41	23.24
ISI				(7,09)	(7,83)	(8,58)	(9,41)	(10,08)	(10,83)	(11,58)	(12,33)	(10,46)
A			300	(8.91)	21.45 (9.65)	(10.40)	(11.23)	(11.90)	(12.65)	(13.41)	(14.15)	(12.28)
			600	22.30	23.94	25.61	27.44	28.94	30.61	32.28	33.94	29.78
	3-in.	Headbox	000	(10,04)	(10,77)	(11,52)	(12,35)	(13,02)	(13,77)	(14,53)	(15,27)	(13,40)
	5		900	33.13 (14,91)	34.83 (15,67)	36.50 (16,53)	38.17 (17,18)	39.84 (17,93)	41.51 (18,68)	43.15 (19,42)	44.85 (20,18)	47.58 (21,41)
			1500	47.75	49.45	51.12	52.79	54.46	56.13	57.76	59.46	62.20
				(21,49)	(22,25)	(23,00)	(23,70)	(24,51)	(25,20)	(25,99)	(20,70)	(27,99)
			2500	(37,50)	(38,26)	(39,02)	(39,77)	(40,52)	(41,27)	(42,01)	(42,77)	(44,00)
			150	28.61 (12,87)	39.17 (17,63)	49.62 (22,33)	60.07 (27,03)	70.52 (31,73)	80.94 (36,42)	91.42 (41,14)	101.88 (45,85)	31.74 (14,28)
			300	38.62 (17,38)	49.18 (22,13)	59.63 (26,83)	70.08 (31,54)	80.54 (36,24)	90.96 (40,93)	101.44 (45,65)	111.89 (50,35)	41.75 (18,79)
			600	48.37	58.93	69.38	79.83	90.28	100.70	111.19	121.64	51.50
		4-in.	000	(21,77)	(26,52)	(31,22)	(35,92)	(40,63)	(45,32)	(50,04)	(54,74)	(23,18)
			900	55.27 (24,87)	58.50 (26,33)	61.73 (27,78)	64.96 (29,23)	67.31 (30,29)	70.34 (31,65)	73.36 (33,01)	76.38 (34,37)	80.30 (36,14)
			1500	72.28 (32,53)	75.51 (33,98)	78.74 (35,43)	81.97 (36,89)	84.33 (37,95)	87.35 (39,31)	90.37 (40,67)	93.39 (42,03)	97.31 (43,79)
			2500	126.52 (56,93)	129.75 (58,39)	132.98 (59,84)	136.20 (61,29)	138.57 (62,36)	141.59 (63,72)	144.61 (65,07)	147.63 (66,43)	151.55 (68,20)

## Table 84. EFW Extended Flanged Seal Weights Pounds (Kilograms)

				Extension length								
	Pij	pe size	Class	1-in.	2-in.	3-in.	4-in.	5-in.	6-in.	7-in.	8-in.	9-in.
				(25 mm)	(51 mm)	(76 mm)	(102 mm)	(127 mm)	(152 mm)	(178 mm)	(203 mm)	(229 mm)
			150	22.84	25.85	28.90	31.99	35.00	38.06	41.11	44.13	32.00
				(10,28)	(11,63)	(13,01)	(14,40)	(15,75)	(17,13)	(18,50)	(19,86)	(14,40)
			300	(14.78)	(16.14)	(17.51)	(18.90)	(20.26)	(21.63)	(23.00)	(24.36)	42.02 (18.91)
ИE			<b>C</b> 00	42.60	45.62	48.67	51.75	54.77	57.82	60.8	63.89	51.77
ASI		4-in.	600	(19,17)	(20,53)	(21,90)	(23,29)	(24,65)	(26,02)	7(27,39)	(28,75)	(23,30)
'ISI	He	eadbox	900	55.24	58.32	61.37	64.41	67.47	70.52	73.5	76.62	80.74
AN				(24,86)	(26,24)	(27,62)	(28,98)	(30,36)	(31,73)	7(33,11)	(34,48)	(36,33)
			1500	(32,51)	(33.90)	(35.27)	(36.64)	84.48	(39 39)	90.58	93.63	97.75 (43.99)
				126.49	129.57	132.62	135.67	138.72	141.78	144.83	147.88	152.00
			2500	(56,92)	(58,31)	(59,68)	(61,05)	(62,42)	(63,80)	(65,17)	(66,55)	(68,4)
			PN 40	7.46	7.92	8.38	8.85	9.31	9.77	10.24	10.70	9.39
				(3,36)	(3,56)	(3,77)	(3,98)	(4,19)	(4,40)	(4,61)	(4,82)	(4,23)
	0	ON 40	PN 63/100	11.52	11.98	12.44	12.91	13.37	13.84	14.30	14.76	13.45
				(5,18)	(5,39)	(5,00)	(5,81)	(0,23)	(0,34)	(0,44)	(0,04)	(0,05)
			PN 160	(5.93)	(6.13)	(6.35)	(6.55)	(6.76)	(6.97)	(7.18)	(7.39)	(7.57)
			511.40	9.87	10.45	11.06	11.66	12.25	12.84	13.44	14.03	12.81
			PN 40	(4,44)	(4,70)	(5,00)	(5,25)	(5,51)	(5,78)	(6,05)	(6,31)	(5,76)
			PN 63	13.37	13.96	14.56	15.16	15.75	16.35	16.94	17.54	16.31
	Г	ON 50	DN 100	(6,02)	(6,28)	(6,55)	(6,82)	(7,09)	(7,36)	(7,62)	(7,89)	(7,34)
	-		PN 100	16.05	16.63	17.23	17.83	18.43	19.02	19.61	20.21	18.99
				(7,22)	(7,48)	(7,75)	(8,02)	(8,29)	(8,50) 10 CC	(8,82)	(9,09)	(8,55)
			PN 160	(8.16)	(8.53)	(8.89)	(9.25)	(9.62)	(9.98)	(10.34)	(10.71)	(10.78)
			DN 40	16.85	18.47	20.08	21.70	23.32	24.94	26.56	28.18	23.97
			PN 40	(7,58)	(8,31)	(9,04)	(9,77)	(10,49)	(11,22)	(11,95)	(12,68)	(10,79)
_			PN 63	20.70	22.32	23.93	25.55	27.17	28.79	30.41	32.03	27.82
2-1		Schedule		(9,32)	(10,04)	(10,77)	(11,50)	(12,23)	(12,96)	(13,68)	(14,41)	(12,52)
260		40	PN 100	25.29	26.90	28.51	30.13	31.75	33.37	34.99	36.61	32.40
۲ ۱				20.45	31.10	32 72	3/33	35.05	37.57	30 17	/0.81	(14,58)
ш			PN 160	(13,25)	(14,00)	(14,72)	(15,45)	(16,18)	(16,91)	(17,64)	(18,36)	(19,58)
			DN 40	16.53	17.76	19.07	20.36	21.65	22.93	24.22	25.51	21.12
			PN 40	(7,44)	(7,99)	(8,58)	(9,16)	(9,74)	(10,32)	(10,90)	(11,48)	(9,50)
			PN 63	20.38	21.61	22.92	24.21	25.50	26.78	28.07	29.36	24.97
	DN	Schedule		(9,17)	(9,72)	(10,31)	(10,89)	(11,48)	(12,05)	(12,63)	(13,21)	(11,24)
	80	80	PN 100	24.97	26.20	(12.38)	(12.06)	30.08	31.37	32.65	(15.27)	29.56
				29.17	30.67	32 17	33.67	35 17	36.66	38.16	39.66	40.51
			PN160	(13,13)	(13,80)	(17,48)	(15,15)	(15,83)	(16,50)	(17,17)	(17,85)	(18,23)
				16.92	18.56	20.23	22,06	23.56	25.23	26.90	28.56	24.40
			FIN 40	(7,61)	(8,35)	(9,10)	(9,93)	(10,60)	(11,35)	(12,11)	(12,85)	(10,98)
			PN 63	20.77	22.41	24.08	25.91	27.41	29.08	30.75	32.41	28.25
		Headbox		(9,35)	(10,08)	(10,84)	(11,66)	(12,33)	(13,09)	(13,84)	(14,58)	(12,/1)
			PN 100	25.35	20.99 (12,15)	28.66	30.49 (13.72)	(14.40)	(15.15)	35.33 (15.90)	(16.65)	32.84 (14,78)
				29.49	31.19	32.86	34.53	36.20	37.87	39.50	41.20	43.94
		-	PN 160	(13,27)	(14,04)	(14,79)	(15,54)	(16,29)	(17,04)	(17,78)	(18,54)	(19,77)

Table 84. EFW Extended Flanged Seal Weights Pounds (Kilograms)

	Pine size					Ex	tension ler	ngth				
	Pip	pe size	Class	1-in. (25 mm)	2-in. (51 mm)	3-in. (76 mm)	4-in. (102 mm)	5-in. (127 mm)	6-in. (152 mm)	7-in. (178 mm)	8-in. (203 mm)	9-in. (229 mm)
			PN 10/16	19.23 (8,65)	22.07 (9,93)	24.95 (11,23)	27.85 (12,53)	30.73 (13,83)	33.62 (15,13)	36.50 (16,43)	39.39 (17,73)	29.81 (13,41)
			PN 40	23.32 (10,50)	26.16 (11,77)	29.05 (13,07)	31.94 (14,37)	34.83 (15,67)	37.71 (16,97)	40.60 (18,27)	43.48 (19,57)	33.90 (15,26)
		Schedule 40	PN 63	29.83 (13,42)	32.67 (14,70)	35.56 (16,00)	38.45 (17,30)	41.34 (18,60)	44.22 (19,90)	47.11 (21,20)	50.00 (22,50)	40.41 (18,18)
			PN 100	37.37 (16,82)	40.21 (18,09)	43.10 (19,40)	45.99 (20,70)	48.88 (22,00)	51.76 (23,29)	54.65 (24,59)	57.53 (25,89)	47.95 (21,58)
	DN		PN 160	42,48 (19,12)	45.4 (20,43)	48.29 (21,73)	51.17 (23,03)	54.05 (24,32)	56.94 (25,62)	59.82 (26,92)	52.71 (28,22)	66.63 (29,98)
	100		PN 16	18.85 (8,48)	21.43 (9,64)	23.98 (10,79)	26.53 (11,94)	29.08 (13,09)	31.66 (14,25)	34.17 (15,38)	36.72 (16,52)	26.81 (12,06)
-1			PN 40	22.95 (10,33)	25.53 (11,49)	28.07 (12,63)	30.62 (13,78)	33.17 (14,93)	35.75 (16,09)	38.27 (17,22)	40.82 (18,37)	30.90 (13,91)
1092		Schedule 80	PN 63	29.46 (13,26)	32.04 (14,42)	34.58 (15,56)	37.13 (16,71)	39.68 (17,86)	42.26 (19,02)	44.78 (20,15)	47.33 (21,30)	37.41 (16,83)
ĒN				PN 100	36.99 (16,65)	39.57 (17,81)	42.12 (18,95)	44.67 (20,10)	47.22 (21,25)	49.80 (22,41)	52.32 (23,54)	84.87 (24,69)
			PN 160	42.18 (18,98)	44.73 (20,13)	47.30 (21,29)	49.85 (22,43)	52.40 (23,58)	54.94 (24,72)	57.49 (25,87)	60.03 (27,01)	63.62 (28,63)
			PN 16	19.38 (8,72)	22.40 (10,08)	25.45 (11,45)	28.53 (12,84)	31.55 (14,20)	34.60 (15,57)	37.65 (16,94)	40.67 (18,30)	28.55 (12,85)
			PN 40	23.48 (10,57)	26.49 (11,92)	29.54 (13,29)	32.63 (14,68)	35.65 (16,04)	38.70 (17,42)	41.75 (18,79)	44.77 (20,15)	32.64 (14,69)
	DN 100	Headbox	PN 63	29.99 (13,50)	33.00 (14,85)	36.05 (16,22)	39.14 (17,61)	42.16 (18,97)	45.21 (20,34)	48.26 (21,72)	51.28 (23,08)	39.15 (17,62)
			PN 100	37.52 (16,88)	40.54 (18,24)	43.59 (19,62)	46.68 (21,01)	49.69 (22,36)	52.74 (23,73)	55.80 (25,11)	58.81 (26,46)	46.69 (21,01)
		_	PN 160	42.68 (19,21)	45.76 (20,59)	48.81 (21,96)	51.86 (23,34)	54.91 (24,71)	57.96 (26,08)	61.01 (27,45)	64.06 (28,83)	68.15 (30,67)

Table 84. EFW Extended Flanged Seal Weights Pounds (Kilograms)

				Extension length									
	Pij	pe size	Class	1-in. (25 mm)	2-in. (51 mm)	3-in. (76 mm)	4-in. (102 mm)	5-in. (127 mm)	6-in. (152 mm)	7-in. (178 mm)	8-in. (203 mm)	9-in. (229 mm)	
			10K	6.09 (2,74)	6.55 (2,95)	7.01 (3,15)	7.48 (3,37)	7.94 (3,57)	8.41 (3,78)	8.87 (3,99)	9.33 (4,20)	8.02 (3,61)	
		40A	20K	6.52 (2,93)	6.98 (3,14)	7.45 (3,35)	7.91 (3,56)	8.38 (3,77)	8.84 (3,98)	9,30 (4,19)	9.33 (4,20)	8.02 (3,81)	
	-		40k	9.64 (4,34)	10.10 (4,55)	10.57 (4,76)	11.03 (4,96)	11.50 (5,18)	11.96 (5,38)	12.43 (5,59)	12.89 (5,80)	11.85 (5,21)	
	10К			7.73 (3.48)	8,31 (3.74)	8,91 (4.01)	9,51 (4.28)	10,11 (4,55)	10.70 (4,82)	11.30 (5,08)	11.89 (5,35)	10.67 (4,80)	
		50A	20K	7.91 (3,56)	8.49 (3,82)	9.10 (4,10)	9.70 (4,37)	10.29 (4,63)	10.89 (4,90)	11,48 (5,17)	12.07 (5,43)	10,85 (4,88)	
			40K	11.18 (5,03)	11.76 (5,29)	12.37 (5,57)	13.00 (5,85)	13.56 (6,10)	14.16 (6,37)	14.75 (6,64)	15.35 (6,91)	14.12 (6,35)	
			10K	12.41 (5,58)	14.02 (6,31)	15.63 (7,03)	17.25 (7,76)	18.87 (8,49)	20.49 (9,22)	22.11 (9,95)	23.73 (10,68)	19.52 (8,78)	
	80A -	Schedule 40	20K	15.51 (6,98)	17.12 (7,70)	18.73 (8,43)	20.35 (9,16)	21.97 (9,89)	23.59 (10,62)	25.21 (11,34)	26.83 (12,07)	22.62 (10,18)	
S			40K	21.92 (9,86)	23.53 (10,59)	25.15 (11,32)	26.77 (12,05)	28.39 (12,78)	30.00 (13,50)	31.62 (14,23)	33.24 (14,96)	29.04 (13,07)	
۲.		Schedule 80	10K	12.09 (5,44)	13.32 (5,99)	14.63 (6,58)	15.91 (7,16)	17.20 (7,74)	18.49 (8,32)	19.78 (8,90)	21.06 (9,48)	16.68 (7,51)	
			20K	15.19 (6,84)	16.42 (7,39)	17.73 (7,98)	19.01 (8,55)	20.30 (9,14)	21.59 (9,72)	22.88 (10,30)	24.16 (10,87)	19.78 (8,90)	
			40K	21.60 (9,72)	22.83 (10,27)	24.14 (10,86)	25.43 (11,44)	26.72 (12,02)	28.00 (12,60)	29.29 (13,18)	30.58 (13,76)	26.19 (11,79)	
			10K	17.15 (7,72)	19.99 (9,00)	22.87 (10,29)	25.77 (11,60)	28.65 (12,89)	31.54 (14,19)	34.42 (15,49)	37.31 (16,79)	27.73 (12,48)	
		Schedule 40	20K	22.16 (9,97)	24.99 (11,25)	27.88 (12,55)	30.78 (13,85)	33.66 (15,15)	36.55 (16,45)	39.43 (17,74)	42.31 (19,04)	32.73 (14,73)	
	100		40K	35.21 (15,84)	38.05 (17,12)	40.94 (18,42)	43.83 (19,72)	46.72 (21,02)	49.60 (22,32)	52.49 (23,62)	55.37 (24,92)	45.79 (20,61)	
	A		10K	16.77 (7,55)	19.35 (8,71)	21.90 (9,86)	24.45 (11,00)	27.00 (12,15)	29.58 (13,31)	32.09 (14,44)	34.64 (15,59)	24.73 (11,13)	
		Schedule 80	20K	21.78 (9,80)	24.36 (10,96)	26.91 (12,11)	29.46 (13,26)	32.00 (14,40)	34.59 (15,57)	37.10 (16,70)	39.65 (17,84)	29.73 (13,38)	
		80	40K	34.83 (15,67)	37.41 (16,83)	39.96 (17,98)	42.51 (19,13)	45.06 (20,28)	47.64 (21,44)	50.16 (22,57)	52.71 (23,72)	42.79 (19,26)	

## Table 84. EFW Extended Flanged Seal Weights Pounds (Kilograms)

Figure 31. PFW Pancake Seal





A. Process flange B. Flushing connection C. Diaphragm

F. Flushing connection

G. Lower housing alignment clamp (option code SA)

Dimensions are in inches (millimeters).

	Pipe size	Class	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Number of bolts	Bolt circle "C" in. (mm)	Bolt hole diameter "D" in. (mm)	Standard diaphragm diameter "F" in. (mm)
		150	6.00 (152)	0.69 (18)	4	4.75 (121)	0.75 (19)	2.30 (58)
		300	6.50 (165)	0.81 (21)	8	5.00 (127)	0.75 (19)	2.30 (58)
	2-in.	600	6.50 (165)	1.00 (25)	8	5.00 (127)	0.75 (19)	2.30 (58)
NSI/ASME		900/1500	8.50 (216)	1.50 (38)	8	6.50 (165)	1.00 (25)	2.30 (58)
		2500	9.25 (235)	2.00 (51)	8	6.75 (172)	1.13 (29)	2.30 (58)
	3-in.	150	7.50 (191)	0.88 (22)	4	6.00 (152)	0.75 (19)	3.50 (89)
		300	8.25 (210)	1.06 (27)	8	6.62 (168)	0.88 (22)	3.50 (89)
A		600	8.25 (210)	1.25 (32)	8	6.62 (168)	0.88 (22)	3.50 (89)
		900	10.50 (267)	1.50 (38)	8	8.00 (203)	1.25 (32)	3.50 (89)
		1500	10.50 (267)	1.88 (48)	8	8.00 (203)	1.25 (32)	3.50 (89)
		2500	12.00 (305)	2.62 (67)	8	9.00 (229)	1.38 (35)	3.50 (89)
		PN 40	6.50 (165)	0.67 (17)	4	4.92 (125)	0.71 (18)	2.30 (58)
<u>.</u>		PN 63	7.09 (180)	0.91 (23)	4	5.31 (135)	0.87 (22)	2.30 (58)
92		PN 100	7.68 (195)	0.98 (25)	4	5.71 (145)	1.10 (28)	2.30 (58)
EN105		PN 40	7.87 (200)	0.83 (21)	8	6.30 (160)	0.71 (18)	3.50 (89)
		PN 63	8.46 (215)	0.98 (25)	8	6.69 (170)	0.87 (22)	3.50 (89)
	80 –	PN 100	9.06 (230)	0.98 (25)	8	7.09 (180)	1.10 (28)	3.50 (89)

#### Table 85. PFW Pancake Seal Dimensions

	Pipe size	Outer diameter "G" in. (mm)	Inner diameter "K" in. (mm)	Beveled diameter "L" in. (mm)	Thickness with 1/4NPT F.C. "M" in. (mm)	Thickness with 1/2 NPT F.C. "M" in. (mm)	Minimum gasket I.D. "N" in. (mm)	Weight lb (kg)
		3.62 (92)	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	2.5 (64)	8.61 (3,87)
		3.62 (92)	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	2.5 (64)	10.20 (4,59)
	2-in.	3.62 (92)	2.12 (54)	2.48 (63)	0.97 (25)	1.30 (33)	2.5 (64)	11.65 (5,24)
ш		3.62 (92)	2.12 (54)	N/A	0.97 (25)	1.30 (33)	2.5 (64)	24.84 (11,18)
NSI/ASM		3.62 (92)	2.12 (54)	N/A	0.97 (25)	1.30 (33)	2.5 (64)	36.92 (16,61)
	3-in	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.7 (94)	16.83 (7,57)
		5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.7 (94)	20.88 (9,40)
A		5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.7 (94)	23.35 (10,51)
	5-111.	5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.7 (94)	33.83 (15,22)
		5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.7 (94)	47.39 (19,98)
		5.00 (127)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.7 (94)	81.97 (36,89)
		4.00 (102)	2.40 (61)	N/A	0.97 (25)	1.30 (33)	2.5 (64)	10.67 (4,80)
<del>.</del>	DN 50	4.00 (102)	2.40 (61)	N/A	0.97 (25)	1.30 (33)	2.5 (64)	14.24 (6,41)
EN1092-1		4.00 (102)	2.40 (61)	N/A	0.97 (25)	1.30 (33)	2.5 (64)	16.89 (7,60)
		5.43 (138)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.7 (94)	18.76 (8,44)
	DN 80	5.43 (138)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.7 (94)	22.60 (10,17)
		5.43 (138)	3.60 (91)	N/A	0.97 (25)	1.30 (33)	3.7 (94)	27.07 (12,18)

Table 86. PFW Pancake Seal Dimensions

## Figure 32. FCW Flush Flanged Seal – RTJ Gasket Surface Two-Piece Design (Shown with Flushing Ring)



D. Connection to transmitter

A. Process flange B. Diaphragm

Dimensions are in inches (millimeters).

Tut				eee hange type h	ush Blaphi ughi se	a.		
	Pipe size	Class	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Bolt circle diameter "C" in. (mm)	Bolt hole diameter "D" in. (mm)	Overall height "H" in. (mm)	Raised face height "J" in. (mm)
		150	6.00 (152)	0.69 (18)	4.75 (121)	0.75 (19)	2.43 (62)	0.68 (17)
ASME		300	6.50 (165)	0.82 (21)	5.00 (127)	0.75 (19)	2.43 (62)	0.68 (17)
	2-in.	600	6.50 (165)	1.00 (25)	5.00 (127)	0.75 (19)	2.43 (62)	0.68 (17)
		1500	8.50 (216)	1.50 (38)	6.50 (165)	1.00 (25)	2.57 (65)	0.82 (21)
'IS		2500	9.25 (235)	2.00 (51)	6.75 (171)	1.14 (29)	3.07 (78)	0.82 (21)
AN		150	7.50 (191)	0.88 (22)	6.00 (152)	0.75 (19)	2.43 (62)	0.68 (17)
		300	8.25 (210)	1.06 (27)	6.62 (168)	0.88 (22)	2.43 (62)	0.68 (17)
	3_in	600	8.25 (210)	1.25 (32)	6.62 (168)	0.88 (22)	2.43 (62)	0.68 (17)
	5-111.	900	9.50 (241)	1.50 (38)	7.50 (191)	1.00 (25)	2.57 (65)	0.82 (21)
		1500	10.50 (267)	1.88 (48)	8.00 (203)	1.25 (32)	3.07 (78)	0.82 (21)
		2500	12.00 (305)	2.62 (67)	9.00 (229)	1.38 (35)	4.07 (103)	0.82 (21)

#### Table 87. Dimensions for FCW Two-Piece Flange Type Flush Diaphragm Seal

	Pipe size	RTJ diameter "E" in. (mm)	Diaphragm diameter "F" in. (mm)	Raised face diameter "G" in. (mm)	Inner diameter "K" in. (mm)	Thickness with ¹ /4NPT F.C. "L" in. (mm)	Thickness with 1/2 NPT F.C. "L" in. (mm)	Weight lb (kg)
		3.25 (83)	2.30 (58)	4.00 (102)	2.12 (54)	1.40 (36)	1.70 (43)	8.78 (3,95)
ш		3.25 (83)	2.30 (58)	4.25 (108)	2.12 (54)	1.40 (36)	1.70 (43)	10.56 (4,75)
SME	2-in.	3.25 (83)	2.30 (58)	4.25 (108)	2.12 (54)	1.40 (36)	1.70 (43)	12.01 (5,40)
I/AS		3.75 (95)	2.30 (58)	4.88 (124)	2.12 (54)	1.40 (36)	1.70 (43)	26.81 (12,06)
NSI		4.00 (102)	3.50 (89)	5.25 (133)	2.12 (54)	1.40 (36)	1.70 (43)	39.98 (17,99)
A		4.50 (114)	3.50 (89)	5.25 (133)	3.60 (91)	1.50 (38)	1.80 (46)	16.04 (7,22)
		4.88 (124)	3.50 (89)	5.75 (146)	3.60 (91)	1.50 (38)	1.80 (46)	20.72 (9,32)
	3_in	4.88 (124)	3.50 (89)	5.75 (146)	3.60 (91)	1.50 (38)	1.80 (46)	23.19 (10,44)
	J-111.	4.88 (124)	3.50 (89)	6.12 (155)	3.60 (91)	1.50 (38)	1.80 (46)	35.56 (16,00)
		5.38 (137)	3.50 (89)	6.62 (168)	3.60 (91)	1.50 (38)	1.80 (46)	50.72 (22,82)
		5.00 (127)	3.50 (89)	6.62 (168)	3.60 (91)	1.50 (38)	1.80 (46)	86.12 (38,75)

Table 88 Dimensional	Table for FCW 2-Pie	ece Flange Type F	lush Dianhragm Seal
		ce mange type i	iusii Diapinagin Scar

## Figure 33. RCW Flanged Remote Seal RTJ and Flushing Connection Ring





A. Process flange B. Diaphragm

Dimensions are in inches (millimeters).

C. Flushing connection D. Connection to transmitter

Pipe			Flange diameter	Flange	Bolt circle	Bolt hole	Lower housing	RTJ groove	Lower housing	Overall "H" in.	height (mm)	
	Pipe size	Class	diameter "A" in. (mm)	thickness "B" in. (mm)	diameter "C" in. (mm)	diameter "D" in. (mm)	inner diameter "E" in. (mm)	diameter "F" in. (mm)	outer diameter "G" in. (mm)	No or 1/4-in. NPT flush connection	¹ /2-in. NPT flush connection	lb (kg)
	¹ /2-in.	2500	5.25 (133)	1.19 (30)	3.50 (89)	0.88 (22)	0.62 (16)	1.69 (43)	2.64 (67)	2.88 (73)	3.18 (81)	1.49 (0,67)
		300/600	4.62 (117)	0.62 (16)	3.25 (83)	0.75 (19)	0.82 (21)	1.69 (43)	2.64 (67)	2.88 (73)	3.18 (81)	5.22 (2,35)
	³ /4-in.	900/1500	5.12 (130)	1.00 (25)	3.50 (89)	0.88 (22)	0.82 (21)	1.75 (45)	2.64 (67)	2.88 (73)	3.18 (81)	7.45 (3,35)
		2500	5.50 (140)	1.25 (32)	3.75 (95)	0.88 (22)	0.82 (21)	2.00 (51)	2.90 (74)	2.88 (73)	3.18 (81)	10.11 (4,55)
	1-in.	150	4.25 (108)	0.50 (13)	3.12 (79)	0.63 (16)	1.05 (27)	1.88 (48)	2.64 (67)	2.88 (73)	3.18 (81)	4.38 (1,97)
		300	4.88 (124)	0.62 (16)	3.50 (89)	0.75 (19)	1.05 (27)	2.00 (51)	2.77 (70)	2.88 (73)	3.18 (81)	5.67 (2,55)
ASME		600	4.88 (124)	0.69 (183)	3.50 (89)	0.75 (19)	1.05 (27)	2.00 (51)	2.77 (70)	2.88 (73)	3.18 (81)	5.95 (2,68)
<b>ISN</b>		900/1500	5.88 (149)	1.12 (29)	4.00 (102)	1.00 (25)	1.05 (27)	2.00 (51)	2.83 (72)	2.88 (73)	3.18 (81)	10.15 (4,57)
4		2500	6.25 (159)	1.38 (35)	4.25 (108)	1.00 (25)	1.05 (27)	2.38 (60)	3.27 (83)	2.88 (73)	3.18 (81)	14.55 (6,55)
		150	5.00 (127)	0.62 (16)	3.88 (98)	0.63 (16)	1.61 (41)	2.56 (65)	3.27 (83)	2.88 (73)	3.18 (81)	6.78 (3,05)
		300	6.12 (156)	0.75 (19)	4.50 (114)	0.88 (22)	1.61 (41)	2.69 (68)	3.58 (91)	2.88 (73)	3.18 (81)	10.01 (4,50)
	1 ¹ /2-in.	600	6.12 (156)	0.88 (22)	4.50 (114)	0.88 (22)	1.61 (41)	2.69 (68)	3.58 (91)	2.88 (73)	3.18 (81)	10.90 (4,91)
		900/1500	7.00 (178)	1.25 (32)	4.88 (124)	1.12 (28)	1.61 (41)	2.69 (68)	3.64 (93)	2.88 (73)	3.18 (81)	16.43 (7,39)
	-	2500	8.00 (203)	1.75 (45)	5.75 (146)	1.25 (32)	1.61 (41)	3.25 (83)	4.52 (115)	2.88 (73)	3.18 (81)	29.39 (13,23)

## Figure 34. FUW Flush Flanged Type Seal - EN1092-1 Type D



A. Process flange B. Diaphragm C. Connection to transmitter

Dimensions are in inches (millimeters).

## Table 90. FUW Flush Flanged Type Seal Dimensions

	Pipe size	Class	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Bolt circle "C" in. (mm)	Bolt hole diameter "D" in. (mm)	Number of bolts	Standard diaphragm diameter "F" in. (mm)	Raised face diameter "G" in. (mm)	Groove O.D. "J"	Groove I.D. "K"	Groove depth "L"	Weight lb (kg)
EN 1092-1	DN 50	PN 40	6.50 (165)	0.79 (20)	4.92 (125)	0.71 (18)	4	2.30 (58)	4.00 (102)	3.46 (88)	2.83 (72)	0.16 (4,00)	6.29 (2,83)
	DN 80	PN 40	7.87 (200)	0.94 (24)	6.30 (160)	0.71 (18)	8	3.50 (89)	5.43 (138)	4.76 (121)	4.13 (105)	0.16 (4,00)	11.29 (5,08)

## Figure 35. FVW Flush Flanged Type Seal - EN1092-1 Type C



	Pipe size	Class	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Bolt circle "C" in. (mm)	Bolt hole diameter "D" in. (mm)	Number of bolts	Standard diaphragm diameter "F" in. (mm)	Groove O.D. "J" in. (mm)	Tongue I.D. "K" in. (mm)	Tongue depth "L" in. (mm)	Weight lb (kg)
92-1	DN 50	PN 40	6.50 (165)	0.79 (20)	4.92 (125)	0.71 (18)	4	2.30 (58)	3.43 (87)	2.87 (73)	0.18 (4,50)	5.52 (2.48)
EN 10	DN 80	PN 40	7.87 (200)	0.94 (24)	6.30 (160)	0.71 (18)	8	3.50 (89)	4.72 (120)	4.17 (106)	0.18 (4,50)	10.01 (4,50)

## Figure 36. RTW Threaded Seal





C. Lower housing or flushing connection D. Connection to transmitter

A. Upper housing

B. Diaphragm

Dimensions are in inches (millimeters).

#### Table 92. RTW Threaded Seal Dimensions

Pating	Overall diameter 'A' in.	Overall height "B" in. (mm)				
Kating	(mm)	No or 1/4-in. NPT flush connection	¹ /2-in. NPT flush connection			
2500 psi (173 bar)	3.74 (95)	2.47 (63)	2.82 (72)			
5000 psi (345 bar)	3.74 (95)	1.95 (50)	2.31 (59)			
10000 psi (690 bar)	4.00 (102)	1.95 (50)	N/A			

#### Table 93. RTW Threaded Seal Weights Pounds (Kilograms)

	Dina siza		Class							
	ripe size	1500 psi	2500 psi	5000 psi	10000 psi	103 bar	172 bar	344 bar		
	¹ /4–18 NPT	10.73 (4,83)	6.15 (2,77)	5.72 (2,57)	6.95 (3,13)	N/A	N/A	N/A		
	³ /8–18 NPT	10.72 (4,82)	6.13 (2,76)	5.70 (2,57)	6.93 (3,12)	N/A	N/A	N/A		
ANSI/ASME	¹ /2–14 NPT	10.67 (4,80)	6.09 (2,74)	5.66 (2,55)	6.89 (3,10)	N/A	N/A	N/A		
	³ /4–14 NPT	10.62 (4,78)	6.03 (2,71)	5.60 (2,52)	6.83 (3,07)	N/A	N/A	N/A		
	1–11.5 NPT	10.52 (4,73)	5.93 (2,67)	5.50 (2,48)	6.73 (3,03)	N/A	N/A	N/A		
	1 ¹ /4–11.5 NPT	10.38 (4,67)	5.76 (2,59)	5.33 (2,40)	6.56 (2,95)	N/A	N/A	N/A		
	1 ¹ /2–11.5 NPT	10.23 (4,60)	5.61 (2,52)	5.18 (2,33)	6.41 (2,88)	N/A	N/A	N/A		
92 - 1	Parallel thread: G ¹ /2 A DIN 16288	N/A	N/A	N/A	N/A	12.93 (5,82)	7.07 (3,18)	6.64 (3,00)		
EN 103	Tapered thread: R ¹ /2 per ISO 7/1	N/A	N/A	N/A	N/A	10.67 (4,80)	6.10 (2,75)	5.67 (2,55)		

Figure 37. HTS Male Threaded Seal





A. Connection to transmitter B. Diaphragm

Dimensions are in inches (millimeters).

Process type	Connection size	Outer diameter "A" in. (mm)	Diaphragm diameter "B" in. (mm)	Length "C" in. (mm)	Overall height "D" in. (mm)	Weight lb (kg)
ANSI NPT	1-in. NPT	2.03 (51,6)	1.09 (27,9)	1.24 (31,5)	2.50 (63,5)	1.60 (0,72)
	1 ¹ /2-in. NPT	2.36 (59,9)	1.70 (43,2)	1.24 (31,5)	2.50 (63,5)	2.32 (1,04)
	2-in. NPT	2.74 (69,6)	1.90 (48,3)	1.24 (31,5)	2.50 (63,5)	3.09 (1,39)
ISO 228-1 BSP	G1 BSP	2.03 (51,6)	1.09 (27,9)	0.87 (22,0)	2.15 (54,6)	1.48 (0,67)
	G1 ¹ /2 BSP	2.36 (59,9)	1.70 (43,2)	0.98 (24,9)	2.24 (56,9)	2.10 (0,95)
	G2 BSP	2.74 (69,6)	1.90 (48,3)	1.24 (31,5)	2.50 (63,5)	3.06 (1,38)

## Figure 38. SCW Tri-Clamp Seal



A. Connection to transmitter B. Diaphragm

Dimensions are in inches (millimeters).

Pipe size	Outer diameter "A" in. (mm)	O-ring groove diameter "B" in. (mm)	Diaphragm diameter "C" in. (mm)	Weight Ib (kg)
1 ¹ /2-in.	2.00 (51)	1.72 (44)	1.21 (31)	0.97 (0,44)
2-in.	2.50 (64)	2.22 (56)	1.68 (43)	1.23 (0,55)
2 ¹ /2-in.	3.05 (77)	2.78 (71)	2.07 (53)	1.56 (0,70)
3-in.	3.58 (91)	3.28 (83)	2.58 (66)	1.98 (0,89)
4-in.	4.68 (119)	4.35 (110)	3.66 (93)	3.02 (1,36)



#### **Note** Wetted surfaces of Spud are 32 Ra max.

#### Table 96. SSW Tank Spud Seal Dimensions

Pipe size	Extension length	"B" in. (mm)	Weight lb (kg)	
4-in. SCH 5	2-in.	2.12 (54)	9.20 (4,14)	
	6-in.	6.12 (156)	12.66 (5,70)	

## Figure 40. STW Hygienic Thin Wall Tank Spud Seal



Figure 41. EES Hygienic Flanged Tank Spud Extended Seal



Dimensions are in inches (millimeters).

Pipe size	Flange diameter "A" in. (mm)	Flange thickness "B" in. (mm)	Number of bolts	Bolt circle diameter "C" in. (mm)	Standard diaphragm diameter "D" in. (mm)	Extension diameter "E" in. (mm)	Bolt hole diameter "F" in. (mm)	Weight lb (kg)
DN50	6.50 (165)	0.79 (20)	4	4.92 (125)	2.99 (76)	3.24 (82)	0.55 (14)	10.48 (4,72)
DN80	7.87 (200)	0.94 (24)	8	6.30 (160)	4.04 (102)	4.24 (108)	0.55 (14)	17.34 (7,80)

## Figure 42. VCS Tri-Clamp In-Line Seal





Dimensions are in inches (millimeters).

#### Table 98. VCS Tri-Clamp In-Line Seal Dimensions

Pipe size	Inner diameter "A" in. (mm)	Groove diameter "B" in. (mm)	Flange diameter "C" in. (mm)	Outer diameter "D" in. (mm)	Weight lb (kg)
1-in.	0.87 (22)	1.72 (44)	1.99 (51)	2.33 (59)	2.67 (1,20)
1 ¹ /2-in.	1.37 (35)	1.72 (44)	1.99 (51)	2.73 (69)	2.69 (1,21)
2-in.	1.87 (48)	2.22 (56)	2.52 (64)	3.19 (81)	3.43 (1,54)
3-in.	2.87 (73)	3.28 (83)	3.58 (91)	4.14 (105)	4.76 (2,14)
4-in.	3.82 (97)	4.35 (110)	4.69 (119)	5.06 (129)	6.24 (2,81)

#### Figure 43. SVS VARIVENT Compatible Connection Seal



Weight lb (kg): 1.13 (0,51)



A. Connection to transmitter b. Diaphragm

Dimensions are in inches (millimeters).

## Figure 44. SHP Cherry-Burrell "I" Line Seal



#### Table 99. SHP Cherry-Burrell "I" Line Seal Dimensions

Size	Outer diameter "A" in. (mm)	Extension diameter "B" in. (mm)	Weight lb (kg)
2-in.	2.64 (67)	2.24 (57)	0.74 (0,33)
3-in.	3.88 (98)	3.31 (84)	1.76 (0,79)

### Figure 45. SLS Hygienic Dairy Process Connection Female Thread Seal per DIN 11851





A. Connection to transmitter B. Diaphragm

Dimensions are in inches (millimeters)

#### Table 100. SLS Hygienic Dairy Process Connection Female Thread Seal per DIN 11851 Dimensions

Female thread	Process size/ rating	Hub diameter "A" in. (mm)	"B" in. (mm)	Thread diameter "C" in. (mm)	Hub height "D" in. (mm)	"E" in. (mm)	Weight lb (kg)
DIN	DN 40 PN 40	1.89 (48)	2.20 (56)	Rd 65 x ¹ /6-in.	1.18 (30)	0.39 (10)	1.61 (0,72)
11851	DN 50 PN 25	2.40 (61)	2.70 (69)	Rd 78 x 1/6-in.	1.22 (31)	0.43 (11)	2.32(1,04)

## Figure 46. WSP Saddle Seal



A. Upper housing B. Connection to transmitter C. Diaphragm

Dimensions are in inches (millimeters).

#### Table 101. WSP Saddle Seal Dimensions

Sizo	Overall height	Inner diameter "B" in. (mm)	Outer diameter "C" in. (mm)	Bolt circle diameter "D" in. (mm)		
Size	"A" in. (mm)			6-Bolt	8-Bolt	
2-in.	2.72 (69)	1.50 (38)	2.50 (64)	2.99 (76)	2.91 (74)	
3-in.	2.46 (63)	2.01 (51)	3.02 (77)	2.99 (76)	2.91 (74)	
4-in. and larger	2.60 (66)	2.01 (51)	3.00 (76)	2.99 (76)	2.91 (74)	

#### Table 102. WSP Saddle Seal Weights

	Pipe size	Class	Weights lb (kg)
ANSI/ASME	2-in.	1250 psig	4.61 (2,09)
		1500 psig	4.63 (2,10)
	3-in.	1250 psig	4.36 (1,98)
		1500 psig	4.38 (1,99)
	4-in.	1250 psig	5.46 (5,48)
		1500 psig	5.60 (2,54)

## Figure 47. UCP and PMW Threaded Pipe Mount Seals



Weights lb (kg): 1.33 (0,60)

PMW



Weight lb (kg): 0.77 (0,35)

A. Connection to transmitter B. Diaphragm

Dimensions are in inches (millimeters).





Ø0.33

Ø4.99[127] Ø4.38[111]

Ø3.50[89]

В

## Figure 48. CTW Chemical Tee Seal



Weight lb (kg): 4.18 (1,88)

A. Connection to transmitter B. Diaphragm

Dimensions are in inches (millimeters).

Figure 49. TFS Wafer Style In-Line Seal



0.50[13]

B. Diaphragm

Dimensions are in inches (millimeters).

#### Table 103. TFS Wafer Style In-Line Seal Dimensions

Pipe size	Flange face diameter "A" in. (mm)	Outer diameter "B" in. (mm)	Inner diameter "C" in. (mm)	Weight lb (kg)
1-in.	2.00 (51)	2.64 (67)	1.090 (28)	3.91 (1,76)
1 ¹ /2-in.	2.88 (73)	3.23 (82)	1.61 (41)	5.73 (2,58)
2-in.	3.62 (92)	3.74 (95)	2.07 (52)	7.42 (3,34)
3-in.	5.00 (127)	5.00 (127)	3.07 (78)	12.20 (5,49)
4-in.	6.19 (157)	6.19 (157)	4.00 (102)	17.56 (7,90)
DN25	2.68 (68)	2.72 (69)	1.09 (28)	4.76 (2,14)
DN40	3.46 (88)	3.46 (88)	1.61 (41)	7.35 (3,31)
DN50	4.02 (102)	4.09 (104)	1.99 (51)	9.97 (4,49)
DN80	5.43 (138)	5.47 (139)	3.24 (82)	15.24 (6,86)
DN100	6.38 (162)	6.46 (164)	4.22 (107)	18.69 (8,41)

## Figure 50. WFW Flow-Thru Flanged Seal



Dimensions are in inches (millimeters).

#### Table 104. WFW Flow-Thru Flanged Seal Dimensions

Nominal pipe size	ANSI Class	Overall length "A" in. (mm)	Upper to centerline height "B" in (mm)	Bolt circle diameter "C" in. (mm)	Outside diameter "D" in. (mm)	Bolt hole diameter "E" in. (mm)	Flange thickness "F" in. (mm)	Weight lb (kg)
1-in.		7.00 (178)	2.40 (61)	3.12 (79)	4.25 (108)	0.62 (16)	0.50(13)	11.80 (5,31)
2-in.	150	9.00 (229)	3.31 (84)	4.75 (121)	6.00 (152)	0.75 (19)	0.69 (18)	23.66 (10,73)
3-in.		11.00 (279)	3.61 (92)	6.00 (152)	7.50 (191)	0.75 (19)	0.88 (22)	29.08 (13,09)

#### Table 105. Capillary and Support Tube Weights Measured per Foot (.30 m) of Capillary

1 2 11	<u> </u>
Part	Weight lb (kg)
0.03-in. ID, SST armor	0.095 (0,043)
0.04-in. ID, SST armor	0.091 (0,041)
0.075-in. ID, SST armor	0.100 (0,045)
0.03-in. ID, PVC armor	0.105 (0,048)
0.04-in. ID, PVC armor	0.100 (0,045)
0.075-in. ID, PVC armor	0.110 (0,050)
Capillary adapter	0.085 (0,039)
2-in. support tube	0.035 (0,016)
4-in. support tube	0.090 (0,041)

00813-0100-4016. Rev RF

## **Global Headquarters**

#### **Emerson Automation Solutions**

6021 Innovation Blvd. Shakopee, MN 55379, USA +1 800 999 9307 or +1 952 906 8888 +1 952 949 7001 a RFQ.RMD-RCC@Emerson.com 

## **North America Regional Office**

#### **Emerson Automation Solutions**

8200 Market Blvd. Chanhassen, MN 55317, USA +1 800 999 9307 or +1 952 906 8888 +1 952 949 7001 0 RMT-NA.RCCRFQ@Emerson.com

## Latin America Regional Office

#### **Emerson Automation Solutions**

1300 Concord Terrace, Suite 400 Sunrise, FL 33323, USA

+1 954 846 5030

+1 954 846 5121 

RFQ.RMD-RCC@Emerson.com

## **Europe Regional Office**

# **Emerson Automation Solutions Europe GmbH**

Neuhofstrasse 19a P.O. Box 1046 CH 6340 Baar Switzerland +41 (0) 41 768 6111

+41 (0) 41 768 6300

RFQ.RMD-RCC@Emerson.com 

# **Asia Pacific Regional Office**

#### **Emerson Automation Solutions**

1 Pandan Crescent Singapore 128461 +65 6777 8211 +65 6777 0947 0 Enquiries@AP.Emerson.com

## Middle East and Africa Regional Office

#### **Emerson Automation Solutions**

Emerson FZE P.O. Box 17033 Iebel Ali Free Zone - South 2 Dubai, United Arab Emirates +971 4 8118100 +971 4 8865465 A RFQ.RMTMEA@Emerson.com



Linkedin.com/company/Emerson-Automation-Solutions



Twitter.com/Rosemount_News





Youtube.com/user/RosemountMeasurement



Google.com/+RosemountMeasurement

Standard Terms and Conditions of Sale can be found on the Terms and Conditions of Sale page.

The Emerson logo is a trademark and service mark of Emerson Electric Co.

ERS, Plantweb, Scalable, SuperModule, Instrument Toolkit, UltraTherm, MultiVariable, Tuned-System, Rosemount, and Rosemount logotype are trademarks of Emerson.

3-A is a registered trademark of 3-A Sanitary Standards, Inc. Cherry-Burrell is a registered trademark of SPX Flow, Inc. Corporation eurofast and minifast are registered trademarks of TURCK. Fluorinert is a trademark of 3M. FOUNDATION Fieldbus is a trademark of the FieldComm Group

GRAFOIL is a registered trademark of GrafTech International Holdings Inc

NEMA is a registered trademark and service mark of the National Electrical Manufacturers Association. Tri-Clamp is a registered trademark of Alfa Laval Corp., Sweden.

National Electrical Code is a registered trademark of National Fire Protection Association, Inc.

HART and WirelessHART are registered trademarks of the FieldComm Group.

Ladish is a trademark of Hackney Ladish, Inc. NACE is a registered trademark of NACE International. Neobee is a registered trademark of Stepan Specialty Products, LLC. PROFIBUS is a registered trademark of PROFINET International (PI). Thermo-Tork is a registered trademark of Armstrong World Industries, Inc. Corporation.

Syltherm is a trademark of Dow Corning Corporation. VÁRIVENT is a registered trademark of GEA Process Engineering Limited. All other marks are the property of their respective owners. © 2017 Emerson. All rights reserved.

